

MTA-SABUETI, Georgia

WMO: 374090

Lat: 42.034N

Lon: 43.475E

Elev: 1246

StdP: 87.23

Time Zone: 4.00 (E04)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-10.5	-8.7	-12.3	1.5	-7.3	-10.3	1.8	-6.6	19.1	-8.3	16.5	-5.3	8.8	90	0.766

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.1	27.0	19.7	25.4	19.0	23.8	18.5	21.2	24.8	20.1	23.6	19.2	22.4	7.7	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
20.0	17.2	23.1	19.0	16.1	22.1	18.1	15.2	20.9	68.0	24.7	64.1	23.6	60.6	22.4	26.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
17.2	14.7	13.3	-11.8	29.1	3.1	1.6	-14.0	30.3	-15.8	31.2	-17.6	32.1	-19.9	33.2		
			-11.9	23.6	3.3	1.4	-14.3	24.6	-16.2	25.4	-18.0	26.1	-20.4	27.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	8.1	-2.1	-1.4	1.5	6.8	11.9	15.6	17.5	18.9	14.7	9.3	3.8	0.1
	DBStd	8.16	3.45	4.15	3.94	4.26	3.16	2.67	2.97	2.92	3.36	3.64	4.36	3.71
	HDD10.0	1651	374	320	265	113	18	1	0	0	5	57	189	308
	HDD18.3	3821	633	553	523	348	200	87	52	28	114	281	436	566
	CDD10.0	957	0	0	0	16	77	170	232	277	147	34	3	1
	CDD18.3	84	0	0	0	0	0	6	26	47	6	0	0	0
	CDH23.3	437	0	0	0	1	3	25	128	252	28	0	0	0
	CDH26.7	62	0	0	0	0	0	1	12	49	1	0	0	0
Wind	WSAvg	6.4	6.1	6.9	6.9	6.6	6.1	5.8	5.9	6.5	6.6	6.7	6.5	6.0
Precipitation	PrecAvg	1079	115	93	100	85	89	86	62	60	76	96	110	108
	PrecMax	1378	246	212	190	145	163	182	127	111	146	189	238	221
	PrecMin	809	31	41	37	37	37	31	24	16	2	35	14	35
	PrecStd	129	57	42	37	23	29	31	25	22	33	39	64	42
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.1	10.6	13.2	20.1	23.2	26.1	28.0	30.5	26.2	20.1	16.0	12.9
		MCWB	3.3	6.1	7.7	12.8	16.4	19.8	21.5	19.1	19.1	15.6	9.2	7.0
	2%	DB	5.0	8.3	10.8	17.7	20.6	23.8	26.4	27.9	24.0	17.7	13.4	8.9
		MCWB	2.1	4.8	6.5	11.9	15.1	18.6	19.9	19.3	18.1	13.8	7.9	5.4
	5%	DB	3.6	6.1	9.2	15.7	19.1	22.3	24.7	26.1	21.6	16.0	11.4	6.8
		MCWB	1.4	2.9	5.7	10.6	14.5	17.9	18.9	19.1	17.1	12.7	7.0	3.6
	10%	DB	2.2	4.2	7.5	13.7	17.4	20.8	22.9	24.3	19.9	14.3	9.5	5.2
		MCWB	0.7	1.9	4.7	9.5	13.5	17.0	18.5	18.7	16.0	11.7	6.3	2.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.0	7.1	8.6	14.1	17.8	21.0	22.6	22.6	21.0	16.3	10.8	7.9
		MCDB	6.0	9.5	11.4	19.0	21.2	24.2	26.7	27.0	25.1	19.1	13.5	10.3
	2%	WB	2.9	5.3	7.2	12.2	16.2	19.6	21.1	21.2	19.0	14.4	9.2	5.8
		MCDB	4.2	7.7	10.2	17.0	19.5	22.7	24.6	25.0	22.3	16.9	11.0	8.3
	5%	WB	1.9	3.4	6.1	11.0	15.0	18.5	20.0	20.3	17.6	13.2	8.0	4.4
		MCDB	3.0	5.3	8.4	15.3	18.1	21.3	23.1	23.9	20.6	15.2	9.9	6.2
	10%	WB	1.0	2.2	5.0	9.7	13.9	17.5	19.0	19.3	16.4	12.2	6.8	3.2
		MCDB	2.1	3.8	7.0	13.0	16.6	20.1	22.0	22.8	19.1	13.8	9.0	4.7
Mean Daily Temperature Range	5% DB	MDBR	4.5	5.2	6.1	7.9	7.7	8.0	7.8	9.1	8.0	6.7	5.5	4.7
		MCDBR	7.0	8.7	9.2	11.5	10.6	10.5	11.1	11.9	10.7	9.3	8.7	7.3
		MCWBR	5.0	6.1	5.8	6.7	6.7	6.6	6.4	6.3	6.2	5.7	5.4	4.9
	5% WB	MCDBR	5.9	7.7	7.9	11.1	9.7	9.8	10.0	10.7	10.1	8.7	7.2	6.1
		MCWBR	4.6	5.7	5.4	6.9	6.6	6.8	6.5	7.1	6.6	5.7	5.1	4.5
Clear-Sky Solar Irradiance	taub	0.283	0.313	0.361	0.408	0.381	0.371	0.398	0.399	0.351	0.341	0.300	0.279	
	taud	2.375	2.297	2.223	2.154	2.317	2.394	2.342	2.335	2.455	2.440	2.500	2.437	
	Ebn at Noon	866	887	879	860	893	901	872	860	884	849	845	843	
	Edh at Noon	80	103	125	145	126	117	122	120	99	89	72	70	
All-Sky Solar Radiation	RadAvg	1.76	2.78	3.58	4.43	5.21	5.89	6.00	5.60	4.48	3.01	2.01	1.50	
	RadStd	0.22	0.38	0.43	0.50	0.52	0.41	0.50	0.43	0.42	0.32	0.26	0.16	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (15 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page