

TELAVI, Georgia

WMO: 375530

Lat: 41.9281N

Lon: 45.5122E

Elev: 1857

StdP: 13.74

Time Zone: 4.00 (E04)

Period: 05-16

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	19.2	22.6	10.8	10.2	23.1	13.8	11.9	26.6	18.2	47.6	11.3	43.8	1.9	180	0.363

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	19.5	92.8	73.1	90.4	71.5	87.4	70.2	74.4	90.4	72.7	88.0	71.1	85.7	3.5	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
68.9	113.8	86.0	67.2	107.2	83.0	65.7	101.6	80.5	39.3	90.6	37.6	88.2	36.2	85.9	84.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10.6	7.7	6.3	14.3	96.7	5.5	4.3	10.3	99.8	7.1	102.3	4.0	104.8	0.0	107.9
			12.7	76.2	5.0	4.9	9.1	79.7	6.1	82.5	3.3	85.3	-0.3	88.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	56.0	36.1	38.1	46.4	55.0	63.0	70.7	75.8	76.0	67.9	57.5	46.5	38.4
	DBStd	15.46	6.90	7.86	6.75	6.72	5.07	4.81	4.71	5.81	5.72	6.46	6.38	6.08
	HDD50	1465	433	337	151	27	1	0	0	0	0	16	138	362
	HDD65	4298	897	754	577	304	98	8	1	3	36	240	555	825
	CDD50	3671	0	3	40	178	403	622	798	807	536	249	33	2
	CDD65	1031	0	0	1	4	35	181	335	345	122	8	0	0
	CDH74	8508	0	0	1	31	189	1274	2896	3366	720	31	0	0
	CDH80	3284	0	0	0	1	18	357	1129	1585	192	2	0	0
Wind	WSAvg	2.8	2.6	2.9	3.7	3.1	2.8	2.7	2.6	2.6	2.7	2.6	2.6	2.6
Precipitation	PrecAvg	29.8	1.1	1.4	2.2	3.3	4.1	3.4	2.5	2.6	2.4	2.6	1.7	1.2
	PrecMax	36.7	2.4	3.1	4.5	6.0	6.7	7.6	6.9	6.0	4.8	7.3	3.8	4.4
	PrecMin	21.7	0.0	0.0	0.5	1.4	1.1	0.2	0.2	0.0	0.1	0.6	0.1	0.0
	PrecStd	4.4	0.6	0.9	1.1	1.3	1.5	1.8	1.6	1.7	1.5	1.5	1.3	1.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	56.0	60.9	69.8	77.8	82.5	90.5	95.3	97.1	90.2	77.7	67.4	59.3
		MCWB	44.9	48.0	52.7	61.3	67.3	72.2	74.3	75.2	69.8	63.1	53.2	47.6
	2%	DB	51.9	56.0	64.6	73.9	78.4	86.9	91.6	93.8	85.0	73.2	63.0	54.3
		MCWB	42.3	45.6	50.3	59.5	63.9	70.1	72.5	73.7	68.9	60.8	51.5	45.4
	5%	DB	48.4	52.0	61.1	70.5	75.9	84.3	88.9	91.8	81.4	70.1	58.8	50.8
		MCWB	40.5	43.7	49.0	58.3	63.2	69.1	70.3	72.4	66.2	59.2	49.6	43.3
	10%	DB	45.3	48.4	57.7	67.2	73.3	81.1	86.4	89.2	77.8	67.0	55.4	47.3
		MCWB	39.1	41.7	47.4	56.3	62.1	67.6	69.6	71.4	64.0	57.4	48.2	41.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	46.1	49.0	53.9	62.5	68.1	73.7	76.4	78.0	71.6	64.7	55.7	48.5
		MCDB	54.0	58.1	67.3	75.2	80.2	87.7	92.7	94.9	85.6	75.7	61.9	57.5
	2%	WB	43.5	46.5	51.5	60.6	65.8	71.6	73.9	75.2	69.5	61.8	53.5	46.1
		MCDB	49.8	55.0	61.7	71.8	76.8	84.9	89.3	91.7	84.5	71.2	60.6	53.1
	5%	WB	41.4	44.3	49.8	58.9	64.3	70.1	72.2	73.4	67.2	60.0	51.1	44.0
		MCDB	47.3	51.5	58.9	69.4	74.3	82.6	86.8	89.7	79.8	68.5	57.0	49.7
	10%	WB	39.6	42.0	48.1	56.9	62.6	68.4	70.6	71.6	65.1	58.4	48.9	42.1
		MCDB	44.3	47.7	56.7	66.2	72.0	79.5	84.0	87.9	75.4	65.7	54.8	46.9
Mean Daily Temperature Range	5% DB	MDBR	12.6	12.3	15.2	15.9	15.8	17.2	17.8	19.5	17.0	14.4	13.6	13.1
		MCDBR	17.8	18.9	21.1	21.5	20.4	21.1	21.5	24.4	22.0	18.7	19.6	18.2
		MCWBR	11.7	11.5	11.8	11.6	11.2	10.8	9.8	12.2	10.1	9.3	11.5	11.9
	5% WB	MCDBR	15.7	17.9	17.9	19.9	18.4	20.2	20.5	23.1	20.5	17.4	17.4	16.4
		MCWBR	10.8	11.2	10.7	11.2	10.9	11.4	10.9	12.1	10.0	8.9	10.5	10.8
Clear-Sky Solar Irradiance	taub	0.331	0.370	0.424	0.488	0.459	0.452	0.499	0.489	0.428	0.401	0.352	0.329	
	taud	2.287	2.156	2.059	1.943	2.094	2.172	2.057	2.078	2.227	2.243	2.331	2.322	
	Ebn at Noon	252	258	257	249	261	263	248	246	254	245	243	242	
	Edh at Noon	28	38	47	57	50	47	52	49	40	35	27	25	
All-Sky Solar Radiation	RadAvg	578	826	1093	1384	1680	1952	1912	1761	1370	913	646	515	
	RadStd	62	103	118	190	128	134	159	177	121	103	73	65	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Regional (14 neighbors)		N/A	N/A	+2.21	N/A	+1.71	+1.69	N/A	N/A	N/A	N/A

Nomenclature: See separate page