

TELAVI, Georgia

WMO: 375530

Lat: 41.9281N

Lon: 45.5122E

Elev: 566

StdP: 94.71

Time Zone: 4.00 (E04)

Period: 05-16

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-7.1	-5.2	-11.8	1.5	-5.0	-10.1	1.7	-3.0	8.1	8.6	5.0	6.5	0.8	180	0.363

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	10.8	33.8	22.8	32.4	22.0	30.8	21.2	23.6	32.4	22.6	31.1	21.7	29.8	1.6	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
20.5	16.3	30.0	19.6	15.3	28.3	18.7	14.5	26.9	73.6	32.6	69.6	31.2	66.2	30.0	29.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 4.7	3.4	2.8	-9.9	36.0	3.1	2.4	-12.1	37.7	-13.8	39.1	-15.6	40.4	-17.8	42.2		
(5)			-10.7	24.6	2.8	2.7	-12.7	26.5	-14.4	28.1	-15.9	29.6	-18.0	31.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	13.4	2.3	3.4	8.0	12.8	17.2	21.5	24.3	24.5	19.9	14.2	8.1	3.6	(6)
(7)		DBStd	8.59	3.84	4.37	3.75	3.73	2.82	2.67	2.62	3.23	3.18	3.59	3.55	3.38	(7)
(8)		HDD10.0	814	241	187	84	15	1	0	0	0	0	9	77	201	(8)
(9)		HDD18.3	2388	498	419	321	169	54	4	1	2	20	133	308	458	(9)
(10)		CDD10.0	2039	0	2	22	99	224	346	443	448	298	138	18	1	(10)
(11)		CDD18.3	573	0	0	1	2	19	101	186	192	68	4	0	0	(11)
(12)		CDH23.3	4727	0	0	1	17	105	708	1609	1870	400	17	0	0	(12)
(13)		CDH26.7	1824	0	0	0	1	10	198	627	881	107	1	0	0	(13)
(14)	Wind	WSAvg	1.2	1.2	1.3	1.7	1.4	1.3	1.2	1.2	1.2	1.2	1.1	1.2	(14)	
(15)	Precipitation	PrecAvg	757	27	35	57	84	103	86	64	65	62	66	43	31	(15)
(16)		PrecMax	932	62	79	115	152	171	194	174	153	123	185	96	112	(16)
(17)		PrecMin	551	1	1	12	35	27	4	5	0	3	16	2	0	(17)
(18)		PrecStd	111	16	22	27	32	39	45	41	42	37	38	32	27	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.3	16.1	21.0	25.4	28.0	32.5	35.2	36.2	32.4	25.4	19.7	15.2	(19)
(20)			MCWB	7.1	8.9	11.5	16.3	19.6	22.4	23.5	24.0	21.0	17.3	11.8	8.6	(20)
(21)		2%	DB	11.0	13.3	18.1	23.3	25.8	30.5	33.1	34.3	29.4	22.9	17.2	12.4	(21)
(22)			MCWB	5.7	7.6	10.2	15.3	17.7	21.1	22.5	23.1	20.5	16.0	10.8	7.5	(22)
(23)		5%	DB	9.1	11.1	16.1	21.4	24.4	29.1	31.6	33.2	27.4	21.2	14.9	10.5	(23)
(24)			MCWB	4.7	6.5	9.4	14.6	17.3	20.6	21.3	22.4	19.0	15.1	9.8	6.3	(24)
(25)		10%	DB	7.4	9.1	14.3	19.5	22.9	27.3	30.2	31.8	25.4	19.4	13.0	8.5	(25)
(26)			MCWB	3.9	5.4	8.5	13.5	16.7	19.8	20.9	21.9	17.8	14.1	9.0	5.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.8	9.4	12.2	16.9	20.0	23.2	24.6	25.6	22.0	18.2	13.2	9.2	(27)
(28)			MCDWB	12.2	14.5	19.6	24.0	26.8	30.9	33.7	35.0	29.8	24.3	16.6	14.2	(28)
(29)		2%	WB	6.4	8.0	10.8	15.9	18.8	22.0	23.3	24.0	20.8	16.5	12.0	7.8	(29)
(30)			MCDWB	9.9	12.8	16.5	22.1	24.9	29.4	31.8	33.2	29.2	21.8	15.9	11.7	(30)
(31)		5%	WB	5.2	6.8	9.9	14.9	18.0	21.1	22.3	23.0	19.6	15.5	10.6	6.7	(31)
(32)			MCDWB	8.5	10.8	15.0	20.8	23.5	28.1	30.4	32.1	26.6	20.3	13.9	9.9	(32)
(33)		10%	WB	4.2	5.5	9.0	13.8	17.0	20.2	21.4	22.0	18.4	14.7	9.4	5.6	(33)
(34)			MCDWB	6.8	8.7	13.7	19.0	22.2	26.4	28.9	31.1	24.1	18.7	12.6	8.3	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	7.0	6.8	8.5	8.8	9.6	9.9	10.8	9.4	8.0	7.6	7.3	(35)	
(36)			MCDBR	9.9	10.5	11.7	12.0	11.3	11.7	11.9	13.6	12.2	10.4	10.9	10.1	(36)
(37)			MCWBR	6.5	6.4	6.6	6.5	6.2	6.0	5.4	6.8	5.6	5.2	6.4	6.6	(37)
(38)		5% WB	MCDWR	8.7	10.0	10.0	11.0	10.2	11.2	11.4	12.8	11.4	9.6	9.7	9.1	(38)
(39)			MCWBR	6.0	6.2	5.9	6.2	6.1	6.3	6.1	6.7	5.6	5.0	5.8	6.0	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.331	0.370	0.424	0.488	0.459	0.452	0.499	0.489	0.428	0.401	0.352	0.329	(40)	
(41)		taud	2.287	2.156	2.059	1.943	2.094	2.172	2.057	2.078	2.227	2.243	2.331	2.322	(41)	
(42)		Ebn at Noon	796	814	810	785	823	828	783	777	800	772	767	764	(42)	
(43)		Edh at Noon	89	119	148	179	158	147	163	155	125	109	86	80	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.82	2.60	3.44	4.36	5.30	6.15	6.03	5.55	4.32	2.88	2.04	1.62	(44)	
(45)		RadStd	0.20	0.33	0.37	0.60	0.40	0.42	0.50	0.56	0.38	0.33	0.23	0.20	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(47) Regional (14 neighbors)	N/A	N/A	+1.23	N/A	+0.95	+0.94	N/A	N/A	N/A		

Nomenclature: See separate page