

QUBA, Azerbaijan

WMO: 376750

Lat: 41.367N

Lon: 48.517E

Elev: 1811

StdP: 13.76

Time Zone: 4.00 (E04)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	15.8	19.5	11.0	10.3	19.8	14.6	12.3	24.7	17.8	51.4	13.4	40.0	4.2	0	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.4	91.4	68.9	88.5	68.4	85.9	67.8	73.1	85.4	71.5	83.4	70.0	81.6	7.9	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
69.3	115.0	80.2	67.4	107.9	78.2	66.0	102.6	76.7	38.0	85.3	36.5	83.5	35.1	81.8	82.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
13.7	10.4	9.0	10.2	98.1	6.0	3.6	5.9	100.7	2.4	102.7	-0.9	104.7	-5.3	107.3
			9.8	78.6	5.8	2.5	5.6	80.3	2.2	81.8	-1.1	83.2	-5.3	85.0
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	53.8	33.6	33.7	41.0	52.0	62.6	71.0	75.5	74.7	65.2	53.8	43.6	37.4	(6)
	DBStd	16.57	6.75	7.97	7.31	7.99	5.49	5.84	5.01	5.71	6.31	7.21	7.44	6.46	(7)
	HDD50	1980	512	459	291	68	1	0	0	0	43	214	392		(8)
	HDD65	5042	975	876	743	394	111	16	1	4	71	353	642	856	(9)
	CDD50	3368	2	3	13	129	393	631	789	766	457	161	22	2	(10)
	CDD65	955	0	0	0	5	38	197	326	305	78	6	0	0	(11)
	CDH74	7464	0	0	10	45	190	1452	2677	2596	456	37	1	0	(12)
	CDH80	2557	0	0	1	4	26	417	992	986	127	4	0	0	(13)
(14) Wind	WSAvg	4.5	3.7	4.0	4.6	4.8	4.9	5.2	5.2	5.0	4.6	4.0	3.8	3.7	(14)
(15) Precipitation	PrecAvg	17.9	1.1	1.3	1.4	1.5	1.5	1.5	1.1	1.2	2.0	2.2	1.4	1.1	(15)
	PrecMax	24.5	2.0	2.4	3.3	3.1	3.1	2.8	3.2	3.3	4.6	5.4	3.2	3.2	(16)
	PrecMin	13.1	0.5	0.2	0.6	0.8	0.4	0.2	0.2	0.2	0.0	0.2	0.0	0.0	(17)
	PrecStd	2.7	0.4	0.6	0.6	0.6	0.7	0.7	0.7	0.7	1.1	1.3	0.8	0.8	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	59.1	61.9	73.8	79.9	83.3	91.8	96.2	95.4	89.8	78.9	67.4	60.0	(19)
		MCWB	45.5	48.0	53.1	59.8	62.3	69.6	71.9	68.4	67.5	60.6	55.0	48.4	(20)
	2%	DB	52.0	52.6	62.6	73.0	78.5	87.6	91.4	91.4	83.5	72.2	61.9	54.0	(21)
		MCWB	42.2	44.4	48.5	57.5	62.5	67.6	69.0	68.9	65.8	60.3	52.6	45.2	(22)
	5%	DB	46.1	47.7	57.3	68.9	75.3	84.6	88.2	88.6	78.9	67.7	57.4	49.2	(23)
		MCWB	39.0	41.6	46.8	55.8	62.2	66.5	68.8	68.4	65.5	59.3	50.5	43.2	(24)
	10%	DB	41.5	43.2	52.7	64.2	72.4	81.9	85.5	85.7	75.6	64.5	53.6	45.8	(25)
		MCWB	37.3	38.9	44.9	54.6	61.2	66.0	68.4	68.0	64.3	57.7	48.5	41.7	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	47.3	49.8	53.7	61.8	67.8	73.8	75.6	75.9	72.5	65.4	58.6	51.8	(27)
		MCDB	57.0	58.8	67.5	74.0	76.5	85.8	90.1	86.9	81.3	71.6	66.2	55.4	(28)
	2%	WB	42.4	45.1	50.1	58.9	65.5	71.1	73.2	72.8	69.4	62.7	54.5	46.7	(29)
		MCDB	49.8	51.0	59.7	68.9	74.1	82.6	86.1	84.8	78.8	68.9	59.9	50.7	(30)
	5%	WB	39.9	42.0	47.6	56.8	63.7	69.2	71.5	71.2	67.4	60.3	51.2	44.3	(31)
		MCDB	44.9	47.0	55.9	66.0	72.2	80.3	84.3	82.7	75.6	65.9	55.4	48.4	(32)
	10%	WB	37.9	39.2	45.3	54.9	62.0	67.6	70.0	69.7	65.6	58.3	49.2	41.8	(33)
		MCDB	41.2	42.6	51.8	63.3	70.6	78.3	81.8	81.7	73.3	63.3	52.9	45.3	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	10.7	11.0	13.1	14.5	14.5	15.8	15.4	16.0	14.4	12.3	11.4	11.1	(35)
		MCDBR	20.1	19.9	23.6	21.2	19.2	19.8	20.4	20.5	20.1	18.6	19.1	18.4	(36)
	5% WB	MCWBR	13.1	13.3	14.2	12.2	11.0	9.6	9.1	9.8	10.7	11.4	14.3	12.7	(37)
		MCWBR	17.5	18.4	20.9	18.7	17.1	18.0	17.5	18.0	18.3	16.4	16.5	16.5	(38)
(40) Clear-Sky Solar Irradiance	taub		0.360	0.404	0.462	0.535	0.513	0.509	0.561	0.545	0.488	0.433	0.380	0.360	(40)
		taud	2.194	2.059	1.951	1.823	1.927	1.980	1.879	1.910	2.020	2.121	2.200	2.198	(41)
	Ebn at Noon		241	246	246	237	246	247	233	232	235	234	231	228	(42)
		Edn at Noon	32	42	53	64	59	56	62	58	49	39	31	29	(43)
(44) All-Sky Solar Radiation	RadAvg		478	688	990	1379	1721	1951	1915	1732	1284	826	574	445	(44)
	RadStd		59	108	112	167	134	140	144	178	149	121	69	49	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (8 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+207

Nomenclature: See separate page