

SEVAN, Armenia

WMO: 377090

Lat: 40.550N

Lon: 44.933E

Elev: 6355

StdP: 11.62

Time Zone: 4.00 (E04)

Period: 82-91

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-0.2	4.4	-7.2	4.7	2.3	-2.8	6.0	6.3	38.9	18.7	35.7	18.5	4.6	290	0.671

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.7	75.3	58.2	72.8	57.8	70.3	57.1	62.2	70.3	60.5	68.4	59.1	66.9	9.3	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
59.2	95.4	67.2	57.5	89.8	65.1	56.1	85.0	63.8	31.4	70.3	30.1	68.5	28.9	66.9	77.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 31.5	22.6	19.5	-3.8	81.6	6.5	3.0	-8.5	83.7	-12.3	85.5	-16.0	87.2	-20.7	89.3		
(5)			-4.5	66.4	6.3	4.7	-9.1	69.8	-12.8	72.5	-16.3	75.2	-20.9	78.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	41.0	19.8	19.6	27.4	41.0	47.9	55.8	61.6	60.4	55.7	43.9	34.1	23.5		
	DBStd	16.38	6.79	7.32	8.67	5.94	5.20	4.76	4.12	4.48	5.50	6.56	7.13	8.70		
	HDD50	4385	937	850	700	272	102	7	0	1	13	204	477	822		
	HDD65	8785	1402	1270	1165	721	531	277	119	152	282	653	926	1287		
	CDD50	1099	0	0	0	2	35	180	359	322	184	17	0	0		
	CDD65	26	0	0	0	0	0	1	13	9	3	0	0	0		
	CDH74	135	0	0	0	0	0	4	52	53	26	0	0	0		
	CDH80	6	0	0	0	0	0	0	3	2	1	0	0	0		
	WSAvg	7.9	10.0	8.4	7.7	8.1	7.4	7.0	7.5	8.0	7.0	7.0	8.4	9.0		
	PrecAvg	19.6	0.7	0.9	1.3	2.3	3.5	2.9	1.9	1.3	1.1	1.9	1.3	0.7		
(15) Precipitation	PrecMax	27.7	2.0	2.3	2.8	4.6	6.8	6.5	4.5	3.7	3.9	3.3	3.2	2.0		
	PrecMin	9.9	0.1	0.2	0.3	1.0	0.4	0.0	0.0	0.2	0.0	0.1	0.0	0.1		
	PrecStd	3.9	0.5	0.5	0.6	0.9	1.5	1.3	1.2	0.8	1.0	0.9	0.8	0.4		
	PrecStd	3.9	0.5	0.5	0.6	0.9	1.5	1.3	1.2	0.8	1.0	0.9	0.8	0.4		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	34.7	37.7	48.1	60.0	67.0	73.6	78.3	78.8	77.3	65.1	54.7	43.9			
	0.4% MCWB	29.2	33.2	39.4	45.3	51.0	56.3	61.9	56.8	53.8	47.9	45.3	37.7			
	2% DB	32.3	35.0	43.4	56.5	63.5	70.2	75.2	74.9	72.7	60.6	49.2	40.4			
	2% MCWB	28.2	31.3	36.0	44.3	49.9	55.7	60.5	57.7	53.3	46.5	40.5	35.4			
	5% DB	30.2	32.8	39.9	53.8	60.3	67.2	72.7	72.4	69.3	57.2	46.1	37.9			
	5% MCWB	27.2	29.7	34.6	43.3	49.0	55.1	59.8	57.9	52.6	45.7	39.5	33.5			
	10% DB	28.4	30.6	37.4	50.8	57.3	64.8	70.1	69.6	66.3	53.8	43.6	35.1			
	10% MCWB	25.9	28.1	33.1	41.8	47.7	54.2	59.1	57.4	52.3	44.7	38.3	31.7			
	0.4% WB	30.6	34.1	40.1	47.6	54.1	59.7	66.6	63.5	59.2	50.4	45.5	38.5			
	0.4% MCDB	32.7	37.1	46.1	55.8	62.1	67.5	74.3	71.9	67.2	60.1	54.3	41.8			
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2% WB	29.1	32.0	36.8	45.8	51.8	58.1	63.3	61.4	57.2	48.4	42.2	36.2			
	2% MCDB	31.2	34.6	41.8	54.1	60.9	66.0	71.6	70.0	65.4	56.7	46.3	40.0			
	5% WB	27.6	29.9	35.1	44.2	50.1	56.6	61.6	59.8	55.5	47.0	40.4	33.6			
	5% MCDB	29.7	32.3	39.2	51.8	58.3	64.9	69.4	68.3	65.7	54.3	44.9	36.9			
	10% WB	26.2	28.3	33.4	42.7	48.6	55.0	60.1	58.5	53.9	45.6	38.9	32.0			
	10% MCDB	28.4	30.8	36.9	49.5	55.6	63.2	67.6	66.4	63.8	52.3	43.1	34.5			
(35) Mean Daily Temperature Range	MDBR	10.1	11.8	12.2	14.4	14.7	15.1	14.7	15.9	19.1	15.8	11.2	9.8			
	5% DB	11.6	10.4	13.9	19.2	19.5	18.8	19.3	21.6	23.7	20.6	14.6	10.6			
	5% WB	9.2	8.0	8.9	9.6	9.3	9.3	9.5	9.2	9.4	9.9	9.1	7.4			
	MCDBR	9.9	9.4	12.7	17.0	17.7	16.9	16.1	17.0	20.5	17.4	13.6	8.8			
	MCWBR	8.3	7.7	8.5	9.2	9.4	9.2	9.1	8.3	8.7	9.0	8.7	6.5			
	MCWBR	8.3	7.7	8.5	9.2	9.4	9.2	9.1	8.3	8.7	9.0	8.7	6.5			
(40) Clear-Sky Solar Irradiance	taub	0.266	0.298	0.347	0.402	0.381	0.370	0.407	0.396	0.345	0.334	0.287	0.264			
	taud	2.366	2.302	2.243	2.118	2.263	2.344	2.242	2.276	2.413	2.383	2.473	2.426			
	Ebn at Noon	287	291	286	276	284	287	274	275	284	273	277	279			
	Edh at Noon	26	33	39	48	43	39	43	41	33	30	24	23			
(44) All-Sky Solar Radiation	RadAvg	682	974	1157	1405	1735	2053	2041	1892	1529	1017	700	538			
	RadStd	77	144	112	173	99	139	128	147	108	85	95	75			

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (15 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page