

GANJA, Azerbaijan

WMO: 377350

Lat: 40.717N

Lon: 46.417E

Elev: 1020

StdP: 14.16

Time Zone: 4.00 (E04)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	23.8	27.5	12.4	10.8	37.3	15.5	12.5	36.5	30.6	44.3	19.5	46.9	1.9	320	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.8	95.6	70.6	93.5	70.2	91.2	69.9	74.7	89.6	73.3	88.1	72.0	86.1	7.2	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
70.2	115.3	82.0	68.7	109.7	80.9	67.3	104.3	80.1	39.1	90.0	37.7	88.2	36.5	86.3	81.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
30.4	20.1	13.7	DB	22.2	100.4	4.2	2.9	19.2	102.5	16.8	104.2	14.5	105.9	11.4	108.0	
			WB	20.4	77.4	3.8	1.7	17.7	78.6	15.5	79.6	13.4	80.5	10.6	81.7	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	59.5	39.7	40.7	49.0	56.5	67.8	76.9	80.9	79.4	70.9	60.1	49.0	42.0
	DBStd	15.91	5.89	7.09	6.05	6.65	5.23	4.89	4.30	4.99	5.46	6.27	6.23	5.79
	HDD50	1051	323	269	91	18	1	0	0	0	0	7	88	254
	HDD65	3639	785	681	497	265	32	1	0	1	14	171	479	713
	CDD50	4523	3	8	59	212	551	806	959	912	627	321	59	6
	CDD65	1635	0	0	0	10	117	356	494	447	191	20	0	0
	CDH74	16124	0	0	1	72	768	3433	5598	4880	1308	63	1	0
	CDH80	7006	0	0	0	6	163	1429	2727	2324	352	5	0	0
(14) Wind	WSAvg	4.4	3.5	3.8	5.7	5.3	4.2	4.8	5.3	5.2	4.3	3.6	3.1	3.4
(15) Precipitation	PrecAvg	10.8	0.4	0.6	0.7	1.3	1.7	2.3	1.0	0.7	0.7	1.1	0.6	0.5
	PrecMax	14.2	1.4	1.7	2.1	3.5	5.7	18.9	3.0	2.9	2.5	3.2	1.7	1.1
	PrecMin	6.4	0.0	0.1	0.0	0.2	0.4	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	2.2	0.3	0.4	0.5	0.7	1.1	3.1	0.8	0.7	0.7	0.8	0.4	0.4
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	60.1	63.4	71.6	80.1	87.9	96.3	99.1	98.0	90.2	79.7	68.5	61.7
		MCWB	45.5	48.0	54.4	61.5	65.2	68.8	71.8	69.6	69.1	64.5	53.5	47.4
	2%	DB	55.4	58.5	67.1	75.9	84.0	92.9	96.2	95.1	87.2	75.2	64.0	56.6
		MCWB	43.3	46.0	51.7	60.9	65.5	69.3	72.0	69.5	68.4	62.6	53.0	46.3
	5%	DB	51.4	54.2	63.6	72.1	81.2	90.3	94.0	93.0	84.4	72.3	60.8	53.1
		MCWB	41.4	44.0	50.1	59.1	64.5	68.5	71.5	69.2	67.7	61.2	51.9	44.7
	10%	DB	48.2	50.5	59.8	68.3	78.3	87.9	91.6	90.6	81.5	69.6	57.7	50.4
		MCWB	39.7	42.1	48.6	57.1	63.8	68.2	71.1	69.4	67.0	60.2	50.3	43.3
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	46.8	50.8	57.5	64.6	70.0	74.1	77.4	76.1	72.3	66.1	58.4	50.0
		MCDB	57.3	59.4	68.6	74.6	81.4	88.7	92.1	89.8	83.3	75.4	64.0	57.1
	2%	WB	44.0	47.5	53.6	62.0	68.1	71.9	75.5	73.9	70.3	64.4	54.9	47.7
		MCDB	53.2	55.3	63.3	73.5	79.5	86.0	90.7	88.4	82.2	72.6	59.3	53.4
	5%	WB	42.3	45.0	51.5	60.1	66.5	70.5	74.0	72.7	69.3	62.9	53.2	46.0
		MCDB	49.1	52.4	61.1	70.9	77.4	85.2	89.2	86.9	81.0	70.4	58.2	51.9
	10%	WB	40.9	43.0	49.8	57.9	64.8	69.5	72.8	71.6	68.0	61.4	51.6	44.1
		MCDB	46.5	48.3	57.8	66.8	75.0	84.4	87.6	85.1	79.7	67.9	57.2	49.5
(35) Mean Daily Temperature Range	5% DB	MDBR	11.9	11.2	14.9	16.4	17.0	18.5	18.8	18.8	16.2	13.5	12.7	11.9
		MCDBR	17.9	18.8	20.7	22.3	21.6	21.4	21.7	22.7	20.1	17.7	18.1	16.4
		MCWBR	9.6	9.6	10.5	11.6	9.0	7.0	7.4	7.3	7.7	8.2	9.6	9.4
	5% WB	MCDBR	14.9	16.2	17.7	20.7	18.6	19.4	19.8	18.8	18.1	15.5	14.5	15.4
		MCWBR	8.7	9.0	10.0	11.6	9.3	7.9	8.3	7.7	7.9	8.0	8.1	9.4
(40) Clear-Sky Solar Irradiance	taub		0.347	0.383	0.430	0.501	0.479	0.472	0.519	0.505	0.459	0.424	0.371	0.347
	taud		2.298	2.180	2.079	1.937	2.066	2.133	2.016	2.050	2.156	2.192	2.288	2.310
	Ebn at Noon		251	257	257	247	256	258	244	243	246	239	239	240
	Edh at Noon		29	38	47	58	52	49	54	51	43	37	29	27
(44) All-Sky Solar Radiation	RadAvg		604	810	1107	1403	1734	2012	1985	1819	1387	935	675	538
	RadStd		60	109	108	190	96	150	148	182	111	102	74	66

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (14 neighbors)	+0.86	N/A	+2.52	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page