

GOYCHAY, Azerbaijan

WMO: 377490

Lat: 40.650N

Lon: 47.750E

Elev: 95

StdP: 100.19

Time Zone: 4.00 (E04)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-3.2	-1.5	-6.5	2.2	-0.4	-4.7	2.6	0.3	11.9	6.5	8.4	9.1	2.0	0	0.386

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.9	37.4	22.3	36.1	22.0	34.9	21.6	24.1	34.4	23.3	33.2	22.6	32.1	2.0	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.0	15.8	28.6	20.2	15.1	28.1	19.5	14.4	27.5	73.1	34.3	69.7	33.2	67.1	32.4	32.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	7.9	4.9	4.0	DB	-5.8	39.7	2.8	1.0	-7.8	40.4	-9.4	41.0	-11.0	41.5	-13.0	42.3
(5)				WB	-6.4	25.4	2.9	1.2	-8.5	26.3	-10.2	27.0	-11.8	27.7	-13.9	28.5

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	16.3	4.7	5.6	9.6	14.6	21.6	26.6	28.6	23.2	16.7	10.0	5.8	(6)	
(7)		DBStd	9.25	2.77	3.38	3.00	3.56	2.67	2.82	2.32	2.70	2.97	3.70	3.38	2.93	(7)
(8)		HDD10.0	515	164	127	42	5	0	0	0	0	3	41	132		(8)
(9)		HDD18.3	1891	422	357	272	119	5	0	0	3	73	251	388		(9)
(10)		CDD10.0	2817	1	3	29	143	361	497	576	559	396	211	39	2	(10)
(11)		CDD18.3	1152	0	0	0	8	107	247	318	301	148	23	0	0	(11)
(12)		CDH23.3	12366	0	0	1	63	856	2719	3898	3601	1152	75	0	0	(12)
(13)		CDH26.7	6071	0	0	0	6	266	1388	2074	1928	402	6	0	0	(13)
(14)	Wind	WSAvg	1.9	1.9	2.0	2.3	2.1	2.0	2.0	1.6	1.7	1.8	1.7	1.7	1.9	(14)
(15)	Precipitation	PrecAvg	564	45	52	59	50	52	43	29	24	50	62	54	42	(15)
(16)		PrecMax	748	85	89	100	109	95	98	90	53	125	139	110	95	(16)
(17)		PrecMin	377	23	18	25	22	10	5	6	0	0	10	1	5	(17)
(18)		PrecStd	73	15	19	21	17	20	21	19	15	29	29	26	21	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	15.8	17.8	22.1	27.6	33.2	38.2	39.2	38.6	34.1	27.7	20.4	14.6	(19)
(20)		0.4%	MCWB	8.2	10.3	13.7	17.8	19.4	21.1	24.3	23.1	22.2	19.5	14.4	9.6	(20)
(21)		2%	DB	12.0	13.8	19.2	25.0	31.2	36.2	37.4	37.3	32.3	25.6	17.9	12.9	(21)
(22)		2%	MCWB	7.2	8.5	12.4	16.5	18.9	21.1	23.1	22.0	20.9	18.9	12.9	8.7	(22)
(23)		5%	DB	10.1	11.3	17.0	23.3	29.5	34.7	36.2	36.0	30.7	23.8	16.1	11.4	(23)
(24)		5%	MCWB	6.4	8.0	11.4	15.8	19.0	20.9	22.7	21.6	20.2	17.8	12.1	8.1	(24)
(25)		10%	DB	8.3	9.8	14.9	21.2	27.9	33.4	34.8	34.7	29.0	22.2	14.6	9.9	(25)
(26)		10%	MCWB	5.6	7.0	10.0	14.9	18.5	20.6	22.2	21.5	19.9	17.0	11.3	7.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.3	11.7	15.1	18.9	21.4	23.6	26.0	24.5	23.5	21.0	15.7	10.6	(27)
(28)		0.4%	MCDWB	14.5	16.0	19.7	25.3	29.4	33.8	36.0	35.0	32.3	24.9	19.4	13.2	(28)
(29)		2%	WB	7.6	9.5	13.2	17.3	20.4	22.6	24.7	23.6	22.1	19.6	13.7	9.5	(29)
(30)		2%	MCDWB	10.9	12.7	18.5	23.8	28.2	32.8	34.8	34.3	29.9	24.4	16.7	11.8	(30)
(31)		5%	WB	6.8	8.1	11.6	16.4	19.7	21.8	23.8	22.9	21.3	18.6	12.7	8.5	(31)
(32)		5%	MCDWB	9.3	11.0	16.4	21.8	27.4	31.7	33.8	33.2	28.6	22.8	15.2	10.6	(32)
(33)		10%	WB	6.0	7.2	10.4	15.4	19.1	21.2	23.0	22.3	20.5	17.6	11.7	7.6	(33)
(34)		10%	MCDWB	8.0	9.4	14.2	20.1	26.2	31.1	32.3	32.0	27.3	21.4	14.2	9.5	(34)
(35)	Mean Daily Temperature Range		MDBR	6.5	6.1	8.3	9.6	10.7	11.4	10.9	11.4	9.6	7.5	6.9	6.2	(35)
(36)		5% DB	MCDDBR	9.7	10.0	12.6	12.6	13.2	13.4	13.2	13.6	12.1	9.8	9.1	8.6	(36)
(37)			MCWBR	6.0	6.1	7.2	6.1	5.1	4.7	5.0	5.2	4.7	4.5	5.4	5.5	(37)
(38)			MCDDBR	8.9	8.9	11.4	11.1	11.6	12.2	12.1	12.4	10.8	8.9	8.1	7.4	(38)
(39)		5% WB	MCWBR	5.7	5.5	6.8	5.7	4.9	4.9	5.0	5.0	4.9	4.5	5.2	5.0	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.370	0.408	0.459	0.535	0.510	0.505	0.552	0.533	0.492	0.445	0.395	0.371	(40)	
(41)		taud	2.218	2.104	1.999	1.858	1.977	2.028	1.923	1.967	2.049	2.130	2.208	2.226	(41)	
(42)		Ebn at Noon	757	780	782	749	781	785	742	743	743	731	720	719	(42)	
(43)		Edh at Noon	100	129	160	197	179	170	187	174	151	124	100	92	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.77	2.40	3.46	4.56	5.84	6.72	6.49	5.84	4.43	2.88	2.05	1.60	(44)	
(45)		RadStd	0.21	0.35	0.40	0.61	0.32	0.38	0.42	0.50	0.37	0.36	0.20	0.20	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (7 neighbors)	N/A	N/A	N/A	+1.12	N/A	N/A	N/A	N/A	N/A	+115

Nomenclature: See separate page