

QOBUSTAN, Azerbaijan

WMO: 377560

Lat: 40.533N

Lon: 48.933E

Elev: 2477

StdP: 13.43

Time Zone: 4.00 (E04)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	18.1	21.1	13.6	12.0	20.5	17.0	14.2	24.3	30.8	41.7	27.0	37.6	6.6	270	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.8	93.1	63.4	90.8	62.9	88.4	62.7	69.4	84.9	67.7	82.8	66.2	80.6	6.0	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
63.8	97.2	77.6	62.2	91.7	75.6	60.8	87.2	73.8	35.0	84.6	33.6	83.2	32.2	80.2	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 22.1	18.1	15.3	DB	11.6	97.6	6.0	3.3	7.3	100.0	3.8	101.9	0.4	103.7	-4.0	106.1	(4)
(5)			WB	10.8	72.2	5.8	2.0	6.6	73.6	3.1	74.8	-0.1	75.9	-4.4	77.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	53.7	33.7	34.0	41.4	49.5	62.0	71.4	76.2	75.0	65.3	54.1	43.3	37.1	(6)	
	DBStd	16.53	6.06	7.32	6.67	6.61	5.01	6.10	5.12	5.52	5.80	7.00	6.96	6.10	(7)	
	HDD50	1972	506	448	274	88	1	0	0	0	41	215	399		(8)	
	HDD65	5097	971	867	730	464	120	13	2	6	67	341	652	864	(9)	
	CDD50	3328	0	1	9	74	372	642	813	776	459	168	13	1	(10)	
	CDD65	978	0	0	0	0	27	205	350	317	76	3	0	0	(11)	
	CDH74	9518	0	0	0	5	244	2024	3545	3155	531	14	0	0	(12)	
	CDH80	3827	0	0	0	0	39	764	1530	1377	117	0	0	0	(13)	
(14) Wind	WSAvg	6.2	7.2	7.3	7.6	5.9	5.3	5.2	5.5	5.4	5.4	5.9	6.0	7.1	(14)	
(15) Precipitation	PrecAvg	22.2	1.8	2.0	2.3	2.0	2.0	1.7	1.1	0.9	2.0	2.4	2.1	1.7	(15)	
	PrecMax	29.4	3.3	3.5	3.9	4.3	3.7	3.9	3.5	2.1	4.9	5.5	4.3	3.7	(16)	
	PrecMin	14.8	0.9	0.7	1.0	0.9	0.4	0.2	0.2	0.0	0.0	0.4	0.0	0.2	(17)	
	PrecStd	2.9	0.6	0.7	0.8	0.7	0.8	0.8	0.7	0.6	1.1	1.1	1.0	0.8	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.8	58.2	65.7	73.6	84.2	94.3	97.5	95.2	88.4	76.0	64.6	58.1	(19)	
		MCWB	43.6	45.7	51.4	57.7	59.3	63.9	65.5	64.2	60.5	60.8	50.6	44.4	(20)	
	2%	DB	49.8	52.1	60.4	69.1	80.0	90.7	93.3	92.8	83.6	71.4	59.6	52.5	(21)	
		MCWB	40.6	44.2	49.2	55.1	60.0	61.8	63.5	63.1	62.1	59.8	49.9	43.2	(22)	
	5%	DB	45.2	46.8	56.2	64.9	76.1	87.5	91.0	90.5	80.3	67.7	55.5	48.6	(23)	
		MCWB	38.2	40.9	47.2	54.6	59.9	62.0	63.8	62.4	61.2	58.3	48.6	42.2	(24)	
	10%	DB	41.2	42.3	52.4	61.2	73.0	84.8	88.6	88.1	76.9	64.1	52.5	45.0	(25)	
		MCWB	36.7	38.8	45.0	52.9	59.4	61.6	63.5	62.3	61.2	57.0	47.7	40.5	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	44.1	48.4	53.5	60.1	65.6	68.9	71.7	70.2	68.1	64.5	54.5	47.1	(27)	
		MCDB	52.5	54.3	62.8	67.1	77.0	82.9	88.1	85.8	78.4	73.2	59.7	52.5	(28)	
	2%	WB	41.2	44.6	50.2	57.4	63.6	66.3	70.2	68.4	65.8	61.3	51.6	44.6	(29)	
		MCDB	47.9	51.8	58.6	65.7	74.8	81.2	86.3	84.3	76.4	68.0	56.6	49.8	(30)	
	5%	WB	39.0	41.3	47.9	55.3	62.0	64.8	68.7	66.8	64.1	59.4	49.8	42.6	(31)	
		MCDB	43.9	45.7	55.2	62.8	72.2	80.7	84.5	82.9	74.5	65.5	54.0	47.5	(32)	
	10%	WB	37.1	39.1	45.7	53.4	60.6	63.6	66.8	65.2	62.7	57.5	48.1	41.0	(33)	
		MCDB	40.4	41.9	51.7	60.7	70.0	79.4	81.6	81.6	73.0	63.1	51.9	44.4	(34)	
(35) Mean Daily Temperature Range	MDBR		10.8	10.2	13.7	16.0	18.6	20.3	19.8	20.6	16.8	13.0	12.1	11.0	(35)	
	5% DB	MCDBR	18.2	19.3	21.4	22.6	23.7	24.1	23.7	25.0	23.1	18.6	18.2	17.5	(36)	
		MCWBR	11.0	11.8	12.5	12.7	10.2	8.6	8.5	10.3	10.5	9.6	10.7	10.6	(37)	
	5% WB	MCDBR	15.4	16.6	19.8	19.3	20.4	21.1	19.5	21.2	19.3	16.4	15.3	15.0	(38)	
		MCWBR	10.2	11.0	12.4	12.2	11.2	9.6	9.1	10.7	10.1	9.5	9.9	10.0	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.345	0.381	0.426	0.491	0.471	0.466	0.506	0.488	0.457	0.414	0.369	0.348	(40)	
	taud		2.249	2.146	2.051	1.913	2.026	2.069	1.967	2.011	2.069	2.156	2.227	2.243	(41)	
	Ebn at Noon		251	258	259	249	259	259	247	248	246	243	239	238	(42)	
	Edh at Noon		30	39	48	59	54	52	57	53	47	38	31	29	(43)	
(44) All-Sky Solar Radiation	RadAvg		518	700	1072	1440	1873	2126	2057	1837	1364	873	610	469	(44)	
	RadStd		68	110	122	187	116	114	119	142	120	115	66	54	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (5 neighbors)		N/A	N/A	N/A	+2.02	N/A	N/A	N/A	N/A	N/A	+207

Nomenclature: See separate page