

QOBUSTAN, Azerbaijan

WMO: 377560

Lat: 40.533N

Lon: 48.933E

Elev: 755

StdP: 92.58

Time Zone: 4.00 (E04)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-7.7	-6.0	-10.2	1.7	-6.4	-8.4	2.0	-4.3	13.8	5.4	12.1	3.1	3.0	270	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.0	33.9	17.4	32.7	17.1	31.4	17.0	20.8	29.4	19.8	28.2	19.0	27.0	2.7	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.7	13.9	25.3	16.8	13.1	24.2	16.0	12.5	23.2	63.5	29.2	60.2	28.4	57.1	26.8	23.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.9	8.1	6.8	-11.3	36.5	3.4	1.8	-13.7	37.8	-15.7	38.8	-17.6	39.9	-20.0	41.2		
(5)			-11.8	22.3	3.2	1.1	-14.1	23.1	-16.0	23.8	-17.9	24.4	-20.2	25.2	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	12.1	0.9	1.1	5.2	9.7	16.7	21.9	24.6	23.9	18.5	12.3	6.3	2.9	(6)
(7)		DBStd	9.18	3.37	4.07	3.71	3.67	2.78	3.39	2.85	3.07	3.22	3.89	3.87	3.39	(7)
(8)		HDD10.0	1096	281	249	152	49	1	0	0	0	23	119	222		(8)
(9)		HDD18.3	2832	539	482	406	258	67	7	1	3	37	189	362	480	(9)
(10)		CDD10.0	1849	0	1	5	41	207	357	452	431	255	93	7	1	(10)
(11)		CDD18.3	543	0	0	0	0	15	114	194	176	42	2	0	0	(11)
(12)		CDH23.3	5288	0	0	0	3	136	1124	1969	1753	295	8	0	0	(12)
(13)		CDH26.7	2126	0	0	0	0	22	424	850	765	65	0	0	0	(13)
(14)	Wind	WSAvg	2.8	3.2	3.2	3.4	2.7	2.4	2.3	2.5	2.4	2.4	2.6	2.7	3.2	(14)
(15)	Precipitation	PrecAvg	564	45	52	59	50	52	43	29	24	50	62	54	42	(15)
(16)		PrecMax	748	85	89	100	109	95	98	90	53	125	139	110	95	(16)
(17)		PrecMin	377	23	18	25	22	10	5	6	0	0	10	1	5	(17)
(18)		PrecStd	73	15	19	21	17	20	21	19	15	29	29	26	21	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.7	14.5	18.7	23.1	29.0	34.6	36.4	35.1	31.3	24.4	18.1	14.5	(19)
(20)			MCWB	6.5	7.6	10.8	14.3	15.2	17.7	18.6	17.9	15.8	16.0	10.3	6.9	(20)
(21)		2%	DB	9.9	11.2	15.8	20.6	26.7	32.6	34.0	33.8	28.7	21.9	15.4	11.4	(21)
(22)			MCWB	4.8	6.8	9.5	12.9	15.5	16.5	17.5	17.3	16.7	15.4	9.9	6.2	(22)
(23)		5%	DB	7.3	8.2	13.5	18.3	24.5	30.8	32.8	32.5	26.8	19.8	13.1	9.2	(23)
(24)			MCWB	3.5	4.9	8.4	12.5	15.5	16.7	17.7	16.9	16.2	14.6	9.2	5.7	(24)
(25)		10%	DB	5.1	5.7	11.4	16.2	22.8	29.3	31.4	31.1	24.9	17.8	11.4	7.2	(25)
(26)			MCWB	2.6	3.8	7.2	11.6	15.2	16.5	17.5	16.8	16.2	13.9	8.7	4.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.7	9.1	11.9	15.6	18.7	20.5	22.1	21.2	20.1	18.1	12.5	8.4	(27)
(28)			MCDWB	11.4	12.4	17.1	19.5	25.0	28.3	31.1	29.9	25.8	22.9	15.4	11.4	(28)
(29)		2%	WB	5.1	7.0	10.1	14.1	17.6	19.1	21.2	20.2	18.8	16.3	10.9	7.0	(29)
(30)			MCDWB	8.9	11.0	14.8	18.7	23.8	27.3	30.2	29.1	24.7	20.0	13.7	9.9	(30)
(31)		5%	WB	3.9	5.2	8.8	12.9	16.7	18.2	20.4	19.3	17.9	15.2	9.9	5.9	(31)
(32)			MCDWB	6.6	7.6	12.9	17.1	22.3	27.0	29.2	28.3	23.6	18.6	12.2	8.6	(32)
(33)		10%	WB	2.9	3.9	7.6	11.9	15.9	17.5	19.4	18.5	17.0	14.2	8.9	5.0	(33)
(34)			MCDWB	4.7	5.5	11.0	16.0	21.1	26.3	27.6	27.5	22.8	17.3	11.0	6.9	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.0	5.7	7.6	8.9	10.4	11.3	11.0	11.4	9.3	7.2	6.7	6.1	(35)
(36)			MCDBR	10.1	10.7	11.9	12.5	13.2	13.4	13.2	13.9	12.8	10.4	10.1	9.7	(36)
(37)			MCWBR	6.1	6.6	6.9	7.0	5.7	4.8	4.7	5.7	5.8	5.3	5.9	5.9	(37)
(38)		5% WB	MCDBR	8.6	9.2	11.0	10.7	11.3	11.7	10.8	11.8	10.7	9.1	8.5	8.3	(38)
(39)			MCWBR	5.7	6.1	6.9	6.8	6.2	5.3	5.1	5.9	5.6	5.3	5.5	5.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.345	0.381	0.426	0.491	0.471	0.466	0.506	0.488	0.457	0.414	0.369	0.348	(40)	
(41)		taud	2.249	2.146	2.051	1.913	2.026	2.069	1.967	2.011	2.069	2.156	2.227	2.243	(41)	
(42)		Ebn at Noon	790	812	815	786	815	818	779	781	776	765	752	750	(42)	
(43)		Edh at Noon	96	123	151	186	170	163	179	167	147	121	98	90	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.63	2.21	3.38	4.54	5.91	6.70	6.49	5.79	4.30	2.75	1.92	1.48	(44)	
(45)		RadStd	0.21	0.35	0.38	0.59	0.37	0.36	0.38	0.45	0.38	0.36	0.21	0.17	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (5 neighbors)		N/A	N/A	N/A	+1.12	N/A	N/A	N/A	N/A	N/A	+115

Nomenclature: See separate page