

YEREVAN ARABKIR, Armenia

WMO: 377890

Lat: 40.212N

Lon: 44.530E

Elev: 1013

StdP: 89.73

Time Zone: 4.00 (E04)

Period: 86-03

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-13.1	-10.7	-15.9	1.1	-11.2	-13.8	1.3	-8.8	9.0	2.7	6.7	3.6	0.6	50	0.492

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.6	36.1	21.6	34.8	21.0	33.2	20.4	22.8	34.1	21.8	33.0	21.0	32.0	2.6	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.0	15.6	30.9	17.9	14.6	29.2	17.0	13.7	28.4	73.0	34.1	68.9	33.4	65.7	31.9	27.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.0	8.4	6.9	-15.0	39.1	5.1	1.4	-18.7	40.1	-21.7	40.9	-24.6	41.7	-28.3	42.6		
(5)			-15.2	25.0	4.6	1.4	-18.6	26.0	-21.3	26.8	-23.9	27.6	-27.2	28.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	12.9	-1.9	1.0	6.6	13.2	17.5	22.6	26.8	26.3	21.0	13.8	6.6	0.9	(6)
(7)		DBStd	10.38	4.09	4.04	3.81	3.34	3.41	3.17	2.49	2.47	2.96	3.35	3.77	4.94	(7)
(8)		HDD10.0	1149	368	253	115	9	0	0	0	0	0	7	113	284	(8)
(9)		HDD18.3	2740	626	487	363	157	57	4	0	0	9	143	352	542	(9)
(10)		CDD10.0	2222	0	0	10	106	233	379	520	507	331	126	11	1	(10)
(11)		CDD18.3	771	0	0	0	3	32	133	262	248	90	3	0	0	(11)
(12)		CDH23.3	8968	0	0	0	46	343	1460	3101	2921	1027	70	0	0	(12)
(13)		CDH26.7	4150	0	0	0	7	77	609	1587	1472	388	9	0	0	(13)
(14)	Wind	WSAvg	2.3	1.2	1.6	2.2	2.6	3.0	3.7	3.5	2.4	1.9	1.4	1.2	(14)	
(15)	Precipitation	PrecAvg	576	43	46	58	77	78	52	38	23	46	43	36	(15)	
(16)		PrecMax	709	83	70	105	143	116	81	84	50	94	119	91	61	(16)
(17)		PrecMin	451	14	25	17	38	48	11	3	7	3	16	11	15	(17)
(18)		PrecStd	75	17	14	22	30	18	18	21	11	20	25	23	13	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.2	14.1	20.2	27.2	30.8	35.7	38.2	38.7	34.1	27.9	19.9	12.9	(19)
(20)			MCWB	6.1	7.0	10.8	15.6	17.6	20.6	22.4	22.3	19.4	16.8	11.7	7.1	(20)
(21)		2%	DB	8.7	12.0	17.9	24.5	28.9	33.8	36.3	36.2	32.2	25.2	17.2	10.3	(21)
(22)			MCWB	4.3	5.8	9.6	14.0	16.8	20.0	21.7	21.6	19.2	15.3	10.5	6.4	(22)
(23)		5%	DB	6.2	10.1	15.9	22.2	27.0	32.0	34.9	34.8	30.9	23.1	15.1	8.4	(23)
(24)			MCWB	2.8	5.1	8.5	13.0	16.0	19.1	21.3	21.0	18.7	14.4	9.4	5.2	(24)
(25)		10%	DB	4.2	7.9	14.0	20.2	25.1	30.2	33.6	33.1	29.0	21.1	13.2	6.8	(25)
(26)			MCWB	1.6	4.0	7.9	11.9	15.1	18.5	20.7	20.6	17.7	13.4	8.5	4.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.6	7.9	11.7	16.5	18.7	22.1	24.2	24.1	21.2	17.5	12.4	8.8	(27)
(28)			MCDWB	10.5	12.1	18.1	25.5	28.7	33.7	35.1	35.5	31.1	24.9	17.8	11.7	(28)
(29)		2%	WB	4.5	6.6	10.4	14.8	17.5	20.7	23.1	22.7	19.9	16.0	11.1	7.0	(29)
(30)			MCDWB	7.9	11.2	16.5	22.5	27.1	31.7	34.5	34.0	30.8	24.3	16.1	9.5	(30)
(31)		5%	WB	3.1	5.3	9.1	13.6	16.6	19.8	22.0	21.8	19.0	14.8	9.9	5.4	(31)
(32)			MCDWB	6.1	9.5	14.6	20.7	25.3	30.8	33.2	33.1	29.5	22.0	14.5	7.9	(32)
(33)		10%	WB	1.7	4.0	8.1	12.6	15.7	18.9	21.2	21.0	18.0	13.8	8.9	4.3	(33)
(34)			MCDWB	3.9	7.8	13.3	19.2	23.9	29.2	32.1	32.1	28.0	20.1	12.6	6.3	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	8.5	10.3	11.8	12.1	12.7	14.1	13.6	14.0	14.9	13.0	11.7	8.2	(35)
(36)			MCDBR	11.0	13.4	14.7	14.9	14.9	15.3	14.7	15.4	16.8	15.8	13.6	10.0	(36)
(37)			MCWBR	7.4	8.6	8.3	7.3	6.7	6.3	6.1	6.3	7.4	8.0	8.0	6.4	(37)
(38)		5% WB	MCDWB	10.3	12.2	13.2	12.9	13.7	14.9	14.1	14.6	16.3	14.8	12.7	8.8	(38)
(39)			MCWBR	7.0	7.9	8.1	7.0	6.6	6.6	6.5	6.7	7.6	8.0	7.6	6.0	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.301	0.335	0.391	0.457	0.430	0.411	0.455	0.439	0.378	0.375	0.320	0.297	(40)	
(41)		taud	2.338	2.239	2.130	1.992	2.146	2.256	2.141	2.182	2.337	2.279	2.408	2.396	(41)	
(42)		Ebn at Noon	857	870	853	818	851	866	823	826	860	815	830	834	(42)	
(43)		Edh at Noon	87	112	140	172	151	135	151	141	113	107	82	77	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.29	3.29	3.87	4.59	5.67	6.85	6.86	6.30	5.14	3.38	2.28	1.73	(44)	
(45)		RadStd	0.26	0.45	0.38	0.54	0.32	0.42	0.32	0.34	0.32	0.25	0.31	0.24	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (14 neighbors)	N/A	N/A	N/A	+0.82	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page