

NAKHCHIVAN, Azerbaijan

WMO: 378635

Lat: 39.189N

Lon: 45.458E

Elev: 873

StdP: 91.27

Time Zone: 4.00 (E04)

Period: 06-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-17.1	-14.0	-19.9	0.7	-17.3	-16.2	1.0	-12.8	7.5	3.6	6.6	3.7	1.6	20	0.521

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.3	39.0	18.3	37.2	18.0	35.9	17.9	19.8	33.8	19.2	32.9	18.7	32.1	3.3	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.8	12.5	22.4	14.9	11.8	23.3	14.0	11.1	23.6	60.7	34.3	58.6	33.0	57.0	32.2	22.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	8.5	7.4	6.5	DB	-16.5	41.2	5.7	1.5	-20.6	42.2	-23.9	43.1	-27.1	43.9	-31.2	44.9
(5)				WB	-17.0	21.0	5.4	0.6	-20.9	21.4	-24.0	21.7	-27.1	22.1	-31.0	22.5

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	14.0	-2.9	1.5	8.3	13.5	18.8	24.6	28.3	23.1	15.5	7.1	0.8	(6)	
(7)		DBStd	11.28	6.48	5.58	4.16	3.50	2.68	2.91	2.95	2.88	3.66	3.60	3.80	4.92	(7)
(8)		HDD10.0	1117	398	239	81	8	0	0	0	0	4	102	286	(8)	
(9)		HDD18.3	2604	657	472	311	149	27	1	0	7	99	338	544	(9)	
(10)		CDD10.0	2569	0	1	28	114	273	439	567	393	175	13	0	(10)	
(11)		CDD18.3	1015	0	0	0	5	41	189	309	308	150	12	0	0	(11)
(12)		CDH23.3	12923	0	0	10	93	557	2334	4114	4040	1616	158	0	0	(12)
(13)		CDH26.7	6757	0	0	1	26	158	1172	2349	2285	737	29	0	0	(13)
(14)	Wind	WSAvg	3.0	2.0	2.5	3.1	3.3	3.2	3.4	4.1	4.1	3.5	2.8	2.4	2.0	(14)
(15)	Precipitation	PrecAvg	249	33	16	30	41	37	24	8	6	22	19	20	(15)	
(16)		PrecMax	363	512	46	73	132	87	84	59	38	52	70	50	58	(16)
(17)		PrecMin	136	0	1	6	11	7	1	0	0	0	0	0	0	(17)
(18)		PrecStd	64	85	10	16	23	21	21	11	9	12	19	14	16	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.9	16.1	24.9	30.0	32.8	38.1	41.1	40.9	38.0	29.2	20.2	14.2	(19)
(20)		0.4%	MCWB	6.4	8.2	11.5	13.6	15.7	17.8	19.0	18.4	17.2	14.3	11.4	7.5	(20)
(21)		2%	DB	10.1	13.9	20.8	26.0	30.1	36.1	39.2	39.0	35.1	27.1	17.8	11.1	(21)
(22)		2%	MCWB	5.1	7.0	10.4	12.9	15.2	17.5	18.6	18.1	16.9	14.0	10.1	6.1	(22)
(23)		5%	DB	7.9	11.9	18.2	23.1	28.2	34.2	37.8	37.2	33.0	25.0	15.8	9.0	(23)
(24)		5%	MCWB	4.3	6.3	9.1	12.2	14.8	17.2	18.6	17.9	16.6	13.7	9.2	5.3	(24)
(25)		10%	DB	5.8	9.9	16.1	21.1	26.8	32.9	35.9	35.9	31.0	22.9	13.8	7.1	(25)
(26)		10%	MCWB	3.2	5.3	8.3	11.4	14.6	16.9	18.4	17.7	16.3	13.3	8.5	4.8	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.4	9.1	12.4	14.7	18.0	19.7	20.9	20.2	19.2	16.3	12.4	8.3	(27)
(28)		0.4%	MCDWB	11.9	13.7	21.2	24.3	27.0	31.9	35.8	34.8	31.7	23.7	18.1	12.2	(28)
(29)		2%	WB	5.5	7.8	11.0	13.7	16.7	18.6	20.1	19.6	18.2	15.2	11.2	6.9	(29)
(30)		2%	MCDWB	8.5	12.6	19.8	23.0	25.9	31.6	34.5	33.6	30.7	23.3	15.9	10.1	(30)
(31)		5%	WB	4.4	6.6	9.7	13.0	16.0	18.1	19.5	19.0	17.5	14.4	10.0	5.9	(31)
(32)		5%	MCDWB	7.3	11.1	16.9	21.1	25.0	30.9	33.6	32.6	29.6	22.8	14.1	8.0	(32)
(33)		10%	WB	3.0	5.4	8.7	12.2	15.3	17.6	19.0	18.5	16.9	13.7	8.9	4.8	(33)
(34)		10%	MCDWB	5.6	9.5	15.4	19.5	24.0	29.9	32.8	32.2	28.5	21.8	13.0	7.0	(34)
(35)	Mean Daily Temperature Range	MDBR	8.6	10.4	12.0	12.6	14.2	15.2	14.3	14.2	14.2	12.9	11.2	8.1	(35)	
(36)		5% DB	MCDBR	11.2	13.4	14.9	15.6	16.8	16.8	15.8	15.7	16.1	15.8	13.7	11.3	(36)
(37)		5% DB	MCWBR	7.1	7.8	7.0	6.3	5.7	4.6	4.1	4.3	4.9	6.5	7.5	7.3	(37)
(38)		5% WB	MCDWR	10.1	12.3	13.1	13.6	15.2	15.7	14.5	14.5	14.7	14.0	10.6	9.4	(38)
(39)		5% WB	MCWBR	6.6	7.2	6.4	5.8	5.6	4.5	3.9	3.9	4.5	6.0	6.0	6.3	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.313	0.346	0.403	0.474	0.456	0.439	0.477	0.452	0.403	0.391	0.334	0.311	(40)	
(41)		taud	2.361	2.261	2.108	1.948	2.064	2.154	2.061	2.128	2.246	2.218	2.355	2.383	(41)	
(42)		Ebn at Noon	852	865	845	806	830	843	806	816	837	800	816	825	(42)	
(43)		Edh at Noon	88	111	145	181	164	150	164	149	125	115	88	80	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.38	3.38	4.03	4.95	6.23	7.61	7.54	6.89	5.60	3.69	2.49	1.87	(44)	
(45)		RadStd	0.22	0.38	0.32	0.51	0.31	0.41	0.24	0.20	0.29	0.25	0.29	0.24	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (11 neighbors)	N/A	N/A	N/A	+1.10	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page