

BAKU HEYDAR ALIYEV, Azerbaijan

WMO: 378640

Lat: 40.468N

Lon: 50.047E

Elev: 10

StdP: 14.69

Time Zone: 4.00 (E04)

Period: 00-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 28.2	(c) 30.4	(d) 22.9	(e) 17.3	(f) 32.6	(g) 26.0	(h) 20.0	(i) 33.9	(j) 34.3	(k) 39.2	(l) 31.4	(m) 39.6	(n) 13.3	(o) 320	(p) 0.577

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 16.6	(c) 95.8	(d) 70.2	(e) 93.1	(f) 70.8	(g) 89.9	(h) 71.2	(i) 80.6	(j) 83.1	(k) 78.6	(l) 82.3	(m) 76.8	(n) 82.1	(o) 10.0	(p) 160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.3	157.5	82.1	77.4	142.5	79.9	75.3	132.8	78.9	44.3	82.0	42.4	81.8	40.3	80.9	90.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
31.3	27.6	24.5	22.8	100.8	5.2	2.7	19.1	102.7	16.0	104.3	13.1	105.8	9.3	107.8
			22.3	81.6	5.0	3.3	18.7	83.9	15.8	85.8	13.0	87.7	9.3	90.1
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	59.7	40.8	41.1	46.1	53.8	65.7	75.1	80.3	80.5	72.7	62.4	51.9	44.6
	DBStd	15.33	4.98	5.13	4.76	5.65	5.56	4.74	3.73	3.83	4.74	5.68	5.76	4.99
	HDD50	922	287	251	139	23	0	0	0	0	0	1	44	177
	HDD65	3554	750	670	586	339	59	1	0	0	5	117	394	633
	CDD50	4459	1	1	18	136	487	753	939	947	682	385	101	9
	CDD65	1616	0	0	0	2	81	304	474	482	237	36	0	0
	CDH74	14929	0	0	1	17	506	2518	4989	5287	1524	87	0	0
	CDH80	5780	0	0	0	1	114	918	2083	2279	379	6	0	0
(14) Wind	WSAvg	11.5	11.4	12.1	13.5	12.3	10.6	12.2	12.4	10.6	10.6	10.5	10.8	11.2
(15) Precipitation	PrecAvg	8.6	0.9	0.9	0.9	0.9	0.5	0.4	0.1	0.3	0.6	1.1	1.3	1.0
	PrecMax	13.2	2.7	2.5	3.2	3.3	1.7	2.1	0.5	1.7	1.7	3.1	4.5	3.1
	PrecMin	4.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0
	PrecStd	2.3	0.7	0.6	0.7	0.7	0.5	0.4	0.1	0.4	0.5	0.9	0.9	0.7
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	57.3	57.6	67.6	76.7	87.8	96.9	98.9	100.1	91.6	79.7	68.4	59.8
		MCWB	47.3	48.3	54.3	60.5	63.8	68.6	70.2	70.4	70.5	68.2	62.3	54.7
	2%	DB	51.6	51.7	59.4	69.9	82.7	91.7	95.3	96.6	87.5	76.6	64.6	55.8
		MCWB	46.3	46.8	52.1	58.5	64.9	68.4	69.8	70.6	71.1	67.8	59.9	52.1
	5%	DB	49.3	49.1	55.5	66.3	79.2	88.2	92.7	93.3	84.2	73.6	62.4	53.8
		MCWB	45.9	45.9	50.1	56.6	64.1	68.7	70.8	71.8	70.6	66.7	58.9	50.6
	10%	DB	47.8	47.8	53.2	62.8	76.0	85.3	89.6	90.0	81.1	71.5	60.3	51.8
		MCWB	45.3	45.5	48.9	55.9	64.1	68.3	71.3	72.8	70.4	65.8	57.3	49.0
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	50.0	50.6	56.3	63.4	72.6	79.0	83.0	83.8	80.6	73.5	64.5	56.9
		MCDB	52.6	53.9	63.4	69.6	75.3	81.7	85.1	85.8	82.6	74.9	66.3	58.2
	2%	WB	47.7	48.0	53.1	60.5	69.4	75.4	80.3	80.8	76.9	70.9	61.7	53.5
		MCDB	49.7	49.6	58.1	66.5	74.7	80.1	82.9	83.5	79.5	73.3	63.7	55.3
	5%	WB	46.4	46.6	51.1	58.5	67.5	73.3	78.2	79.0	74.6	68.8	59.4	51.4
		MCDB	48.4	48.3	55.0	64.6	74.3	79.4	82.3	82.6	78.8	71.7	61.2	53.4
	10%	WB	45.1	45.4	49.4	56.5	65.7	71.6	76.2	77.3	72.9	66.9	57.6	49.6
		MCDB	46.8	46.9	52.2	62.0	72.6	79.1	82.3	82.7	77.9	70.1	59.5	51.3
(35) Mean Daily Temperature Range	5% DB	MDBR	9.4	9.3	11.4	13.6	16.2	16.3	15.5	16.6	14.2	11.9	10.4	9.3
		MCDBR	13.6	12.4	17.1	19.2	21.5	22.2	22.7	24.4	19.0	15.5	13.6	12.4
		MCWBR	9.8	8.9	10.6	10.2	8.8	9.2	10.1	11.4	9.2	10.0	9.9	9.4
	5% WB	MCDBR	11.9	11.2	15.6	17.1	17.6	17.8	16.6	19.0	15.5	13.7	12.7	11.1
		MCWBR	9.4	8.9	10.8	10.7	10.0	10.4	11.4	11.3	10.1	10.8	10.8	9.5
(40) Clear-Sky Solar Irradiance	taub		0.402	0.443	0.479	0.554	0.528	0.518	0.562	0.542	0.520	0.479	0.431	0.410
	taud		2.149	2.049	1.992	1.852	1.973	2.029	1.933	1.977	2.001	2.066	2.121	2.128
	Ebn at Noon		227	236	242	233	244	246	233	234	228	221	214	212
	Edh at Noon		34	43	51	63	57	54	59	55	50	42	35	33
(44) All-Sky Solar Radiation	RadAvg		488	676	1092	1518	1975	2203	2108	1876	1413	884	585	437
(45)	RadStd		65	106	111	156	113	104	97	106	108	121	61	54

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	+2.02	N/A	N/A	N/A	N/A	N/A	+207
(47) Regional (3 neighbors)	N/A	N/A	N/A	N/A	+2.02	N/A	N/A	N/A	N/A	N/A	+207

Nomenclature: See separate page