

BAKU HEYDAR ALIYEV, Azerbaijan

WMO: 378640

Lat: 40.468N

Lon: 50.047E

Elev: 3

StdP: 101.29

Time Zone: 4.00 (E04)

Period: 00-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-2.1	-0.9	-5.0	2.5	0.3	-3.3	2.9	1.1	15.3	4.0	14.0	4.2	5.9	320	0.577

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.2	35.5	21.2	33.9	21.5	32.1	21.8	27.0	28.4	25.9	27.9	24.9	27.8	4.5	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.9	22.5	27.8	25.2	20.4	26.6	24.1	19.0	26.0	85.3	27.8	80.7	27.7	75.9	27.2	32.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
14.0	12.3	11.0	-5.1	38.2	2.9	1.5	-7.2	39.3	-8.9	40.2	-10.5	41.0	-12.6	42.1		
			-5.4	27.5	2.8	1.8	-7.4	28.8	-9.0	29.9	-10.6	30.9	-12.6	32.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	15.4	4.9	5.0	7.8	12.1	18.7	23.9	26.8	27.0	22.6	16.9	11.0	7.0	
	DBStd	8.52	2.77	2.85	2.64	3.14	3.09	2.63	2.07	2.13	2.63	3.16	3.20	2.77	
	HDD10.0	512	159	139	77	13	0	0	0	0	0	1	24	98	
	HDD18.3	1974	417	372	326	188	33	1	0	0	3	65	219	352	
	CDD10.0	2477	1	1	10	76	271	418	522	526	379	214	56	5	
	CDD18.3	898	0	0	0	1	45	169	263	268	132	20	0	0	
	CDH23.3	8294	0	0	1	9	281	1399	2772	2937	847	48	0	0	
	CDH26.7	3211	0	0	0	1	63	510	1157	1266	211	3	0	0	
Wind	WSAvg	5.1	5.1	5.4	6.0	5.5	4.7	5.4	5.6	4.7	4.7	4.7	4.8	5.0	
Precipitation	PrecAvg	218	23	22	23	23	13	9	2	7	16	27	32	26	
	PrecMax	336	69	64	82	85	44	54	12	42	42	80	115	80	
	PrecMin	101	0	1	0	1	0	0	0	0	0	0	3	0	
	PrecStd	59	19	15	18	17	12	11	3	11	13	22	23	19	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	14.1	14.2	19.8	24.8	31.0	36.1	37.2	37.9	33.1	26.5	20.2	15.4	
		MCWB	8.5	9.1	12.4	15.8	17.7	20.3	21.2	21.3	21.4	20.1	16.8	12.6	
	2%	DB	10.9	11.0	15.2	21.1	28.2	33.1	35.2	35.9	30.9	24.8	18.1	13.2	
		MCWB	7.9	8.2	11.1	14.7	18.3	20.2	21.0	21.5	21.7	19.9	15.5	11.2	
	5%	DB	9.6	9.5	13.1	19.1	26.2	31.2	33.7	34.1	29.0	23.1	16.9	12.1	
		MCWB	7.7	7.7	10.1	13.7	17.8	20.4	21.6	22.1	21.4	19.3	15.0	10.3	
	10%	DB	8.8	8.8	11.8	17.1	24.4	29.6	32.0	32.2	27.3	21.9	15.7	11.0	
		MCWB	7.4	7.5	9.4	13.3	17.8	20.1	21.8	22.7	21.3	18.8	14.0	9.4	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.0	10.4	13.5	17.5	22.6	26.1	28.4	28.8	27.0	23.1	18.1	13.8
			MCDB	11.4	12.1	17.5	20.9	24.1	27.6	29.5	29.9	28.1	23.8	19.0	14.6
2%		WB	8.7	8.9	11.7	15.9	20.8	24.1	26.8	27.1	24.9	21.6	16.5	12.0	
		MCDB	9.8	9.8	14.5	19.2	23.7	26.7	28.3	28.6	26.4	23.0	17.6	12.9	
5%		WB	8.0	8.1	10.6	14.7	19.7	22.9	25.7	26.1	23.7	20.4	15.2	10.8	
		MCDB	9.1	9.1	12.8	18.1	23.5	26.4	27.9	28.1	26.0	22.0	16.2	11.9	
10%		WB	7.3	7.4	9.7	13.6	18.7	22.0	24.5	25.2	22.7	19.4	14.2	9.8	
		MCDB	8.2	8.3	11.2	16.6	22.5	26.2	28.0	28.1	25.5	21.2	15.3	10.7	
Mean Daily Temperature Range		5% DB	MDBR	5.2	5.2	6.4	7.6	9.0	9.1	8.6	9.2	7.9	6.6	5.8	5.2
			MCDBR	7.5	6.9	9.5	10.7	12.0	12.3	12.6	13.6	10.6	8.6	7.6	6.9
	MCWBR		5.4	5.0	5.9	5.7	4.9	5.1	5.6	6.3	5.1	5.6	5.5	5.2	
	5% WB	MCDBR	6.6	6.2	8.7	9.5	9.8	9.9	9.2	10.6	8.6	7.6	7.0	6.2	
		MCWBR	5.2	4.9	6.0	5.9	5.6	5.8	6.3	6.3	5.6	6.0	6.0	5.3	
Clear-Sky Solar Irradiance	taub	0.402	0.443	0.479	0.554	0.528	0.518	0.562	0.542	0.520	0.479	0.431	0.410		
	taud	2.149	2.049	1.992	1.852	1.973	2.029	1.933	1.977	2.001	2.066	2.121	2.128		
	Ebn at Noon	717	743	764	734	768	775	735	737	719	697	676	668		
	Edh at Noon	108	137	161	198	180	170	186	173	159	133	110	103		
All-Sky Solar Radiation	RadAvg	1.54	2.13	3.44	4.78	6.23	6.95	6.64	5.92	4.46	2.79	1.84	1.38		
	RadStd	0.20	0.33	0.35	0.49	0.36	0.33	0.30	0.33	0.34	0.38	0.19	0.17		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	+1.12	N/A	N/A	N/A	N/A	N/A	+115
(47)	Regional (3 neighbors)	N/A	N/A	N/A	+1.12	N/A	N/A	N/A	N/A	N/A	+115

Nomenclature: See separate page