

LANKARAN, Azerbaijan

WMO: 379850

Lat: 38.7411N

Lon: 48.8262E

Elev: -39

StdP: 14.72

Time Zone: 4.00 (E04)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	27.8	30.2	23.2	17.5	31.8	26.5	20.4	33.1	15.2	45.7	13.1	42.6	3.0	320	0.371

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.2	93.2	72.5	91.2	73.8	89.2	74.0	80.5	86.3	78.3	85.3	76.8	84.9	7.4	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
78.9	149.8	84.5	76.5	137.8	82.8	74.3	128.0	81.9	44.2	86.0	41.9	85.2	40.3	84.7	90.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
15.7	13.5	11.6	DB	21.3	98.1	3.3	1.8	18.9	99.4	16.9	100.5	15.1	101.5	12.7	102.8
			WB	20.6	81.8	3.2	1.6	18.3	82.9	16.4	83.9	14.6	84.8	12.3	85.9

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	59.7	41.5	42.1	48.2	55.8	66.9	75.1	79.0	78.2	71.3	61.9	51.2	44.3	(6)
	DBStd	14.48	4.92	5.50	4.82	5.42	4.48	3.88	3.51	3.56	4.34	5.56	5.85	5.18	(7)
	HDD50	832	267	223	89	10	0	0	0	0	0	2	53	188	(8)
	HDD65	3389	729	640	522	278	32	1	0	0	6	124	414	643	(9)
	CDD50	4381	3	3	33	185	523	752	900	873	638	372	89	10	(10)
	CDD65	1463	0	0	1	3	90	303	435	408	194	29	0	0	(11)
	CDH74	14009	2	0	14	34	556	2827	4775	4400	1281	119	1	0	(12)
	CDH80	5372	0	0	5	5	83	1035	2069	1896	265	14	0	0	(13)
(14) Wind	WSAvg	4.0	3.6	3.7	4.6	4.6	4.5	4.6	4.1	4.1	3.9	3.5	3.3	3.2	(14)
(15) Precipitation	PrecAvg	45.9	3.6	4.2	4.1	2.2	1.8	1.7	0.8	2.3	6.9	9.1	6.1	3.7	(15)
	PrecMax	70.6	10.0	8.7	8.4	4.7	4.4	6.0	8.8	18.3	31.3	19.3	16.4	10.0	(16)
	PrecMin	24.7	1.0	0.2	1.1	0.2	0.2	0.0	0.0	0.0	0.0	0.1	0.8	0.4	(17)
	PrecStd	9.1	2.0	2.2	2.0	1.3	1.3	1.8	1.6	3.3	5.9	3.9	3.5	2.2	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	62.8	61.5	71.8	78.8	86.5	93.5	95.6	95.4	87.1	81.5	69.1	64.1	(19)
		MCWB	51.3	49.5	56.8	62.6	68.8	70.2	72.9	72.3	74.9	68.2	62.0	53.2	(20)
	2%	DB	55.4	55.7	63.4	72.7	82.4	90.5	93.4	93.0	85.3	76.8	64.7	58.4	(21)
		MCWB	48.0	48.4	54.8	61.5	68.4	70.5	72.7	73.3	73.4	68.9	59.0	52.4	(22)
	5%	DB	51.6	52.0	59.1	68.4	79.7	88.1	91.3	91.1	83.3	74.2	62.4	55.1	(23)
		MCWB	46.9	47.1	52.5	60.8	68.1	70.6	74.1	75.0	72.5	67.1	58.3	50.8	(24)
	10%	DB	49.0	50.0	55.8	65.7	77.1	85.9	89.3	89.0	80.9	71.7	60.2	52.2	(25)
		MCWB	45.9	46.3	50.8	59.3	67.3	70.6	74.3	75.5	71.7	66.0	56.8	49.1	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	52.0	51.8	60.2	66.6	73.9	77.3	83.5	84.3	78.3	72.6	63.5	56.4	(27)
		MCDB	58.6	58.0	67.4	73.4	79.2	85.0	87.9	87.5	83.2	76.6	67.3	60.0	(28)
	2%	WB	49.3	49.4	55.8	63.6	71.7	75.5	80.4	81.3	76.5	70.3	60.4	53.6	(29)
		MCDB	53.4	54.0	61.6	69.3	78.2	83.7	86.1	87.0	82.0	74.7	62.8	56.7	(30)
	5%	WB	47.6	47.8	53.3	61.6	69.8	74.1	78.3	78.9	74.5	68.4	58.9	51.5	(31)
		MCDB	50.5	51.1	58.4	67.4	76.5	82.8	85.5	85.7	80.3	72.6	61.6	54.5	(32)
	10%	WB	46.1	46.7	51.4	59.5	68.4	72.8	76.6	77.3	72.8	66.7	57.1	49.7	(33)
		MCDB	48.6	49.4	55.1	64.8	75.0	81.7	85.0	85.6	78.7	70.6	59.7	52.2	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	13.2	12.0	13.3	15.4	17.1	19.0	18.2	18.4	14.8	13.6	13.1	13.1	(35)
		MCDBR	20.8	18.0	20.9	21.1	22.3	23.2	22.2	23.8	19.2	19.0	17.7	19.3	(36)
		MCWBR	14.8	12.4	13.1	12.4	11.6	11.2	11.3	12.7	10.9	11.9	12.9	13.8	(37)
	5% WB	MCDBR	17.4	14.6	19.1	19.1	19.1	20.5	19.5	19.4	16.1	16.6	15.1	16.7	(38)
		MCWBR	13.0	10.8	12.7	12.5	11.5	12.0	12.8	12.8	10.8	11.4	11.9	12.6	(39)
(40) Clear-Sky Solar Irradiance	taub		0.395	0.442	0.493	0.577	0.558	0.552	0.600	0.578	0.556	0.505	0.436	0.398	(40)
	taud		2.161	2.039	1.948	1.801	1.894	1.939	1.848	1.897	1.931	2.013	2.122	2.171	(41)
	Ebn at Noon		236	240	241	229	237	238	225	226	221	217	219	224	(42)
	Edh at Noon		35	45	54	67	62	59	64	60	55	46	36	32	(43)
(44) All-Sky Solar Radiation	RadAvg		613	825	1120	1460	1907	2207	2117	1903	1407	938	664	541	(44)
(45)	RadStd		66	121	128	173	119	117	120	161	124	129	77	57	(45)

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (8 neighbors)	+0.59	N/A	N/A	+1.82	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page