

LANKARAN, Azerbaijan

WMO: **379850**Lat: **38.7411N**Lon: **48.8262E**Elev: **-12**StdP: **101.47**Time Zone: **4.00 (E04)**Period: **94-19**WBAN: **99999**

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-2.4	-1.0	-4.9	2.5	-0.1	-3.1	2.9	0.6	6.8	7.6	5.9	5.9	1.3	320	0.371

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.1	34.0	22.5	32.9	23.2	31.8	23.3	26.9	30.2	25.7	29.6	24.9	29.4	3.3	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.1	21.4	29.1	24.7	19.7	28.2	23.5	18.3	27.7	84.9	30.0	79.5	29.6	75.9	29.3	32.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
7.0	6.0	5.2	DB	-6.0	36.7	1.8	1.0	-7.3	37.5	-8.4	38.1	-9.4	38.6	-10.7	39.4	(4)
			WB	-6.3	27.6	1.8	0.9	-7.6	28.3	-8.6	28.8	-9.7	29.3	-11.0	30.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	15.4	5.3	5.6	9.0	13.2	19.4	23.9	26.1	25.7	21.8	16.6	10.7	6.8
	DBStd	8.04	2.73	3.06	2.68	3.01	2.49	2.16	1.95	1.98	2.41	3.09	3.25	2.88
	HDD10.0	462	148	124	49	6	0	0	0	0	0	1	29	104
	HDD18.3	1883	405	356	290	154	18	1	0	0	3	69	230	357
	CDD10.0	2434	2	2	18	103	291	418	500	485	354	207	49	6
	CDD18.3	813	0	0	1	2	50	168	242	227	108	16	0	0
	CDH23.3	7783	1	0	8	19	309	1571	2653	2444	712	66	1	0
	CDH26.7	2984	0	0	3	3	46	575	1149	1053	147	8	0	0
Wind	WSAvg	1.8	1.6	1.6	2.0	2.1	2.0	2.1	1.8	1.8	1.7	1.6	1.5	1.4
Precipitation	PrecAvg	1167	92	106	103	57	45	44	20	59	174	230	156	93
	PrecMax	1792	254	222	214	119	113	153	224	465	796	489	416	253
	PrecMin	628	25	6	28	5	5	0	0	0	0	3	20	11
	PrecStd	230	52	57	52	33	34	46	41	83	149	100	90	57
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	17.1	16.4	22.1	26.0	30.3	34.2	35.3	35.2	30.6	27.5	20.6	17.8
		MCWB	10.7	9.7	13.8	17.0	20.4	21.2	22.7	22.4	23.8	20.1	16.6	11.8
	2%	DB	13.0	13.1	17.4	22.6	28.0	32.5	34.1	33.9	29.6	24.9	18.2	14.7
		MCWB	8.9	9.1	12.7	16.4	20.2	21.4	22.6	23.0	23.0	20.5	15.0	11.3
	5%	DB	10.9	11.1	15.1	20.2	26.5	31.1	32.9	32.8	28.5	23.4	16.9	12.8
		MCWB	8.3	8.4	11.4	16.0	20.0	21.4	23.4	23.9	22.5	19.5	14.6	10.5
	10%	DB	9.4	10.0	13.2	18.7	25.0	30.0	31.8	31.6	27.2	22.1	15.7	11.2
		MCWB	7.7	7.9	10.5	15.1	19.6	21.5	23.5	24.2	22.1	18.9	13.8	9.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.1	11.0	15.6	19.2	23.3	25.2	28.6	29.1	25.7	22.5	17.5	13.6
		MCDB	14.8	14.4	19.7	23.0	26.2	29.4	31.1	30.9	28.4	24.8	19.6	15.6
	2%	WB	9.6	9.6	13.2	17.6	22.0	24.2	26.9	27.4	24.7	21.3	15.8	12.0
		MCDB	11.9	12.2	16.4	20.7	25.6	28.7	30.1	30.6	27.8	23.7	17.1	13.7
	5%	WB	8.7	8.8	11.8	16.5	21.0	23.4	25.7	26.1	23.6	20.2	14.9	10.8
		MCDB	10.3	10.6	14.7	19.7	24.7	28.2	29.7	29.8	26.8	22.6	16.4	12.5
	10%	WB	7.8	8.2	10.8	15.3	20.2	22.6	24.8	25.2	22.6	19.3	13.9	9.8
		MCDB	9.2	9.6	12.8	18.2	23.9	27.6	29.4	29.8	26.0	21.4	15.4	11.2
Mean Daily Temperature Range	5% DB	MDBR	7.4	6.6	7.4	8.6	9.5	10.6	10.1	10.2	8.2	7.6	7.3	7.3
		MCDBR	11.6	10.0	11.6	11.7	12.4	12.9	12.3	13.2	10.7	10.6	9.8	10.7
		MCWBR	8.2	6.9	7.3	6.9	6.4	6.2	6.3	7.0	6.1	6.6	7.2	7.6
	5% WB	MCDBR	9.7	8.1	10.6	10.6	10.6	11.4	10.9	10.8	8.9	9.2	8.4	9.3
		MCWBR	7.2	6.0	7.1	6.9	6.4	6.7	7.1	7.1	6.0	6.4	6.6	7.0
Clear-Sky Solar Irradiance	taub	0.395	0.442	0.493	0.577	0.558	0.552	0.600	0.578	0.556	0.505	0.436	0.398	
	taud	2.161	2.039	1.948	1.801	1.894	1.939	1.848	1.897	1.931	2.013	2.122	2.171	
	Ebn at Noon	743	756	759	721	747	751	709	713	696	684	690	706	
	Edh at Noon	110	142	171	211	195	187	203	189	173	144	114	102	
All-Sky Solar Radiation	RadAvg	1.93	2.60	3.53	4.60	6.01	6.96	6.67	6.00	4.43	2.96	2.09	1.71	
	RadStd	0.21	0.38	0.40	0.55	0.37	0.37	0.38	0.51	0.39	0.41	0.24	0.18	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (8 neighbors)	+0.33	N/A	N/A	+1.01	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page