

JASLIQ, Uzbekistan

WMO: 381410

Lat: 43.971N

Lon: 57.500E

Elev: 127

StdP: 99.81

Time Zone: 5.00 (E05)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-23.8	-20.5	-28.1	0.3	-23.6	-25.0	0.4	-20.2	22.1	-14.3	20.3	-7.7	2.8	90	0.603

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.9	40.1	19.6	38.4	19.1	36.8	18.7	21.1	35.6	20.2	35.0	19.5	34.3	3.6	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.0	11.6	26.3	14.4	10.4	26.4	13.2	9.6	26.4	61.5	35.3	58.4	35.0	55.8	34.2	26.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
20.0	16.3	14.7	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
			-25.8	42.8	4.3	2.0	-28.9	44.2	-31.4	45.4	-33.8	46.6	-36.9	48.0		
			-26.1	23.5	4.2	1.8	-29.1	24.8	-31.5	25.9	-33.9	26.9	-36.9	28.2		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	11.3	-7.4	-5.6	4.8	13.2	21.3	26.4	28.7	26.4	19.2	10.3	1.7	-4.2	(6)
(7)		DBStd	13.64	6.83	6.66	5.20	5.16	3.81	3.49	3.42	3.87	4.25	4.87	5.92	5.57	(7)
(8)		HDD10.0	1918	538	436	173	25	0	0	0	0	1	54	252	439	(8)
(9)		HDD18.3	3557	796	669	419	168	16	1	0	1	39	251	499	698	(9)
(10)		CDD10.0	2407	0	0	12	121	349	492	579	510	276	65	3	0	(10)
(11)		CDD18.3	1003	0	0	0	14	107	243	321	252	64	2	0	0	(11)
(12)		CDH23.3	14095	0	0	4	204	1360	3482	4743	3469	786	46	0	0	(12)
(13)		CDH26.7	7949	0	0	1	62	592	2006	2932	2043	308	7	0	0	(13)
(14)	Wind	WSAvg	4.5	4.7	5.4	5.5	5.0	5.5	4.6	4.1	4.0	3.9	3.7	3.4	4.1	(14)
(15)	Precipitation	PrecAvg	120	10	8	15	17	16	11	4	4	3	8	13	12	(15)
(16)		PrecMax	242	37	40	40	46	61	40	13	23	17	34	30	38	(16)
(17)		PrecMin	46	0	1	0	2	0	0	0	0	0	0	0	0	(17)
(18)		PrecStd	45	8	8	11	10	14	9	4	6	4	8	10	10	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.5	9.5	22.6	31.3	36.1	40.8	43.1	41.2	35.8	27.5	18.3	9.6	(19)
(20)			MCWB	4.5	5.0	13.8	16.5	17.8	19.7	20.0	19.7	18.1	14.5	12.0	4.2	(20)
(21)		2%	DB	4.2	6.1	18.5	28.5	34.0	38.8	40.7	39.2	32.5	24.4	14.7	5.9	(21)
(22)			MCWB	1.8	2.6	11.1	15.9	17.2	19.3	19.7	19.4	17.2	13.3	8.7	3.0	(22)
(23)		5%	DB	2.2	3.6	15.5	25.6	32.1	37.1	38.9	37.5	30.1	21.6	12.0	3.9	(23)
(24)			MCWB	0.1	0.6	9.6	14.7	17.0	18.6	19.4	19.0	16.3	12.0	6.7	1.6	(24)
(25)		10%	DB	0.7	1.9	12.8	22.6	30.1	35.3	37.0	35.6	27.9	19.0	9.3	2.2	(25)
(26)			MCWB	-1.0	-0.5	7.7	13.2	16.2	18.1	18.8	18.5	15.2	10.8	5.2	0.1	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.9	5.2	14.7	18.4	20.0	21.7	22.5	21.9	19.2	15.7	12.5	5.2	(27)
(28)			MCDWB	6.5	9.5	22.2	28.9	31.1	36.5	35.6	37.1	32.1	25.7	18.0	8.4	(28)
(29)		2%	WB	2.1	2.8	11.7	16.4	18.5	20.5	21.3	20.6	17.9	14.1	9.2	3.3	(29)
(30)			MCDWB	3.6	5.7	17.8	27.1	30.6	35.2	35.7	35.9	31.1	22.8	13.3	5.6	(30)
(31)		5%	WB	0.3	1.0	9.6	15.0	17.7	19.6	20.3	19.7	16.7	12.7	7.2	1.8	(31)
(32)			MCDWB	1.9	3.2	15.2	24.9	29.8	34.0	35.2	35.1	28.8	20.7	10.9	3.8	(32)
(33)		10%	WB	-0.9	-0.4	7.9	13.5	16.9	18.8	19.5	18.9	15.7	11.3	5.7	0.3	(33)
(34)			MCDWB	0.6	1.8	12.7	21.9	28.8	33.0	34.8	34.1	27.0	18.3	8.9	2.0	(34)
(35)	Mean Daily Temperature Range	MDBR		7.2	8.5	10.4	12.5	13.5	14.3	13.9	14.5	14.0	13.1	9.3	6.8	(35)
(36)		5% DB	MCDBR	6.8	8.9	15.0	16.3	16.1	16.0	15.6	16.9	16.4	16.4	13.9	9.0	(36)
(37)			MCWBR	5.7	7.1	10.0	8.3	6.9	6.1	5.3	6.3	7.3	8.9	9.6	7.1	(37)
(38)		5% WB	MCDBR	6.5	8.5	14.6	15.5	14.5	14.6	14.4	15.8	15.1	15.0	11.9	8.2	(38)
(39)			MCWBR	5.6	7.0	10.1	8.8	7.2	6.5	6.2	6.7	7.5	8.7	8.6	6.8	(39)
(40)	Clear-Sky Solar Irradiance	taub		0.368	0.393	0.464	0.518	0.516	0.497	0.483	0.462	0.431	0.427	0.391	0.369	(40)
(41)		taud		2.050	1.997	1.870	1.770	1.819	1.899	1.960	1.995	2.026	1.984	2.051	2.050	(41)
(42)		Ebn at Noon		704	762	754	750	768	785	791	792	781	712	668	654	(42)
(43)		Edh at Noon		108	135	176	211	206	191	178	166	148	135	107	98	(43)
(44)	All-Sky Solar Radiation	RadAvg		1.40	2.35	3.76	5.30	6.58	7.38	7.07	6.41	5.01	3.29	1.91	1.22	(44)
(45)		RadStd		0.22	0.32	0.36	0.41	0.36	0.30	0.25	0.29	0.23	0.19	0.22	0.20	(45)

Historical Trends

		DBAvg		Heating		Cooling		Degree-Days			
				99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	N/A	N/A	+1.18	-0.47	-0.90	N/A	N/A	N/A	N/A	+98

Nomenclature: See separate page