

AK-BAJTAL, Uzbekistan

WMO: 381780

Lat: 43.1543N

Lon: 64.3212E

Elev: 237

StdP: 98.51

Time Zone: 5.00 (E05)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-21.2	-17.9	-26.4	0.3	-20.1	-23.1	0.5	-16.9	13.4	-1.4	10.4	-2.8	2.6	0	0.536

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.5	40.0	21.4	38.3	20.6	36.8	20.0	22.2	38.0	21.2	36.9	20.5	35.7	3.6	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.2	11.8	29.8	14.7	10.8	30.4	13.5	9.9	30.4	66.0	38.1	62.7	36.8	59.8	35.8	28.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.0	9.1	7.5	-23.1	42.7	4.1	1.9	-26.0	44.1	-28.4	45.2	-30.7	46.3	-33.7	47.6		
(5)			-23.3	24.0	4.0	1.7	-26.2	25.2	-28.6	26.2	-30.8	27.2	-33.8	28.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	13.0	-4.5	-2.2	6.5	14.7	22.0	27.3	29.3	27.8	20.6	12.5	3.8	-2.6	(6)
(7)		DBStd	13.16	6.43	7.08	6.11	5.45	4.16	3.75	3.30	3.69	4.70	5.52	5.84	6.27	(7)
(8)		HDD10.0	1583	450	345	140	19	0	0	0	0	1	38	199	391	(8)
(9)		HDD18.3	3107	708	576	368	133	14	1	0	0	29	192	437	649	(9)
(10)		CDD10.0	2684	0	2	33	160	371	521	598	551	320	116	13	1	(10)
(11)		CDD18.3	1165	0	0	2	24	127	271	340	292	98	11	0	0	(11)
(12)		CDH23.3	15964	0	0	27	267	1503	3831	5049	4046	1104	134	3	0	(12)
(13)		CDH26.7	8868	0	0	7	83	656	2196	3063	2351	479	33	0	0	(13)
(14)	Wind	WSAvg	3.4	3.0	3.3	3.7	3.7	3.7	3.6	3.5	3.6	3.2	3.0	3.0	3.2	(14)
(15)	Precipitation	PrecAvg	124	12	13	18	20	18	7	2	1	6	14	10	(15)	
(16)		PrecMax	284	37	42	53	75	76	58	18	13	4	27	43	42	(16)
(17)		PrecMin	49	1	0	0	0	0	0	0	0	0	0	0	0	(17)
(18)		PrecStd	54	8	11	14	17	21	12	4	4	1	7	13	10	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.9	18.1	27.0	32.4	36.7	41.1	43.1	41.2	37.1	30.2	22.4	14.0	(19)
(20)			MCWB	7.0	10.0	15.1	18.1	19.8	22.0	23.0	21.3	20.0	16.5	12.5	6.6	(20)
(21)		2%	DB	8.2	12.7	21.9	29.1	34.2	38.9	40.5	39.1	34.3	26.8	18.1	10.1	(21)
(22)			MCWB	4.7	7.6	12.4	16.0	18.9	21.0	21.8	20.7	18.7	14.6	10.4	5.5	(22)
(23)		5%	DB	5.2	9.3	18.7	26.3	32.4	37.2	38.5	37.3	31.6	24.3	14.9	7.4	(23)
(24)			MCWB	2.2	5.2	10.6	14.8	18.0	20.0	20.8	20.3	17.3	13.5	8.7	3.6	(24)
(25)		10%	DB	3.0	6.5	15.8	23.9	30.4	35.5	36.9	35.7	29.4	21.6	12.1	5.2	(25)
(26)			MCWB	0.7	3.2	9.2	13.5	17.1	19.3	20.1	19.7	16.2	12.1	7.2	2.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.8	11.4	15.4	18.7	20.9	23.2	23.4	22.8	20.4	16.9	13.3	8.2	(27)
(28)			MCDWB	11.1	17.1	24.4	29.8	34.5	38.5	40.4	38.4	36.2	28.6	20.0	12.6	(28)
(29)		2%	WB	4.8	8.0	13.0	16.8	19.3	21.6	22.4	21.5	18.8	15.2	11.1	5.7	(29)
(30)			MCDWB	7.9	12.1	20.9	27.3	32.5	37.1	38.8	37.3	33.5	25.8	16.9	9.6	(30)
(31)		5%	WB	2.6	5.5	11.2	15.3	18.4	20.6	21.5	20.7	17.6	13.8	9.2	4.0	(31)
(32)			MCDWB	4.9	8.9	17.8	25.2	31.3	36.0	37.2	36.3	31.2	23.4	14.2	7.0	(32)
(33)		10%	WB	0.8	3.4	9.5	13.8	17.5	19.7	20.6	19.9	16.3	12.3	7.4	2.3	(33)
(34)			MCDWB	2.7	6.4	15.5	23.2	29.5	34.5	35.8	35.0	28.9	21.3	11.5	5.0	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	7.5	9.0	11.1	12.0	12.9	12.8	12.5	12.8	12.9	12.1	9.2	7.9	(35)
(36)			MCDBR	9.3	12.4	14.9	14.6	14.9	14.4	14.0	14.7	14.8	12.5	10.7	(36)	
(37)			MCWBR	6.9	8.4	8.5	7.5	7.2	6.6	6.2	6.5	7.3	8.1	7.7	7.4	(37)
(38)		5% WB	MCDBR	8.9	11.8	13.9	14.2	14.1	13.9	13.7	13.7	14.2	14.4	11.6	9.9	(38)
(39)			MCWBR	6.7	8.2	8.6	7.7	7.3	6.9	6.4	6.8	7.3	8.3	7.3	7.2	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.352	0.381	0.436	0.480	0.478	0.464	0.444	0.420	0.391	0.394	0.376	0.348	(40)	
(41)		taud	2.121	2.063	1.964	1.898	1.945	2.015	2.091	2.136	2.168	2.098	2.112	2.138	(41)	
(42)		Ebn at Noon	741	786	789	787	802	814	826	834	829	760	703	703	(42)	
(43)		Edh at Noon	102	128	161	186	183	171	157	145	130	122	103	92	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.58	2.61	4.04	5.56	6.96	7.73	7.57	6.88	5.51	3.65	2.16	1.44	(44)	
(45)		RadStd	0.23	0.35	0.36	0.44	0.42	0.29	0.27	0.20	0.18	0.20	0.22	0.19	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	-1.55	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	N/A	N/A	N/A	-0.63	-1.80	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page