

DASHOGUZ, TurkmenistanWMO: **383920**Lat: **41.761N**Lon: **59.827E**Elev: **269**StdP: **14.55**Time Zone: **5.00 (E05)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	1.6	8.2	-6.1	4.0	4.1	-0.5	5.4	11.3	21.0	30.6	19.7	32.2	8.1	0	0.561

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	23.3	104.1	72.8	101.0	71.8	98.6	71.3	76.1	98.4	74.3	96.7	72.8	95.1	10.3	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
68.3	105.0	91.1	66.2	97.5	89.8	64.3	91.1	88.0	39.7	97.9	38.0	96.8	36.6	95.1	83.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.3	18.5	16.8	-0.1	109.4	8.7	3.0	-6.4	111.5	-11.5	113.3	-16.4	115.0	-22.8	117.2		
(5)			-0.9	78.5	8.6	2.8	-7.0	80.5	-12.1	82.1	-16.9	83.7	-23.1	85.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	57.7	28.8	32.7	46.5	60.6	73.3	82.0	85.0	81.4	69.9	56.2	42.0	32.0	
	DBStd	21.57	10.25	10.23	9.29	9.16	6.85	5.67	5.13	6.02	6.94	8.51	9.37	8.47	
	HDD50	2204	657	486	179	18	0	0	0	0	0	39	266	559	
	HDD65	4841	1122	903	578	188	15	0	0	0	31	290	690	1024	
	CDD50	5001	0	3	69	337	723	959	1084	973	596	231	26	0	
	CDD65	2162	0	0	3	57	273	509	619	508	176	17	0	0	
	CDH74	29247	0	0	47	652	3173	7146	9099	6851	2024	251	4	0	
	CDH80	16337	0	0	10	225	1450	4168	5568	4009	846	61	0	0	
Wind	WSAvg	9.0	9.0	9.7	10.2	10.2	9.6	9.2	8.7	8.5	8.3	8.0	8.3	8.9	
Precipitation	PrecAvg	3.9	0.4	0.4	0.6	0.6	0.5	0.2	0.0	0.1	0.1	0.2	0.4	0.4	
	PrecMax	6.8	1.1	1.1	1.3	1.7	1.9	0.8	0.3	0.3	0.7	0.9	1.3	1.5	
	PrecMin	1.8	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
	PrecStd	1.2	0.3	0.3	0.4	0.4	0.5	0.2	0.1	0.1	0.2	0.2	0.4	0.4	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.2	63.8	80.6	92.3	98.8	105.8	109.3	106.7	99.1	86.3	71.5	57.2	
		MCWB	44.3	50.7	60.4	67.9	69.2	73.3	73.8	73.6	70.3	62.6	56.4	48.0	
	2%	DB	48.6	55.6	72.0	86.2	94.6	102.2	104.8	102.3	92.7	80.5	64.6	51.1	
		MCWB	42.3	46.3	56.3	63.6	67.8	72.1	73.1	72.0	67.5	60.2	52.3	44.1	
	5%	DB	44.5	50.5	66.4	81.2	91.4	99.0	101.8	99.6	88.2	75.7	60.6	46.5	
		MCWB	40.0	43.2	53.4	60.5	66.6	71.1	72.5	71.3	64.8	57.9	49.8	41.3	
	10%	DB	40.9	46.3	61.1	76.9	88.0	96.6	98.7	96.5	84.5	71.7	55.7	43.0	
		MCWB	37.0	40.2	50.2	58.6	64.7	70.1	71.8	70.4	63.2	55.7	47.5	38.7	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	46.2	51.3	61.9	69.7	73.1	77.8	79.1	77.2	72.4	64.5	58.1	48.6
			MCDB	52.6	62.3	77.9	88.4	93.2	100.6	101.6	101.4	93.4	80.2	68.5	55.6
2%		WB	42.9	46.9	57.2	65.1	70.2	75.1	76.7	74.6	69.0	61.4	53.8	44.9	
		MCDB	48.1	54.4	70.7	83.5	90.6	97.8	98.1	97.4	89.6	78.0	62.9	49.7	
5%		WB	40.0	43.7	54.1	62.1	67.8	73.4	74.7	72.8	66.5	58.8	50.9	41.9	
		MCDB	43.8	49.7	65.4	78.1	87.6	95.7	96.8	95.6	86.1	74.2	58.7	46.3	
10%		WB	37.1	40.7	50.9	59.4	66.0	71.6	73.1	71.1	64.2	56.5	48.0	39.0	
		MCDB	40.3	45.6	60.4	74.1	84.9	93.5	95.4	93.5	82.7	70.2	55.5	42.5	
Mean Daily Temperature Range		5% DB	MDBR	14.7	16.9	19.5	20.9	22.4	23.4	23.3	25.1	24.7	23.2	18.2	14.9
			MCDBR	19.4	23.5	27.3	26.7	26.4	27.2	27.3	28.5	28.8	29.2	24.2	20.2
	MCWBR		13.8	15.6	15.5	12.2	11.8	11.4	10.9	11.8	13.5	15.2	15.3	14.8	
	5% WB	MCDBR	17.8	21.9	25.7	24.1	23.7	24.6	24.4	26.7	27.0	27.1	22.1	18.8	
		MCWBR	13.2	15.2	15.2	12.4	11.8	12.4	11.6	12.4	13.7	15.0	14.7	14.2	
Clear-Sky Solar Irradiance	taub	0.386	0.418	0.478	0.538	0.544	0.538	0.524	0.487	0.452	0.463	0.425	0.391		
	taud	2.035	1.970	1.873	1.777	1.805	1.834	1.889	1.956	1.999	1.933	1.995	2.032		
	Ebn at Noon	225	239	239	235	238	240	241	246	245	220	208	210		
	Edh at Noon	37	46	57	67	67	65	61	56	49	47	38	34		
All-Sky Solar Radiation	RadAvg	540	857	1304	1737	2136	2419	2357	2169	1735	1166	719	491		
	RadStd	63	93	94	124	116	101	81	68	60	68	78	69		