

URGENCH, Uzbekistan

WMO: 383960

Lat: 41.584N

Lon: 60.642E

Elev: 101

StdP: 100.12

Time Zone: 5.00 (E05)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-16.3	-13.2	-21.0	0.6	-15.9	-18.0	0.8	-11.7	9.5	-1.0	8.6	-1.1	3.3	30	0.522

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.3	39.1	21.2	37.6	20.8	36.1	20.3	23.5	34.7	22.5	33.9	21.6	33.0	3.7	30

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.9	14.8	29.4	18.7	13.7	28.6	17.3	12.6	28.0	70.7	34.6	66.8	33.9	63.4	33.0	29.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
(4) 8.9	7.8	7.0	DB	-17.8	41.7	4.3	1.4	-20.9	42.7	-23.4	43.5	-25.8	44.3	-28.9	45.3	(4)
(5)			WB	-18.3	25.6	4.1	1.4	-21.2	26.7	-23.7	27.5	-26.0	28.3	-29.0	29.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	13.7	-1.8	0.4	8.0	15.5	22.2	26.8	28.3	26.2	19.9	12.8	5.2	-0.2	(6)	
	DBStd	11.56	5.57	5.73	5.14	4.96	3.51	2.94	2.65	3.09	3.63	4.62	5.17	4.74	(7)	
	HDD10.0	1246	365	271	99	11	0	0	0	0	1	26	158	315	(8)	
	HDD18.3	2738	623	503	321	112	9	0	0	1	24	178	395	573	(9)	
	CDD10.0	2589	0	2	38	176	377	504	566	503	298	112	13	0	(10)	
	CDD18.3	1041	0	0	2	26	128	254	308	245	72	6	0	0	(11)	
	CDH23.3	13685	0	0	27	322	1533	3467	4214	3089	909	121	2	0	(12)	
	CDH26.7	7464	0	0	6	108	689	2010	2506	1754	363	28	0	0	(13)	
(14) Wind	WSAvg	3.3	3.5	3.8	4.0	3.9	3.5	3.4	3.1	3.0	2.9	2.7	2.9	3.4	(14)	
(15) Precipitation	PrecAvg	92	8	7	17	18	13	4	2	1	1	5	8	12	(15)	
	PrecMax	221	30	34	80	68	70	29	21	13	9	26	27	52	(16)	
	PrecMin	34	0	0	0	0	0	0	0	0	0	0	0	0	(17)	
	PrecStd	39	7	8	17	17	16	7	5	2	2	7	7	12	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.8	17.8	26.9	33.0	36.4	40.2	41.8	40.0	35.9	29.8	22.0	14.2	(19)	
		MCWB	7.7	10.2	14.8	18.5	18.3	20.3	21.9	22.2	20.0	16.6	14.1	8.6	(20)	
	2%	DB	9.2	13.5	22.1	29.8	34.2	38.7	39.3	38.0	32.8	26.5	18.1	10.9	(21)	
		MCWB	5.9	8.0	12.7	16.3	18.0	20.1	21.6	21.5	18.3	14.6	11.4	6.9	(22)	
	5%	DB	6.9	10.6	19.1	27.0	32.6	37.0	37.8	36.2	30.8	24.0	15.4	8.1	(23)	
		MCWB	4.6	6.2	11.4	14.9	17.6	19.6	21.3	21.0	17.3	13.5	9.5	5.5	(24)	
	10%	DB	4.9	8.0	16.2	24.4	30.8	35.2	36.1	34.8	28.5	21.7	13.0	6.1	(25)	
		MCWB	2.8	4.9	9.9	14.1	17.0	19.4	20.8	20.4	16.3	12.5	8.6	3.9	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.2	10.7	15.3	19.3	21.6	23.9	25.1	24.7	21.2	17.4	14.8	9.4	(27)	
		MCDB	11.7	16.3	25.3	30.7	30.3	34.4	35.4	35.8	32.7	26.5	20.9	13.5	(28)	
	2%	WB	6.3	8.3	13.4	17.2	19.7	22.3	23.7	23.3	19.4	15.7	12.2	7.2	(29)	
		MCDB	8.9	12.6	20.7	27.6	30.6	33.4	34.9	34.6	30.2	24.3	16.8	10.0	(30)	
	5%	WB	4.6	6.7	11.9	15.8	18.7	21.2	22.7	22.2	18.1	14.3	10.4	5.7	(31)	
		MCDB	6.7	10.2	18.3	25.1	29.4	32.9	34.4	33.6	28.6	22.4	14.3	8.1	(32)	
	10%	WB	2.9	4.9	10.4	14.5	17.8	20.3	21.8	21.2	17.0	13.0	8.7	4.0	(33)	
		MCDB	4.6	7.7	15.8	23.2	28.3	32.3	33.4	32.1	27.0	20.2	12.4	6.0	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	8.1	9.4	11.0	12.3	13.8	14.6	14.3	15.1	15.2	13.8	10.5	8.2	(35)	
		MCDBR	10.4	13.4	15.2	15.9	16.6	17.1	16.4	17.0	17.6	17.3	13.9	11.5	(36)	
	5% WB	MCWBR	7.4	8.5	7.9	6.6	6.2	5.7	6.3	6.9	7.5	8.1	8.2	8.3	(37)	
		MCWBR	9.9	12.6	14.1	14.2	14.5	14.8	15.0	16.0	16.1	15.4	12.3	11.0	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.389	0.422	0.484	0.536	0.540	0.535	0.521	0.480	0.444	0.458	0.425	0.391	(40)	
		taud	2.041	1.969	1.871	1.793	1.825	1.854	1.909	1.989	2.029	1.952	2.003	2.040	(41)	
	Ebn at Noon	Ebn at Noon	708	750	750	744	754	759	764	784	781	700	659	664	(42)	
		Edh at Noon	116	145	180	209	207	202	189	170	152	146	120	107	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1.74	2.76	4.18	5.55	6.81	7.75	7.59	6.95	5.56	3.74	2.33	1.60	(44)	
	RadStd	RadStd	0.21	0.29	0.28	0.41	0.35	0.33	0.24	0.21	0.18	0.22	0.25	0.21	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	+0.73	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (5 neighbors)	N/A	N/A	N/A	+0.73	N/A	N/A	N/A	N/A	N/A	+52	

Nomenclature: See separate page