

BUZAUBAY, Uzbekistan

WMO: 384030

Lat: 41.750N

Lon: 62.467E

Elev: 318

StdP: 14.53

Time Zone: 5.00 (E05)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-0.6	6.0	-10.8	3.1	0.8	-5.8	4.1	6.5	22.9	37.3	19.0	29.3	4.4	20	0.534

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	22.9	107.3	75.0	104.6	73.8	102.0	72.8	76.2	105.1	74.6	102.8	73.2	100.5	6.6	20

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
65.1	93.8	100.5	63.1	87.3	98.5	61.4	82.3	97.0	39.8	105.2	38.3	103.3	37.0	100.8	83.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
22.9	19.0	17.6	-2.7	112.3	9.0	3.0	-9.2	114.4	-14.5	116.2	-19.5	117.8	-26.1	120.0		
			-3.8	78.5	8.6	1.7	-10.0	79.7	-15.1	80.7	-19.9	81.7	-26.1	82.9		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	58.9	28.5	33.3	47.4	60.6	73.9	84.1	85.6	72.6	56.9	41.8	31.5
		DBStd	22.87	10.93	10.97	9.26	9.09	7.28	6.26	5.61	6.36	7.79	8.89	9.47
		HDD50	2200	667	473	158	18	0	0	0	0	36	272	576
		HDD65	4801	1131	888	550	187	14	0	0	21	275	695	1040
		CDD50	5433	0	4	77	335	742	1024	1189	1104	679	251	28
		CDD65	2561	0	0	3	54	291	574	724	639	250	25	1
		CDH74	38851	0	2	75	840	3983	8875	11777	9750	3133	401	15
		CDH80	23435	0	0	21	313	2029	5544	7763	6148	1499	117	1
(14)	Wind	WSAvg	6.5	5.7	6.5	7.1	7.2	7.1	6.9	6.7	7.0	6.7	5.6	5.4
(15)	Precipitation	PrecAvg	3.8	0.5	0.4	0.7	0.6	0.5	0.1	0.1	0.1	0.0	0.2	0.3
		PrecMax	7.6	2.0	1.1	2.0	1.6	3.5	0.7	0.4	0.4	0.2	0.7	1.0
		PrecMin	1.8	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
		PrecStd	1.4	0.4	0.3	0.5	0.4	0.7	0.2	0.1	0.1	0.0	0.2	0.3
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	56.9	67.2	82.6	93.8	101.4	108.3	113.1	109.8	102.9	89.0	75.7
			MCWB	44.8	51.4	62.6	69.1	73.9	76.1	77.5	75.4	73.3	65.8	58.0
		2%	DB	50.1	57.9	73.8	87.9	97.2	105.1	108.6	106.1	96.8	83.0	67.1
			MCWB	40.3	46.3	57.0	66.0	71.2	74.6	75.8	73.6	70.1	62.1	52.5
		5%	DB	45.4	52.4	68.4	82.9	94.1	102.2	105.3	103.3	92.4	78.2	62.1
			MCWB	37.2	42.2	53.5	63.2	69.7	73.4	74.1	72.7	67.5	59.5	49.3
		10%	DB	41.3	47.7	63.2	78.4	90.6	99.4	102.3	100.3	88.4	73.8	57.1
			MCWB	34.1	38.9	50.2	60.4	67.6	72.1	72.9	71.7	65.3	56.8	45.9
		0.4%	WB	44.8	51.9	62.9	69.9	74.5	77.7	79.2	76.9	73.5	66.0	58.0
			MCDB	55.4	65.6	81.6	92.6	99.7	106.1	109.0	106.7	101.7	88.2	74.4
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	40.6	46.4	57.5	66.4	71.9	75.7	76.6	74.7	70.7	62.4	52.8
			MCDB	49.4	57.5	73.1	87.2	95.9	103.2	106.5	103.7	96.0	82.2	66.7
		2%	WB	37.3	42.5	53.7	63.6	69.9	73.9	74.8	73.2	67.9	59.6	49.3
			MCDB	45.1	52.1	67.5	82.5	93.3	100.6	103.7	101.4	91.5	77.8	61.8
		5%	WB	34.3	39.1	50.4	60.5	68.0	72.4	73.3	71.8	65.6	56.9	45.8
			MCDB	41.0	47.4	62.9	78.1	90.0	98.4	101.1	99.8	87.6	73.6	56.6
		10%	WB	34.3	39.1	50.4	60.5	68.0	72.4	73.3	71.8	65.6	56.9	45.8
			MCDB	41.0	47.4	62.9	78.1	90.0	98.4	101.1	99.8	87.6	73.6	56.6
(35)	Mean Daily Temperature Range	5% DB	MDBR	16.2	17.7	21.9	24.5	26.1	24.9	22.9	23.6	24.9	25.4	20.3
			MCDBR	20.5	25.2	31.0	31.6	29.8	27.8	25.8	26.7	29.1	31.4	28.0
		5% WB	MCWBR	14.8	17.8	20.5	18.8	16.1	13.1	11.4	11.7	15.1	19.4	16.3
			MCDBR	20.1	24.6	30.4	31.6	29.5	26.9	25.4	26.3	28.6	30.7	27.5
		5% WB	MCWBR	14.8	17.5	20.3	19.1	16.5	13.5	11.8	12.2	15.0	19.1	16.1
			MCDBR	20.1	24.6	30.4	31.6	29.5	26.9	25.4	26.3	28.6	30.7	27.5
(40)	Clear-Sky Solar Irradiance	taub	0.384	0.419	0.479	0.526	0.524	0.521	0.499	0.461	0.427	0.436	0.409	0.380
		taud	2.038	1.958	1.847	1.787	1.822	1.843	1.913	1.990	2.033	1.969	2.009	2.045
		Ebn at Noon	226	238	239	239	243	244	248	253	252	229	213	214
		Edh at Noon	37	46	58	67	66	65	60	54	48	45	37	34
(44)	All-Sky Solar Radiation	RadAvg	556	868	1328	1774	2199	2469	2420	2207	1782	1199	747	512
		RadStd	65	95	90	134	112	96	70	64	53	64	74	65

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.85	N/A	N/A	+1.13	+1.66	+2.57	N/A	N/A	+338	+221
(47)	Regional (3 neighbors)	N/A	N/A	N/A	+1.10	-1.06	-1.66	N/A	N/A	N/A	N/A

Nomenclature: See separate page