

BUZAUBAY, Uzbekistan

WMO: 384030

Lat: 41.750N

Lon: 62.467E

Elev: 97

StdP: 100.17

Time Zone: 5.00 (E05)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-18.1	-14.5	-23.8	0.4	-17.3	-21.0	0.6	-14.1	10.2	2.9	8.5	-1.5	2.0	20	0.534

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.7	41.9	23.9	40.4	23.2	38.9	22.7	24.5	40.6	23.7	39.3	22.9	38.1	2.9	20

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.4	13.4	38.1	17.3	12.5	36.9	16.3	11.8	36.1	74.7	40.7	71.2	39.6	68.2	38.2	28.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.2	8.5	7.8	-19.3	44.6	5.0	1.7	-22.9	45.8	-25.8	46.8	-28.6	47.7	-32.3	48.9		
(5)			-19.9	25.8	4.8	1.0	-23.3	26.5	-26.1	27.1	-28.8	27.6	-32.3	28.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	14.9	-1.9	0.7	8.5	15.9	23.3	29.0	31.3	29.8	22.6	13.9	5.5	-0.3		
	DBStd	12.71	6.07	6.09	5.14	5.05	4.04	3.48	3.12	3.53	4.33	4.94	5.26	5.03		
	HDD10.0	1222	371	263	88	10	0	0	0	0	0	20	151	320		
	HDD18.3	2667	628	493	306	104	8	0	0	0	12	153	386	578		
	CDD10.0	3018	0	2	43	186	412	569	661	613	377	139	16	0		
	CDD18.3	1423	0	0	2	30	162	319	402	355	139	14	1	0		
	CDH23.3	21584	0	1	42	467	2213	4931	6543	5417	1741	223	8	0		
	CDH26.7	13019	0	0	12	174	1127	3080	4313	3416	833	65	1	0		
(14) Wind	WSAvg	2.9	2.5	2.9	3.2	3.2	3.2	3.1	3.0	3.1	3.0	2.5	2.4	2.5		
(15) Precipitation	PrecAvg	96	12	11	18	14	12	3	2	2	1	4	8	9		
	PrecMax	194	51	29	51	40	90	17	11	10	6	18	26	36		
	PrecMin	45	2	1	0	1	0	0	0	0	0	0	0	0		
	PrecStd	36	10	8	13	11	19	5	3	3	1	4	8	10		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.9	19.5	28.1	34.4	38.5	42.4	45.1	43.2	39.4	31.7	24.3	14.5		
		MCWB	7.1	10.8	17.0	20.6	23.3	24.5	25.3	24.1	23.0	18.8	14.4	7.4		
	2%	DB	10.1	14.4	23.2	31.1	36.2	40.6	42.5	41.2	36.0	28.3	19.5	11.4		
		MCWB	4.6	7.9	13.9	18.9	21.8	23.7	24.3	23.1	21.1	16.7	11.4	5.6		
	5%	DB	7.4	11.3	20.2	28.3	34.5	39.0	40.7	39.6	33.6	25.7	16.7	8.8		
		MCWB	2.9	5.7	11.9	17.3	20.9	23.0	23.4	22.6	19.7	15.3	9.6	3.7		
	10%	DB	5.1	8.7	17.3	25.8	32.5	37.4	39.1	38.0	31.3	23.2	13.9	6.5		
		MCWB	1.1	3.9	10.1	15.8	19.8	22.3	22.7	22.0	18.5	13.8	7.7	2.2		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.1	11.0	17.2	21.1	23.6	25.4	26.2	25.0	23.1	18.9	14.4	7.8		
		MCDB	13.0	18.7	27.6	33.6	37.6	41.1	42.8	41.5	38.7	31.2	23.6	13.7		
	2%	WB	4.8	8.0	14.2	19.1	22.2	24.3	24.8	23.7	21.5	16.9	11.6	5.9		
		MCDB	9.6	14.2	22.8	30.7	35.5	39.5	41.4	39.8	35.5	27.9	19.3	11.1		
	5%	WB	3.0	5.8	12.0	17.5	21.1	23.3	23.8	22.9	20.0	15.3	9.6	4.0		
		MCDB	7.3	11.2	19.7	28.1	34.1	38.1	39.9	38.6	33.0	25.5	16.5	8.6		
	10%	WB	1.3	3.9	10.2	15.8	20.0	22.5	23.0	22.1	18.6	13.8	7.7	2.2		
		MCDB	5.0	8.6	17.2	25.6	32.2	36.9	38.4	37.7	30.9	23.1	13.7	6.4		
(35) Mean Daily Temperature Range	5% DB	MDBR	9.0	9.8	12.2	13.6	14.5	13.8	12.7	13.1	13.8	14.1	11.3	9.2		
		MCDBR	11.4	14.0	17.2	17.6	16.6	15.4	14.4	14.9	16.2	17.5	15.5	12.6		
	5% WB	MCWBR	8.2	9.9	11.4	10.5	9.0	7.3	6.3	6.5	8.4	10.8	10.6	9.1		
		MCWBR	11.2	13.7	16.9	17.5	16.4	15.0	14.1	14.6	15.9	17.1	15.3	12.1		
(40) Clear-Sky Solar Irradiance	taub		0.384	0.419	0.479	0.526	0.524	0.521	0.499	0.461	0.427	0.436	0.409	0.380		
	taud		2.038	1.958	1.847	1.787	1.822	1.843	1.913	1.990	2.033	1.969	2.009	2.045		
	Ebn at Noon		712	751	752	752	767	770	782	799	796	722	673	674		
	Edh at Noon		116	146	184	210	208	204	188	169	150	142	118	106		
(44) All-Sky Solar Radiation	RadAvg		1.75	2.73	4.19	5.59	6.93	7.78	7.63	6.96	5.62	3.78	2.36	1.61		
	RadStd		0.20	0.30	0.28	0.42	0.35	0.30	0.22	0.20	0.17	0.20	0.23	0.20		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.47	N/A	N/A	+0.63	+0.92	+1.43	N/A	N/A	+188	+123
(47) Regional (3 neighbors)		N/A	N/A	N/A	+0.61	-0.59	-0.92	N/A	N/A	N/A	N/A

Nomenclature: See separate page