

TAMDYBULAQ, Uzbekistan

WMO: 384130

Lat: 41.733N

Lon: 64.617E

Elev: 774

StdP: 14.29

Time Zone: 5.00 (E05)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	2.0	8.5	-6.3	4.0	4.3	-1.4	5.2	12.6	28.4	35.1	22.8	35.2	5.3	90	0.490

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	22.4	105.3	67.9	102.5	67.1	100.1	66.4	71.0	98.0	69.3	97.0	67.8	96.1	7.4	30

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
61.1	82.9	82.1	58.1	74.2	84.5	55.4	67.2	83.6	35.3	98.1	33.8	96.6	32.5	96.2	85.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	22.2	18.0	15.1	DB	-0.1	110.4	8.0	3.0	-5.9	112.5	-10.5	114.3	-15.0	115.9	-20.8	118.1
(5)				WB	-0.8	73.8	7.7	3.9	-6.3	76.6	-10.9	78.8	-15.2	81.0	-20.8	83.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	59.3	30.6	33.8	48.2	61.3	74.4	83.9	87.2	84.3	72.3	58.3	43.1	32.5	(6)
(7)		DBStd	22.25	10.48	12.00	9.80	9.57	7.09	5.99	5.66	6.28	7.84	9.46	10.51	10.37	(7)
(8)		HDD50	2068	605	461	151	20	0	0	0	0	35	251	545	(8)	
(9)		HDD65	4588	1068	872	524	179	12	0	0	23	246	658	1006	(9)	
(10)		CDD50	5462	2	9	97	357	755	1016	1153	1062	670	291	46	4	(10)
(11)		CDD65	2504	0	0	4	66	302	566	688	597	242	37	2	0	(11)
(12)		CDH74	34985	0	2	66	690	3531	8302	10673	8594	2709	401	17	0	(12)
(13)		CDH80	20214	0	0	15	230	1650	4985	6790	5193	1235	114	2	0	(13)
(14)	Wind	WSAvg	6.5	7.0	7.2	7.3	7.0	6.6	6.4	6.2	6.0	5.8	5.9	6.3	6.8	(14)
(15)	Precipitation	PrecAvg	4.8	0.5	0.6	0.7	0.8	0.6	0.1	0.1	0.0	0.2	0.4	0.6	(15)	
(16)		PrecMax	10.9	2.8	2.0	2.5	4.1	3.3	0.7	1.3	1.1	0.4	1.4	1.9	2.1	(16)
(17)		PrecMin	2.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)
(18)		PrecStd	1.8	0.4	0.5	0.6	0.7	0.7	0.2	0.2	0.2	0.1	0.3	0.4	0.5	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	61.3	68.0	81.9	91.7	99.5	106.6	110.9	107.9	100.6	89.5	76.0	62.2	(19)
MCWB			47.6	51.5	59.6	64.7	66.8	69.0	68.5	69.0	66.5	62.7	56.8	48.8	(20)	
2%		DB	52.6	59.6	74.1	86.2	95.5	103.2	106.7	104.0	95.3	82.7	68.3	56.2	(21)	
		MCWB	44.1	47.7	55.5	61.3	65.1	68.2	67.7	67.5	64.5	59.0	52.7	44.8	(22)	
5%		DB	47.4	54.6	68.9	81.7	92.3	100.6	103.1	101.0	91.1	78.2	63.0	51.1	(23)	
		MCWB	40.3	44.5	53.1	59.1	63.7	67.0	66.7	66.6	62.5	56.9	50.0	41.9	(24)	
10%		DB	42.8	49.7	64.0	77.3	88.9	97.8	100.4	98.3	87.2	73.9	58.2	46.5	(25)	
		MCWB	37.3	41.8	50.8	56.9	62.3	65.7	66.3	65.5	60.8	54.8	47.2	39.2	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	48.9	53.1	61.8	66.8	70.7	73.6	73.3	72.9	68.1	63.8	58.0	49.8	(27)
MCD B			59.5	63.8	76.9	83.7	90.6	98.5	103.4	101.8	96.0	87.7	73.2	59.5	(28)	
2%		WB	44.5	48.6	57.4	63.5	67.3	70.9	70.7	69.7	65.4	60.1	54.2	45.5	(29)	
		MCD B	52.2	58.6	70.5	81.6	90.3	96.2	100.4	98.6	93.7	80.4	65.6	54.9	(30)	
5%		WB	40.7	45.1	54.2	60.6	65.4	69.0	68.9	67.8	63.3	57.6	50.9	42.5	(31)	
		MCD B	46.8	53.6	67.3	78.5	88.4	95.4	98.4	98.1	90.0	76.3	61.4	50.2	(32)	
10%		WB	37.6	41.9	51.4	58.3	63.4	67.2	67.4	66.2	61.2	55.4	48.0	39.6	(33)	
		MCD B	42.5	49.3	63.5	75.1	86.0	94.5	97.2	96.4	86.4	72.6	56.9	45.9	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	13.0	15.9	19.2	20.8	22.3	22.9	22.4	23.1	23.2	21.5	16.4	13.3	(35)
MCD BR			18.4	22.0	25.8	25.3	25.4	25.1	24.6	25.6	26.2	25.7	21.9	19.4	(36)	
MCWBR			12.8	14.2	15.1	12.7	12.2	11.3	9.9	11.1	13.1	14.2	13.5	13.1	(37)	
5% WB		MCD BR	17.4	21.0	24.5	23.8	23.6	24.0	23.1	23.9	25.5	24.2	20.1	18.3	(38)	
		MCWBR	12.7	14.1	15.5	13.2	12.4	12.2	11.2	11.9	13.5	14.1	12.8	12.9	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.371	0.407	0.464	0.506	0.496	0.478	0.450	0.423	0.396	0.423	0.405	0.362	(40)	
taud		2.103	2.025	1.910	1.851	1.910	1.972	2.068	2.122	2.153	2.023	2.045	2.124	(41)		
Ebn at Noon		233	244	244	244	251	255	261	265	263	234	216	223	(42)		
Edh at Noon		34	43	55	62	60	57	51	47	42	43	36	31	(43)		
(44)	All-Sky Solar Radiation	RadAvg	563	871	1302	1773	2191	2457	2423	2206	1780	1196	727	488	(44)	
(45)		RadStd	65	104	105	150	130	79	87	56	55	65	73	61	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	-2.14	-3.49	N/A	N/A	N/A	N/A
(47)	Regional (4 neighbors)	N/A	N/A	N/A	+0.76	N/A	N/A	N/A	N/A	+189	+130

Nomenclature: See separate page