

TASHKENT INTL, Uzbekistan

WMO: 384570

Lat: **41.258N**Lon: **69.281E**Elev: **1417**StdP: **13.96**Time Zone: **5.00 (E05)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	14.2	19.1	7.9	8.7	20.9	11.8	10.6	27.9	14.1	46.7	12.3	45.2	3.6	70	0.439

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	28.1	102.2	67.5	100.0	66.8	97.1	66.1	72.2	93.1	70.2	91.9	68.5	90.6	6.3	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
64.9	97.1	83.6	62.8	90.0	80.5	60.8	83.8	78.5	36.9	93.4	35.0	92.1	33.7	90.4	83.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.2	12.0	10.4	11.5	107.2	6.6	2.2	6.8	108.8	2.9	110.1	-0.8	111.3	-5.5	112.9
			10.5	74.6	6.3	3.4	5.9	77.0	2.2	79.0	-1.3	80.9	-5.9	83.4
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	60.4	36.9	40.0	51.7	61.3	71.1	79.8	83.1	80.8	71.2	59.8	48.2	39.1
	DBStd	17.98	8.85	9.98	9.22	8.27	6.42	5.08	4.29	4.86	6.42	8.22	8.92	8.65
	HDD50	1313	411	297	91	14	0	0	0	0	19	133	348	
	HDD65	3700	871	699	420	161	20	0	0	19	199	509	802	
	CDD50	5096	5	18	144	352	655	893	1025	954	638	322	79	11
	CDD65	2011	0	0	8	50	210	444	560	490	207	37	5	0
	CDH74	27267	0	1	85	570	2530	6136	8210	6685	2548	465	37	0
	CDH80	14818	0	0	17	170	1083	3446	4930	3872	1165	128	7	0
Wind	WSAvg	4.9	4.2	4.7	5.3	5.3	5.5	5.8	5.5	5.2	4.9	4.2	3.9	4.0
Precipitation	PrecAvg	17.1	2.1	2.1	2.8	2.4	1.5	0.4	0.1	0.0	0.2	1.2	2.0	2.2
	PrecMax	37.7	5.7	7.2	7.3	7.0	3.9	1.7	1.6	0.4	4.2	4.4	12.5	5.4
	PrecMin	11.1	0.3	0.0	0.6	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.2	0.2
	PrecStd	4.7	1.0	1.3	1.4	1.3	1.0	0.4	0.3	0.1	0.6	1.1	1.9	1.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	62.9	69.7	82.3	89.4	96.9	103.9	106.1	103.7	98.0	89.6	79.5	65.8
		MCWB	47.3	51.3	56.9	62.7	64.8	66.5	69.2	68.1	64.9	61.6	57.9	48.6
	2%	DB	57.1	62.6	75.4	84.6	93.0	100.4	102.6	100.6	93.6	83.0	71.1	60.4
		MCWB	45.1	47.9	54.9	61.1	63.9	65.9	68.0	67.4	63.5	58.6	54.2	46.8
	5%	DB	52.8	57.8	70.6	80.7	89.7	97.2	100.3	98.6	90.5	79.1	66.0	55.7
		MCWB	43.3	45.9	53.1	60.0	63.5	65.8	67.2	66.6	62.6	57.4	52.0	45.2
	10%	DB	48.6	53.7	66.2	76.6	86.2	94.8	97.3	96.0	87.4	75.1	61.5	51.4
		MCWB	41.5	44.1	51.8	58.5	62.7	65.5	66.5	65.9	61.4	55.9	49.9	43.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.1	53.5	59.3	66.2	69.7	73.6	76.1	74.3	68.0	62.9	59.1	51.1
		MCDB	58.0	65.0	73.5	81.9	88.4	93.4	95.8	95.4	90.3	82.7	74.7	60.7
	2%	WB	46.6	50.2	56.8	63.8	67.0	71.1	72.6	71.3	65.9	60.4	56.4	48.5
		MCDB	54.7	58.8	70.9	78.6	85.4	91.1	93.8	93.3	88.7	78.4	67.5	56.4
	5%	WB	44.5	47.8	54.9	62.0	65.4	68.9	70.2	69.3	64.0	58.8	53.6	46.2
		MCDB	50.3	55.3	66.7	75.7	83.9	89.4	93.0	91.6	86.5	75.5	63.1	53.8
	10%	WB	42.3	45.3	53.1	60.1	63.9	67.2	68.5	67.6	62.2	57.1	51.1	43.9
		MCDB	47.9	52.1	63.9	72.9	81.6	88.6	91.7	90.2	83.9	71.5	59.7	50.2
Mean Daily Temperature Range	5% DB	MDBR	15.2	16.8	18.9	21.5	25.0	27.2	28.1	28.8	27.9	23.4	18.3	15.7
		MCDBR	21.1	22.5	25.1	28.3	29.6	30.4	31.2	31.5	31.4	29.2	24.4	22.5
		MCWBR	12.4	12.7	12.2	12.4	10.5	10.1	10.4	10.5	11.5	12.1	11.9	13.1
	5% WB	MCDBR	17.6	19.3	21.7	24.1	25.6	26.9	27.8	29.2	29.5	25.5	20.6	19.6
		MCWBR	11.0	11.9	11.5	11.6	10.6	11.1	11.5	11.3	12.1	11.5	10.8	12.0
Clear-Sky Solar Irradiance	taub	0.376	0.419	0.479	0.488	0.467	0.458	0.437	0.415	0.410	0.466	0.441	0.378	
	taud	2.108	2.013	1.909	1.933	2.040	2.072	2.136	2.187	2.135	1.926	1.971	2.086	
	Ebn at Noon	233	240	240	250	259	261	266	268	259	220	204	218	
	Edh at Noon	35	44	55	58	53	51	48	44	43	48	40	33	
All-Sky Solar Radiation	RadAvg	569	834	1203	1657	2111	2403	2402	2155	1708	1103	670	484	
	RadStd	67	102	100	170	119	87	81	76	54	95	88	57	