

PSKEM, Uzbekistan

WMO: 384620

Lat: 41.9096N

Lon: 70.3671E

Elev: 4117

StdP: 12.64

Time Zone: 5.00 (E05)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	6.8	11.4	-4.5	5.0	10.4	-0.2	6.3	14.6	18.3	25.7	16.6	25.6	0.3	N/A	0.472

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	26.9	91.4	60.7	88.6	59.3	86.0	58.3	63.2	83.7	61.8	82.3	60.5	80.6	8.9	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
57.0	80.8	68.0	55.0	75.1	66.1	53.4	70.6	65.3	30.8	84.0	29.6	82.2	28.7	80.6	76.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.3	15.8	12.9	DB	1.4	97.7	4.9	2.9	-2.1	99.9	-5.0	101.6	-7.7	103.2	-11.2	105.4	(4)
(5)			WB	0.6	68.3	4.6	2.9	-2.6	70.3	-5.3	72.0	-7.9	73.6	-11.2	75.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	50.6	28.0	30.1	40.3	51.6	59.0	66.3	71.7	71.3	63.1	51.7	41.2	31.2	(6)
(7)		DBStd	16.78	7.11	7.74	7.39	7.46	5.44	5.13	4.81	5.14	6.25	7.65	7.95	7.13	(7)
(8)		HDD50	2556	682	556	310	69	5	0	0	0	2	72	278	582	(8)
(9)		HDD65	5834	1147	976	765	404	196	45	6	12	107	415	714	1047	(9)
(10)		CDD50	2764	0	0	10	116	284	488	673	659	395	125	14	0	(10)
(11)		CDD65	563	0	0	0	1	9	83	213	206	49	2	0	0	(11)
(12)		CDH74	7249	0	0	1	32	178	1072	2650	2563	708	45	0	0	(12)
(13)		CDH80	2646	0	0	0	2	18	295	1091	1059	177	4	0	0	(13)
(14)	Wind	WSAvg	2.1	0.8	1.1	1.5	2.1	1.9	3.1	3.9	4.0	2.5	1.3	1.0	(14)	
(15)	Precipitation	PrecAvg	32.9	3.3	4.1	4.1	4.0	3.2	1.7	1.1	0.5	0.7	2.6	3.8	3.7	(15)
(16)		PrecMax	50.4	6.3	9.4	6.5	9.1	7.1	5.0	3.5	2.2	2.8	8.7	11.9	9.5	(16)
(17)		PrecMin	18.2	0.9	0.6	1.1	0.7	0.4	0.1	0.0	0.0	0.0	0.1	0.5	0.7	(17)
(18)		PrecStd	6.9	1.5	2.1	1.7	2.0	1.7	1.1	0.9	0.5	0.7	2.2	3.1	1.9	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	47.6	51.7	66.1	78.0	82.5	90.4	96.0	95.2	88.4	79.3	66.1	51.1	(19)
MCWB			37.6	40.3	47.2	54.0	58.2	61.0	63.0	62.1	57.3	52.0	46.9	39.6	(20)	
2%		DB	42.9	46.7	60.0	73.4	78.5	86.2	92.0	91.3	84.6	73.6	60.8	46.3	(21)	
		MCWB	34.9	37.4	44.9	52.5	57.1	59.7	61.4	60.0	55.5	50.3	44.3	37.1	(22)	
5%		DB	39.7	43.3	55.6	69.2	75.5	83.4	89.0	88.8	81.7	69.3	56.3	43.2	(23)	
		MCWB	33.0	35.5	43.2	50.5	56.1	59.1	60.1	58.8	54.6	49.1	42.5	35.4	(24)	
10%		DB	37.0	40.2	51.3	65.0	72.3	80.3	86.0	86.1	78.1	65.2	52.4	40.5	(25)	
		MCWB	32.1	33.8	41.1	49.1	55.1	58.6	58.8	57.8	53.0	47.7	41.1	34.2	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	39.0	42.1	49.2	57.6	61.5	64.5	66.6	64.0	59.5	54.7	50.3	41.9	(27)
MCD B			45.1	50.3	58.9	69.4	75.8	79.6	85.0	87.5	81.1	69.8	60.5	46.8	(28)	
2%		WB	36.3	38.8	46.6	54.8	59.0	62.7	63.7	61.9	57.3	52.4	47.3	39.3	(29)	
		MCD B	40.5	44.6	57.4	67.6	73.8	80.1	85.9	84.7	79.0	67.2	55.2	43.7	(30)	
5%		WB	34.6	36.6	44.5	52.5	57.5	61.2	62.0	60.6	55.7	50.8	44.7	36.9	(31)	
		MCD B	38.0	41.5	53.5	64.9	72.2	78.3	84.1	83.5	76.9	65.0	53.1	41.5	(32)	
10%		WB	32.9	34.8	42.3	50.5	56.2	59.9	60.7	59.3	54.3	49.2	42.3	34.8	(33)	
		MCD B	36.2	39.1	50.1	62.0	69.8	76.6	82.0	81.7	74.8	62.3	50.1	39.3	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	14.5	15.4	16.2	19.5	22.3	25.0	26.9	27.3	26.1	21.8	16.6	13.8	(35)
MCDBR			16.3	18.3	20.9	26.5	27.3	29.2	30.0	30.4	30.1	27.7	22.6	16.6	(36)	
MCWBR			11.4	12.0	11.3	12.2	12.7	11.3	9.8	9.9	10.5	11.4	11.7	10.7	(37)	
5% WB		MCD BR	12.8	15.0	18.3	22.2	24.0	25.4	27.1	28.0	26.9	23.2	18.2	13.4	(38)	
		MCWBR	9.5	10.5	11.2	11.6	12.5	12.3	10.9	10.2	10.6	10.7	10.5	9.6	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.327	0.373	0.461	0.484	0.465	0.450	0.432	0.403	0.387	0.431	0.390	0.318	(40)	
taud		2.016	1.899	1.771	1.846	1.964	2.040	2.101	2.183	2.166	1.951	1.965	2.059	(41)		
Ebn at Noon		246	252	243	250	259	263	266	271	266	230	218	238	(42)		
Edh at Noon		36	49	63	62	57	53	49	44	42	46	39	32	(43)		
(44)	All-Sky Solar Radiation	RadAvg	625	900	1211	1552	1979	2284	2341	2135	1705	1032	623	495	(44)	
(45)		RadStd	74	116	126	183	146	127	120	102	89	147	101	62	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (9 neighbors)			N/A	N/A	N/A	+1.03	-0.79	-1.31	N/A	N/A	+173
											+126

Nomenclature: See separate page