

NUROTA, Uzbekistan

WMO: 385650

Lat: 40.550N

Lon: 65.683E

Elev: 1588

StdP: 13.87

Time Zone: 5.00 (E05)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	7.5	13.2	3.0	6.8	8.9	8.3	8.9	15.7	24.5	47.0	20.7	47.8	1.0	30	0.431

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	26.7	101.7	70.0	99.0	68.7	96.4	67.7	71.6	98.6	70.1	96.2	68.8	94.0	4.6	30

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
61.8	87.6	84.1	60.0	81.8	83.1	58.3	77.0	82.6	36.4	98.3	35.0	96.4	33.9	94.4	78.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 17.5	14.3	11.8	DB	3.2	107.2	7.1	2.6	-1.9	109.1	-6.0	110.7	-10.0	112.2	-15.2	114.1	(4)
(5)			WB	2.8	74.1	7.0	1.9	-2.3	75.5	-6.4	76.6	-10.3	77.7	-15.4	79.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	58.1	34.5	36.8	48.5	59.1	70.0	78.6	81.8	79.0	68.5	56.6	45.2	36.9		
	DBStd	18.80	10.77	11.44	9.82	8.71	6.61	5.01	4.51	5.07	6.51	8.40	10.11	10.35		
	HDD50	1707	488	387	148	23	1	0	0	0	0	34	205	421		
	HDD65	4281	944	791	517	212	28	0	0	1	37	280	599	872		
	CDD50	4657	9	16	101	297	621	859	987	899	555	238	60	15		
	CDD65	1756	0	0	5	37	183	409	522	435	142	19	4	0		
	CDH74	24446	0	3	76	480	2297	5764	7626	5921	1882	355	41	1		
	CDH80	13185	0	0	11	139	961	3224	4566	3379	801	98	6	0		
(14) Wind	WSAvg	3.3	3.6	3.9	3.8	3.8	3.6	3.4	3.5	3.1	2.7	2.4	2.9	3.4		
(15) Precipitation	PrecAvg	9.3	1.1	1.5	1.7	1.3	0.8	0.2	0.1	0.1	0.1	0.3	1.1	1.1		
	PrecMax	13.9	2.2	3.1	3.2	4.4	3.3	1.1	0.7	0.6	0.3	1.0	2.7	2.9		
	PrecMin	5.4	0.4	0.4	0.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1		
	PrecStd	2.5	0.4	0.7	0.8	1.0	0.7	0.2	0.2	0.2	0.1	0.3	0.8	0.7		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	67.2	70.3	80.7	89.5	96.6	103.4	107.0	103.6	96.9	88.1	79.7	68.6		
		MCWB	49.2	53.2	59.3	65.4	67.5	71.8	72.4	70.1	68.2	63.7	59.8	52.0		
	2%	DB	60.0	64.0	75.5	83.9	92.7	99.6	102.5	100.5	92.4	82.5	71.9	63.5		
		MCWB	47.7	50.2	57.5	62.8	66.4	69.8	70.1	69.3	65.9	60.9	54.9	49.9		
	5%	DB	55.1	59.0	70.3	79.5	89.1	96.8	99.5	97.6	88.7	77.7	66.9	59.0		
		MCWB	45.2	47.5	55.3	60.6	64.8	68.2	68.9	67.6	64.0	58.8	52.8	47.7		
	10%	DB	50.6	53.7	65.2	75.3	85.6	94.0	96.6	94.8	84.6	73.0	61.2	53.3		
		MCWB	43.2	45.4	52.6	58.5	63.7	66.9	68.0	66.7	62.3	56.6	50.2	44.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	51.3	54.9	61.4	66.6	70.1	73.5	74.1	72.3	69.5	64.9	60.0	54.5		
		MCDB	60.8	66.2	77.3	85.2	91.7	100.6	101.1	99.8	93.9	86.7	77.5	65.9		
	2%	WB	48.5	51.0	58.2	64.0	67.5	71.0	71.8	70.4	66.8	61.4	56.5	50.6		
		MCDB	59.1	62.0	72.9	80.6	88.6	96.7	99.2	98.1	90.4	80.5	68.6	61.8		
	5%	WB	45.9	48.4	55.9	61.7	65.8	69.3	70.2	68.9	64.7	59.2	53.5	48.1		
		MCDB	54.6	57.7	68.5	76.6	86.3	94.1	96.8	95.4	87.1	76.3	65.5	58.6		
	10%	WB	43.2	45.5	53.2	59.6	64.3	67.8	68.8	67.4	62.5	57.0	50.8	45.0		
		MCDB	50.3	53.4	64.5	73.3	84.0	91.6	94.6	92.8	83.4	72.3	60.7	52.8		
(35) Mean Daily Temperature Range	5% DB	MDBR	15.8	16.8	19.0	21.4	24.7	26.9	26.7	27.8	27.1	24.9	19.2	16.5		
		MCDBR	22.2	23.4	26.2	28.3	30.1	31.2	31.4	32.0	32.6	31.3	25.6	24.7		
		MCWBR	13.5	12.9	13.2	12.4	12.6	12.6	12.3	12.1	14.2	15.3	13.3	14.6		
	5% WB	MCDBR	20.5	21.7	24.2	25.4	27.3	29.8	30.1	30.9	31.3	29.6	23.1	23.2		
		MCWBR	13.3	12.9	13.0	11.9	12.5	13.1	12.8	12.9	14.5	15.0	13.0	14.7		
(40) Clear-Sky Solar Irradiance	taub		0.361	0.400	0.464	0.493	0.485	0.471	0.441	0.418	0.400	0.438	0.417	0.360		
	taud		2.147	2.049	1.929	1.899	1.946	1.992	2.081	2.130	2.132	1.976	2.016	2.136		
	Ebn at Noon		242	249	246	249	254	258	265	268	264	231	216	230		
	Edh at Noon		34	43	54	60	58	56	51	47	44	46	38	31		
(44) All-Sky Solar Radiation	RadAvg		573	844	1251	1745	2173	2465	2462	2220	1783	1209	727	521		
	RadStd		69	95	100	154	115	89	73	52	55	69	80	57		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+155	+113
Regional (6 neighbors)	N/A	N/A	N/A	+0.67	N/A	N/A	N/A	N/A	N/A	+95

Nomenclature: See separate page