

NUROTA, Uzbekistan

WMO: 385650

Lat: 40.550N

Lon: 65.683E

Elev: 484

StdP: 95.64

Time Zone: 5.00 (E05)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-13.6	-10.4	-16.1	1.0	-12.8	-13.2	1.3	-9.0	10.9	8.4	9.3	8.8	0.4	30	0.431

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.9	38.7	21.1	37.2	20.4	35.8	19.8	22.0	37.0	21.1	35.7	20.4	34.4	2.1	30

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.6	12.5	28.9	15.5	11.7	28.4	14.6	11.0	28.1	66.7	36.8	63.5	35.8	60.9	34.7	25.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.8	6.4	5.3	DB	-16.0	41.8	3.9	1.5	-18.8	42.9	-21.1	43.7	-23.3	44.5	-26.2	45.6	(4)
(5)			WB	-16.2	23.4	3.9	1.1	-19.0	24.1	-21.3	24.8	-23.5	25.4	-26.3	26.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	14.5	1.4	2.7	9.2	15.1	21.1	25.9	27.7	26.1	20.3	13.7	7.3	2.7		
	DBStd	10.45	5.98	6.35	5.46	4.84	3.67	2.78	2.51	2.81	3.62	4.67	5.61	5.75		
	HDD10.0	948	271	215	82	13	1	0	0	0	0	19	114	234		
	HDD18.3	2378	524	439	287	118	16	0	0	1	21	156	333	484		
	CDD10.0	2587	5	9	56	165	345	477	548	499	308	132	33	8		
	CDD18.3	976	0	0	3	21	102	227	290	242	79	11	2	0		
	CDH23.3	13581	0	2	42	267	1276	3202	4237	3289	1046	197	23	1		
	CDH26.7	7325	0	0	6	77	534	1791	2537	1877	445	54	3	0		
(14) Wind	WSAvg	1.5	1.6	1.7	1.7	1.7	1.6	1.5	1.5	1.4	1.2	1.1	1.3	1.5		
(15) Precipitation	PrecAvg	237	27	38	44	33	20	6	2	2	2	8	27	28		
	PrecMax	353	55	80	82	112	83	27	17	14	8	26	68	73		
	PrecMin	138	9	11	12	1	0	0	0	0	0	0	1	2		
	PrecStd	63	11	19	20	25	18	6	4	4	3	7	20	19		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	19.5	21.3	27.0	31.9	35.9	39.7	41.7	39.8	36.1	31.2	26.5	20.3		
		MCWB	9.6	11.8	15.2	18.6	19.7	22.1	22.4	21.2	20.1	17.6	15.4	11.1		
	2%	DB	15.6	17.8	24.2	28.8	33.7	37.6	39.2	38.1	33.6	28.1	22.2	17.5		
		MCWB	8.7	10.1	14.2	17.1	19.1	21.0	21.2	20.7	18.8	16.1	12.7	9.9		
	5%	DB	12.8	15.0	21.3	26.4	31.7	36.0	37.5	36.4	31.5	25.4	19.4	15.0		
		MCWB	7.3	8.6	12.9	15.9	18.2	20.1	20.5	19.8	17.8	14.9	11.6	8.7		
	10%	DB	10.3	12.1	18.5	24.0	29.8	34.4	35.9	34.9	29.2	22.8	16.2	11.8		
		MCWB	6.2	7.4	11.5	14.7	17.6	19.4	20.0	19.3	16.8	13.7	10.1	7.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.7	12.7	16.3	19.2	21.2	23.1	23.4	22.4	20.8	18.3	15.6	12.5		
		MCDB	16.0	19.0	25.1	29.6	33.2	38.1	38.4	37.7	34.4	30.4	25.3	18.8		
	2%	WB	9.2	10.6	14.6	17.8	19.7	21.6	22.1	21.3	19.3	16.4	13.6	10.3		
		MCDB	15.1	16.6	22.7	27.0	31.5	36.0	37.3	36.7	32.5	27.0	20.3	16.6		
	5%	WB	7.7	9.1	13.3	16.5	18.8	20.7	21.2	20.5	18.2	15.1	12.0	9.0		
		MCDB	12.5	14.3	20.3	24.8	30.2	34.5	36.0	35.2	30.6	24.6	18.6	14.8		
	10%	WB	6.2	7.5	11.8	15.4	17.9	19.9	20.5	19.7	17.0	13.9	10.5	7.2		
		MCDB	10.2	11.9	18.0	22.9	28.9	33.1	34.8	33.8	28.6	22.4	15.9	11.6		
(35) Mean Daily Temperature Range	5% DB	MDBR	8.8	9.3	10.6	11.9	13.7	14.9	14.9	15.4	15.1	13.8	10.7	9.2		
		MCDBR	12.4	13.0	14.5	15.7	16.7	17.3	17.4	17.8	18.1	17.4	14.2	13.7		
	5% WB	MCWBR	7.5	7.2	7.4	6.9	7.0	7.0	6.8	6.7	7.9	8.5	7.4	8.1		
		MCWBR	11.4	12.0	13.4	14.1	15.2	16.5	16.7	17.2	17.4	16.5	12.8	12.9		
(40) Clear-Sky Solar Irradiance	taub		0.361	0.400	0.464	0.493	0.485	0.471	0.441	0.418	0.400	0.438	0.417	0.360		
	taud		2.147	2.049	1.929	1.899	1.946	1.992	2.081	2.130	2.132	1.976	2.016	2.136		
	Ebn at Noon		763	785	775	785	802	813	834	844	831	729	680	724		
	Edh at Noon		106	136	171	189	184	176	160	148	138	144	121	99		
(44) All-Sky Solar Radiation	RadAvg		1.81	2.66	3.94	5.50	6.85	7.77	7.76	7.00	5.62	3.81	2.29	1.64		
	RadStd		0.22	0.30	0.32	0.49	0.36	0.28	0.23	0.16	0.17	0.22	0.25	0.18		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+86	+63
(47) Regional (6 neighbors)		N/A	N/A	N/A	+0.37	N/A	N/A	N/A	N/A	N/A	+53

Nomenclature: See separate page