

NAVOI, Uzbekistan

WMO: 385670

Lat: 40.133N

Lon: 65.350E

Elev: 1115

StdP: 14.11

Time Zone: 5.00 (E05)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	13.6	19.3	5.4	7.6	19.4	10.6	9.8	28.0	23.6	49.1	21.4	47.6	6.0	130	0.541

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	27.1	105.6	66.1	102.5	65.0	100.4	64.2	67.3	99.3	66.2	97.6	65.2	95.6	12.4	20

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
58.9	77.4	68.5	57.1	72.4	68.6	55.2	67.6	69.5	32.1	99.7	31.3	98.3	30.6	96.1	71.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 23.0	20.4	18.1	7.3	108.9	6.5	2.3	2.6	110.6	-1.2	111.9	-4.9	113.2	-9.7	114.8		
(5)			6.6	69.8	6.5	1.0	1.8	70.6	-2.0	71.1	-5.6	71.7	-10.4	72.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	61.0	38.7	39.5	51.4	61.3	73.9	82.2	85.9	81.5	71.6	59.1	46.1	38.7		
	DBStd	18.81	8.01	10.72	9.32	7.72	5.47	5.03	4.76	5.70	6.29	8.70	9.39	8.60		
	HDD50	1334	359	311	96	7	0	0	0	0	0	26	173	362		
	HDD65	3736	816	714	430	158	3	0	0	0	13	217	570	815		
	CDD50	5335	8	17	140	346	741	965	1114	977	648	309	57	13		
	CDD65	2261	0	0	9	48	279	515	649	512	210	35	4	0		
	CDH74	33742	0	6	106	669	3661	7810	10333	7688	2889	540	39	1		
	CDH80	19731	0	0	28	209	1768	4789	6703	4702	1361	162	9	0		
(14) Wind	WSAvg	8.5	8.6	8.8	9.4	9.0	8.8	8.8	9.9	8.3	7.7	7.2	7.2	8.0		
(15) Precipitation	PrecAvg	8.0	1.1	1.3	1.5	1.1	0.7	0.1	0.0	0.0	0.1	0.2	0.8	1.1		
	PrecMax	12.0	2.4	3.1	2.6	4.0	2.2	0.6	0.4	0.2	0.6	0.6	2.2	2.6		
	PrecMin	4.7	0.3	0.6	0.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.1		
	PrecStd	2.4	0.6	0.6	0.6	1.0	0.6	0.2	0.1	0.1	0.2	0.2	0.6	0.7		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	64.2	71.8	83.8	91.7	98.8	105.9	109.5	106.1	100.0	90.0	78.9	66.6		
		MCWB	48.0	52.7	56.8	61.0	62.8	65.7	67.2	66.5	63.1	59.6	56.9	48.0		
	2%	DB	59.2	62.6	76.6	86.0	96.4	102.6	106.2	103.8	95.1	84.3	70.1	61.1		
		MCWB	47.3	49.9	56.1	59.5	62.4	64.9	66.2	65.6	61.3	57.4	53.4	46.4		
	5%	DB	55.4	57.4	71.5	81.0	93.2	100.5	104.0	100.6	91.7	79.2	64.8	55.8		
		MCWB	45.0	47.0	54.3	57.8	61.4	64.2	65.8	64.1	60.6	56.2	50.5	44.9		
	10%	DB	51.7	53.6	66.6	77.2	89.8	98.2	100.8	98.3	88.0	75.5	60.8	51.8		
		MCWB	43.4	46.0	52.6	57.0	60.8	63.4	64.6	63.4	59.6	54.6	49.0	42.9		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	50.3	54.6	60.7	63.8	66.4	68.0	68.9	67.9	64.2	60.9	58.3	50.4		
		MCDB	58.5	67.8	73.0	80.0	85.6	98.5	102.5	100.8	92.1	84.4	72.2	60.7		
	2%	WB	48.7	51.9	58.0	62.0	64.7	66.6	67.5	66.7	62.6	59.1	54.8	48.0		
		MCDB	57.4	60.2	70.9	77.7	85.1	96.0	101.4	99.0	91.1	79.3	66.4	57.7		
	5%	WB	46.2	49.1	55.7	60.5	63.6	65.5	66.4	65.3	61.5	57.4	52.4	46.1		
		MCDB	53.5	55.5	68.3	75.9	84.2	94.4	100.5	96.9	89.4	76.0	63.4	54.9		
	10%	WB	44.2	46.6	53.8	58.9	62.6	64.6	65.3	64.1	60.1	55.7	49.7	43.8		
		MCDB	50.3	52.5	65.6	73.7	83.2	93.2	98.6	94.9	86.3	73.4	59.4	50.5		
(35) Mean Daily Temperature Range	5% DB	MDBR	16.7	17.6	20.5	22.8	26.1	27.5	27.1	28.8	28.9	25.9	20.8	17.4		
		MCDBR	22.8	23.5	26.1	29.2	31.6	30.6	30.6	31.3	32.7	30.6	26.8	23.0		
		MCWBR	13.2	12.8	11.2	11.1	10.3	10.2	11.1	11.6	12.6	12.9	13.4	12.7		
	5% WB	MCDBR	20.1	20.2	23.7	23.6	25.5	27.2	28.0	29.4	30.3	26.6	23.0	20.8		
		MCWBR	12.6	11.5	11.4	10.0	9.1	9.1	10.6	11.1	12.3	11.9	12.2	12.5		
(40) Clear-Sky Solar Irradiance	taub		0.373	0.413	0.481	0.508	0.502	0.490	0.457	0.431	0.414	0.455	0.432	0.373		
	taud		2.136	2.033	1.900	1.869	1.908	1.943	2.037	2.091	2.094	1.943	1.992	2.120		
	Ebn at Noon		239	246	241	245	250	253	260	264	259	227	212	226		
	Edh at Noon		35	44	56	62	61	59	53	49	46	48	40	33		
(44) All-Sky Solar Radiation	RadAvg		595	869	1271	1754	2178	2475	2458	2220	1789	1222	751	537		
	RadStd		63	92	96	151	104	80	64	49	53	67	75	56		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (7 neighbors)	N/A	N/A	N/A	+0.63	-0.94	-1.80	N/A	N/A	N/A	+115

Nomenclature: See separate page