

JIZZAKH, UzbekistanWMO: **385790**Lat: **40.117N**Lon: **67.833E**Elev: **1132**StdP: **14.10**Time Zone: **5.00 (E05)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	13.0	18.2	8.8	9.0	14.0	13.6	11.5	19.8	22.3	43.6	17.8	43.8	1.7	180	0.410

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	25.9	100.2	73.4	97.8	72.3	95.5	71.0	76.6	96.8	74.6	94.5	72.8	92.4	5.1	50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
69.7	113.7	93.3	67.5	105.2	89.0	65.6	98.6	86.7	41.1	96.6	39.0	94.6	37.3	92.3	82.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.6	12.0	9.6	10.7	104.7	7.2	1.7	5.6	106.0	1.4	107.0	-2.6	107.9	-7.8	109.2		
(5)			10.4	78.8	7.2	1.8	5.2	80.1	1.0	81.2	-3.0	82.2	-8.3	83.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	59.4	36.3	39.1	50.5	60.5	71.1	79.6	81.8	79.1	69.6	58.8	47.0	38.1
	DBStd	17.96	9.19	10.16	8.93	8.15	6.27	4.83	4.16	4.75	6.42	8.14	8.90	8.88
	HDD50	1425	432	318	105	16	0	0	0	0	0	22	155	377
	HDD65	3889	891	725	453	176	20	0	0	0	28	220	542	834
	CDD50	4862	5	14	120	332	654	887	987	903	589	296	66	9
	CDD65	1848	0	0	3	42	208	437	522	438	167	29	2	0
	CDH74	24036	0	1	48	426	2315	5887	7323	5625	1999	385	27	0
	CDH80	12626	0	0	4	118	950	3257	4269	3074	846	105	3	0
Wind	WSAvg	3.6	3.6	3.8	3.9	4.0	4.0	3.8	3.6	3.5	3.2	3.2	3.2	3.4
Precipitation	PrecAvg	15.2	1.9	1.9	2.7	2.6	1.3	0.3	0.2	0.0	0.2	1.1	1.3	1.8
	PrecMax	32.2	5.7	4.9	7.8	7.4	4.7	1.7	4.4	0.3	1.2	5.2	4.3	4.9
	PrecMin	9.9	0.3	0.1	0.4	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	4.3	1.1	1.1	1.7	1.6	1.1	0.4	0.7	0.0	0.3	1.3	1.1	1.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	63.6	67.4	79.1	89.5	96.0	102.7	104.1	101.5	95.9	88.4	78.4	65.3
		MCWB	50.0	52.8	59.7	65.3	70.1	73.6	76.6	74.2	69.6	64.1	58.9	49.8
	2%	DB	57.1	61.7	74.0	83.6	92.3	99.2	100.7	98.6	92.4	82.5	70.6	59.5
		MCWB	46.6	49.9	57.6	63.8	68.0	72.0	74.4	73.0	68.0	61.9	54.9	48.1
	5%	DB	53.0	57.2	69.1	78.9	89.1	96.6	98.0	96.1	88.8	78.3	65.4	55.4
		MCWB	44.9	47.9	55.5	61.9	67.0	70.9	73.3	71.6	66.0	59.5	52.9	46.0
	10%	DB	48.9	53.4	64.4	74.9	85.6	93.9	95.6	93.6	85.1	74.0	61.2	51.3
		MCWB	42.6	46.1	53.6	60.4	65.8	69.5	71.8	70.7	64.7	57.7	51.0	44.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	50.7	53.8	61.5	68.3	72.5	77.0	79.8	78.0	71.9	66.5	59.9	52.0
		MCDB	61.0	64.2	76.2	82.5	91.5	98.1	101.3	97.9	92.8	85.0	73.1	61.1
	2%	WB	47.7	51.3	58.5	65.7	70.1	74.5	77.6	75.4	69.7	62.9	56.4	49.1
		MCDB	55.7	59.9	71.3	78.6	89.0	96.0	98.0	95.2	88.7	80.3	67.1	57.5
	5%	WB	45.2	48.6	56.3	63.5	68.2	72.6	75.4	73.5	67.5	60.5	54.1	46.6
		MCDB	51.8	55.6	67.2	76.3	85.8	93.3	95.1	92.6	85.7	75.6	63.4	54.3
	10%	WB	42.9	46.4	54.1	61.6	66.5	70.9	73.5	71.8	65.5	58.5	51.9	44.5
		MCDB	48.5	52.7	63.4	73.0	83.2	91.0	92.8	90.8	82.7	71.8	59.8	50.7
Mean Daily Temperature Range	5% DB	MDBR	13.2	14.9	17.1	19.4	23.2	25.5	25.9	26.3	26.4	23.0	17.4	13.9
		MCDBR	20.4	21.8	24.9	26.4	28.7	29.6	29.2	29.4	30.6	29.3	25.0	22.4
		MCWBR	12.0	12.1	11.9	11.2	11.5	12.1	12.5	12.1	12.4	13.0	12.1	13.0
	5% WB	MCDBR	18.4	19.2	22.3	23.7	26.7	27.8	28.3	27.8	29.2	26.4	21.1	19.8
		MCWBR	11.3	11.4	11.5	11.2	11.9	13.0	13.7	13.4	13.5	12.4	10.9	12.0
Clear-Sky Solar Irradiance	taub	0.383	0.430	0.496	0.512	0.501	0.494	0.476	0.452	0.439	0.487	0.450	0.388	
	taud	2.106	1.996	1.876	1.878	1.947	1.965	2.012	2.060	2.038	1.878	1.949	2.071	
	Ebn at Noon	234	239	237	244	251	252	255	258	252	216	205	219	
	Edh at Noon	36	46	58	61	58	57	55	50	48	51	42	34	
All-Sky Solar Radiation	RadAvg	573	811	1177	1638	2094	2408	2409	2174	1761	1166	696	510	
	RadStd	71	111	111	111	174	119	80	86	78	57	97	95	68