

SYRDARYA, Uzbekistan

WMO: 385830

Lat: 40.817N

Lon: 68.683E

Elev: 263

StdP: 98.21

Time Zone: 5.00 (E05)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-12.4	-8.9	-13.8	1.2	-12.0	-10.4	1.6	-8.4	5.1	5.1	4.3	4.8	1.0	270	0.412

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.0	38.3	24.0	36.9	23.4	35.6	23.0	26.1	35.3	25.1	34.5	24.2	33.4	1.6	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.5	18.9	31.7	22.2	17.4	31.0	21.2	16.4	30.2	83.0	35.3	78.4	34.6	74.6	33.5	33.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 4.6	3.8	3.3	-13.9	41.0	5.1	1.0	-17.6	41.7	-20.5	42.4	-23.4	43.0	-27.1	43.7		
(5)			-13.8	27.4	4.8	2.3	-17.3	29.1	-20.1	30.4	-22.8	31.6	-26.3	33.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	14.9	1.1	3.3	10.3	16.2	21.9	26.5	27.7	26.1	20.8	14.5	7.6	2.1
	DBStd	10.28	4.95	5.46	4.72	4.38	3.38	2.55	2.22	2.59	3.35	4.24	4.81	4.56
	HDD10.0	886	275	192	55	7	0	0	0	0	0	12	99	246
	HDD18.3	2277	533	422	251	89	10	0	0	1	15	131	323	503
	CDD10.0	2671	0	3	64	192	368	494	548	498	323	151	27	1
	CDD18.3	1020	0	0	1	24	119	244	290	241	88	11	1	0
	CDH23.3	13427	0	0	23	278	1408	3319	4009	3044	1149	188	8	0
	CDH26.7	7213	0	0	2	79	607	1895	2376	1712	496	46	1	0
Wind	WSAvg	1.5	1.4	1.6	1.7	1.6	1.6	1.6	1.5	1.4	1.3	1.3	1.3	1.4
Precipitation	PrecAvg	317	41	47	53	40	27	8	2	1	3	17	34	45
	PrecMax	509	75	108	117	74	72	41	11	8	21	75	134	129
	PrecMin	160	12	0	13	7	0	0	0	0	0	0	0	5
	PrecStd	73	19	26	24	22	18	10	3	2	5	18	30	27
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.8	18.8	26.4	31.8	36.0	39.7	40.4	38.9	35.5	30.8	24.3	15.3
		MCWB	8.6	11.8	16.2	19.7	22.0	24.6	25.1	24.1	22.1	19.3	15.3	9.8
	2%	DB	11.0	15.2	23.1	29.0	33.8	37.8	38.5	37.3	33.5	27.7	20.3	12.5
		MCWB	7.3	9.7	14.9	18.8	20.9	23.5	24.3	23.6	20.8	17.3	13.6	8.2
	5%	DB	9.2	12.7	20.3	26.6	32.1	36.3	37.1	35.9	31.6	25.3	17.3	10.3
		MCWB	6.3	8.7	13.6	17.7	20.4	23.1	23.8	23.1	20.0	15.8	12.1	7.3
	10%	DB	7.3	10.6	17.9	24.2	30.2	34.8	35.7	34.4	29.7	23.0	15.0	8.4
		MCWB	5.2	7.6	12.5	16.6	19.8	22.4	23.3	22.6	18.9	14.8	10.8	6.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.2	12.4	17.6	21.7	23.6	27.8	28.8	26.3	24.4	19.7	16.5	10.5
		MCDB	12.5	17.2	23.3	28.7	33.4	36.5	36.9	36.0	32.6	29.0	22.0	13.7
	2%	WB	7.8	10.5	15.6	20.0	22.4	25.7	26.6	25.4	22.0	18.0	14.4	8.9
		MCDB	10.3	14.2	21.4	26.1	31.2	34.8	35.4	34.9	31.0	26.2	19.1	11.5
	5%	WB	6.6	9.1	14.2	18.7	21.3	24.5	25.3	24.4	20.7	16.6	12.8	7.5
		MCDB	8.7	12.1	19.2	24.5	29.7	33.9	34.5	33.7	29.9	23.6	16.6	10.0
	10%	WB	5.4	7.9	13.0	17.4	20.4	23.4	24.3	23.5	19.5	15.4	11.3	6.2
		MCDB	7.2	10.4	17.3	22.9	28.3	32.6	33.6	32.5	28.3	21.7	14.5	8.2
Mean Daily Temperature Range	5% DB	MDBR	7.2	8.6	10.2	11.6	13.9	15.5	16.0	16.4	16.4	13.8	10.3	7.3
		MCDBR	9.9	12.3	14.4	15.8	16.6	17.9	17.7	17.8	18.4	17.3	13.9	10.9
		MCWBR	6.7	7.3	7.2	6.6	6.1	6.8	6.7	6.7	7.3	7.9	7.6	7.1
	5% WB	MCDBR	9.1	10.6	12.5	13.9	15.4	16.9	16.7	17.2	17.8	15.8	12.3	10.1
		MCWBR	6.5	6.7	6.8	6.4	6.3	7.4	7.3	7.2	7.7	7.7	7.0	6.8
Clear-Sky Solar Irradiance	taub	0.404	0.448	0.504	0.511	0.491	0.484	0.462	0.441	0.435	0.497	0.474	0.412	
	taud	2.044	1.947	1.863	1.888	1.980	2.001	2.065	2.108	2.061	1.863	1.904	2.002	
	Ebn at Noon	702	729	736	769	797	801	816	822	794	666	610	648	
	Edh at Noon	118	151	183	191	178	175	162	151	148	162	136	114	
All-Sky Solar Radiation	RadAvg	1.74	2.57	3.80	5.27	6.72	7.65	7.60	6.79	5.43	3.55	2.15	1.54	
	RadStd	0.20	0.31	0.33	0.53	0.32	0.25	0.23	0.22	0.15	0.28	0.27	0.20	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
Station Only		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (11 neighbors)		+0.50	N/A	N/A	+0.32	-1.10	-1.38	N/A	N/A	+125	+83
		N/A	N/A	N/A	+0.52	N/A	N/A	N/A	N/A	+103	+77

Nomenclature: See separate page