

JALAL-ABAD, Kyrgyzstan

WMO: 386130

Lat: 40.9337N

Lon: 72.9696E

Elev: 765

StdP: 92.47

Time Zone: 6.00 (E06)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-11.3	-8.8	-16.5	1.0	-10.1	-13.5	1.3	-8.2	3.5	0.0	3.2	-0.5	1.5	20	0.391

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.1	36.1	19.9	34.8	19.4	33.5	19.0	21.2	33.3	20.4	32.4	19.7	31.5	1.3	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.1	13.4	27.1	16.1	12.6	26.5	15.2	11.9	26.0	65.4	33.4	62.4	32.4	60.0	31.6	24.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
3.8	3.2	2.6	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
			-13.5	38.5	4.4	1.0	-16.7	39.3	-19.3	39.9	-21.8	40.5	-25.0	41.2		
			-14.0	22.6	3.9	0.8	-16.8	23.2	-19.1	23.6	-21.3	24.1	-24.1	24.6		
				</												

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	14.3	-0.3	2.5	9.7	15.2	20.1	24.5	26.9	25.9	21.9	14.9	7.9	1.3	(6)
(7)		DBStd	10.14	4.22	4.73	4.47	4.18	2.96	2.63	2.19	2.41	3.06	4.13	4.25	3.93	(7)
(8)		HDD10.0	966	318	212	61	9	0	0	0	0	9	87	270		(8)
(9)		HDD18.3	2379	577	443	268	108	17	1	0	7	119	312	528		(9)
(10)		CDD10.0	2527	0	2	51	165	313	435	523	494	357	162	26	1	(10)
(11)		CDD18.3	899	0	0	1	14	71	186	265	236	114	13	1	0	(11)
(12)		CDH23.3	9989	0	0	8	168	729	2095	3181	2604	1076	125	3	0	(12)
(13)	CDH26.7	4692	0	0	0	38	235	997	1686	1304	408	23	1	0	(13)	
(14)	Wind	WSAvg	1.4	1.2	1.3	1.4	1.5	1.5	1.6	1.5	1.5	1.4	1.3	1.2	(14)	
(15)	Precipitation	PrecAvg	477	41	51	61	59	54	24	11	6	8	33	54	49	(15)
(16)		PrecMax	739	122	103	121	160	151	77	32	30	23	121	173	104	(16)
(17)		PrecMin	297	5	11	11	14	4	1	0	0	0	10	13		(17)
(18)		PrecStd	112	24	24	30	30	38	22	10	7	7	27	43	23	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.7	17.4	24.5	30.0	32.9	36.8	38.5	36.7	33.5	29.2	22.8	13.4	(19)
MCWB			6.5	9.1	13.0	16.8	18.0	19.5	21.2	20.3	18.0	15.4	12.4	7.3	(20)	
2%		DB	9.0	13.5	21.6	27.4	31.0	35.0	36.7	35.3	32.1	26.6	19.3	10.3	(21)	
		MCWB	4.9	7.7	12.1	16.1	17.6	19.0	20.5	19.6	17.8	14.7	10.7	5.9	(22)	
5%		DB	7.0	10.9	19.2	25.0	29.3	33.5	35.3	34.0	30.8	24.3	16.2	8.4	(23)	
		MCWB	3.8	6.4	11.2	14.9	17.2	18.6	19.8	19.3	17.4	13.9	9.5	4.7	(24)	
10%		DB	5.3	8.8	16.9	22.9	27.5	31.9	33.9	32.8	29.2	22.0	14.1	6.7	(25)	
		MCWB	2.7	5.2	10.3	14.0	16.6	18.0	19.4	18.9	16.5	12.7	8.6	3.7	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.1	9.8	14.0	18.8	20.2	21.2	22.7	22.0	19.6	16.7	13.2	8.2	(27)
MCDWB			10.8	15.8	22.0	26.6	29.4	33.9	34.8	33.7	31.1	26.5	20.8	11.9	(28)	
2%		WB	5.4	8.2	12.6	16.9	18.7	20.0	21.6	20.9	18.6	15.4	11.5	6.3	(29)	
		MCDWB	8.3	12.8	19.9	25.1	28.0	32.4	34.0	32.6	30.4	24.8	17.1	9.7	(30)	
5%		WB	4.1	6.7	11.6	15.7	17.8	19.2	20.7	20.2	17.8	14.4	10.2	5.1	(31)	
		MCDWB	6.6	10.5	18.1	23.4	27.1	31.1	33.0	31.9	29.4	22.8	15.3	8.0	(32)	
10%		WB	2.9	5.4	10.6	14.5	17.1	18.6	20.0	19.5	17.0	13.4	9.1	3.8	(33)	
		MCDWB	5.2	8.5	16.3	21.6	26.2	30.1	32.0	31.0	27.9	20.8	13.5	6.3	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	7.9	8.5	9.7	10.9	12.1	13.2	13.1	12.8	12.9	11.7	9.5	7.9	(35)
MCDBR			9.7	11.3	13.5	14.8	15.2	15.3	14.8	14.1	14.6	14.6	12.8	10.4	(36)	
MCWBR			6.6	7.0	6.9	7.0	6.4	5.5	5.7	5.6	6.4	6.7	6.7	6.7	(37)	
5% WB		MCDBR	8.8	10.6	12.1	13.2	13.5	14.0	13.9	13.3	13.8	13.2	11.6	9.7	(38)	
		MCWBR	6.2	6.8	6.6	7.1	6.5	5.6	5.9	5.8	6.5	6.5	6.3	6.6	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.351	0.400	0.475	0.499	0.484	0.485	0.468	0.434	0.426	0.458	0.416	0.350	(40)	
taud		2.160	2.048	1.900	1.882	1.976	1.997	2.045	2.140	2.092	1.932	2.002	2.157	(41)		
Ebn at Noon		772	783	762	778	802	801	810	828	803	705	676	734	(42)		
Edh at Noon		104	135	176	192	178	175	165	146	143	150	121	96	(43)		
(44)	All-Sky Solar Radiation	RadAvg	2.25	3.15	4.21	5.16	6.21	7.08	7.23	6.65	5.44	3.51	2.31	1.89	(44)	
(45)		RadStd	0.16	0.24	0.32	0.39	0.41	0.33	0.32	0.30	0.23	0.39	0.30	0.17	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (5 neighbors)	N/A	N/A	N/A	+0.53	N/A	N/A	N/A	N/A	+75	+64

Nomenclature: See separate page