

BUKHARA KOGON, Uzbekistan

WMO: 386830

Lat: 39.717N

Lon: 64.617E

Elev: 735

StdP: 14.31

Time Zone: 5.00 (E05)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.4	17.7	3.3	6.7	15.1	9.4	9.1	22.9	20.4	35.4	17.3	40.5	7.5	0	0.531

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	26.1	103.8	68.1	101.3	67.4	98.9	66.5	71.4	96.6	69.8	95.6	68.4	93.9	11.2	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
62.6	87.2	82.7	60.4	80.7	80.9	58.5	75.2	80.6	35.7	96.9	34.3	95.3	33.1	94.1	78.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
20.5	17.4	16.0	9.9	109.1	7.3	3.0	4.6	111.2	0.4	113.0	-3.7	114.6	-8.9	116.8		
			9.2	73.9	7.3	2.5	3.9	75.7	-0.4	77.2	-4.5	78.6	-9.8	80.4		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	61.0	36.0	39.8	51.3	63.1	74.1	82.5	85.3	82.2	71.8	59.6	46.9	37.8	(6)
(7)		DBStd	19.16	9.54	10.04	8.96	8.63	6.11	4.90	4.30	5.05	6.19	7.87	9.02	8.35	(7)
(8)		HDD50	1406	441	303	94	9	0	0	0	0	16	158	385	(8)	
(9)		HDD65	3782	900	707	430	134	9	0	0	15	200	545	842	(9)	
(10)		CDD50	5412	5	16	135	402	746	975	1095	999	653	313	66	7	(10)
(11)		CDD65	2316	0	0	6	77	290	526	630	534	218	32	3	0	(11)
(12)		CDH74	30885	0	0	100	918	3538	7452	9020	6898	2459	459	41	0	(12)
(13)		CDH80	17430	0	0	18	329	1716	4494	5595	4054	1098	119	7	0	(13)
(14)	Wind	WSAvg	8.2	7.1	8.0	8.2	8.5	8.5	9.1	10.0	9.6	8.7	6.9	6.3	7.0	(14)
(15)	Precipitation	PrecAvg	5.5	0.7	0.8	1.0	0.9	0.5	0.1	0.0	0.0	0.1	0.6	0.6	(15)	
(16)		PrecMax	8.3	1.7	1.9	2.0	2.2	2.3	0.4	0.2	0.1	0.3	0.2	1.7	1.4	(16)
(17)		PrecMin	2.7	0.2	0.3	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	(17)
(18)		PrecStd	1.7	0.4	0.4	0.6	0.6	0.6	0.1	0.0	0.0	0.1	0.1	0.4	0.5	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	64.7	69.7	82.9	94.1	99.8	105.7	108.2	105.3	98.1	88.9	79.8	65.6	(19)
(20)		MCWB	49.2	52.8	57.9	63.0	65.1	67.1	69.8	69.5	65.7	61.6	57.4	49.2	(20)	
(21)		2%	DB	58.1	63.5	76.6	88.1	96.0	102.6	104.6	101.9	93.5	83.2	71.1	59.6	(21)
(22)		MCWB	47.0	50.4	56.3	61.6	63.8	66.6	68.7	68.5	63.5	58.6	54.2	47.5	(22)	
(23)		5%	DB	53.2	58.7	71.5	83.3	92.7	100.1	101.9	99.3	90.3	79.0	65.8	54.6	(23)
(24)		MCWB	45.0	47.8	54.5	60.0	62.8	65.9	68.0	67.3	62.4	57.7	52.3	45.6	(24)	
(25)		10%	DB	48.6	54.3	66.5	79.3	89.3	97.4	99.1	96.5	86.5	75.2	61.5	50.2	(25)
(26)		MCWB	42.7	46.5	52.7	58.6	62.1	65.2	67.2	66.0	61.1	56.1	50.0	43.5	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	50.7	54.7	60.4	67.5	68.8	72.4	74.3	73.2	68.4	63.5	58.8	51.6	(27)
(28)		MCDWB	59.5	65.0	74.4	84.6	88.8	95.3	99.9	98.9	92.9	83.5	73.9	60.9	(28)	
(29)		2%	WB	47.7	51.7	58.2	64.1	66.7	69.8	71.7	71.0	65.5	60.6	56.0	48.5	(29)
(30)		MCDWB	56.2	61.1	71.8	80.2	87.0	95.6	97.6	96.6	88.9	79.0	68.6	57.5	(30)	
(31)		5%	WB	45.7	49.1	55.8	62.0	65.3	68.3	70.1	69.3	63.7	58.6	53.3	46.2	(31)
(32)		MCDWB	52.2	57.2	68.9	78.6	85.9	93.9	96.5	94.7	86.6	76.6	63.7	53.7	(32)	
(33)		10%	WB	43.1	46.6	53.7	60.1	63.9	66.8	68.6	67.6	62.0	56.8	50.9	43.9	(33)
(34)		MCDWB	48.5	53.3	65.4	75.2	84.5	91.9	94.9	92.9	84.4	73.3	59.9	50.1	(34)	
(35)	Mean Daily Temperature Range	MDBR	15.6	17.2	20.2	22.6	25.3	26.8	26.1	26.6	26.7	25.2	20.3	16.0	(35)	
(36)		5% DB	MCDBR	23.0	25.1	27.9	29.3	30.2	30.4	29.4	29.2	30.2	30.3	26.6	23.7	(36)
(37)		MCWBR	13.9	13.6	11.7	10.2	9.7	10.0	10.5	11.3	11.6	13.1	13.3	14.0	(37)	
(38)		5% WB	MCDBR	20.6	21.7	24.8	25.2	26.0	27.4	27.4	27.9	29.0	27.5	23.0	21.5	(38)
(39)		MCWBR	13.2	12.7	11.4	10.0	9.6	9.8	10.3	11.6	12.0	12.7	12.1	13.5	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.381	0.422	0.492	0.520	0.516	0.509	0.474	0.444	0.425	0.466	0.441	0.383	(40)	
(41)		taud	2.121	2.019	1.873	1.839	1.873	1.892	1.987	2.053	2.062	1.923	1.975	2.098	(41)	
(42)		Ebn at Noon	237	244	239	242	247	248	256	260	257	224	210	223	(42)	
(43)		Edh at Noon	35	45	58	64	63	62	56	51	47	49	41	34	(43)	
(44)	All-Sky Solar Radiation	RadAvg	624	921	1305	1764	2175	2465	2438	2225	1813	1252	788	556	(44)	
(45)		RadStd	56	91	102	145	95	72	52	46	48	66	74	61	(45)	

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65		
(46)	Station Only	N/A	N/A	N/A	N/A	-1.57	-2.32	N/A	N/A	N/A	+83	(46)
(47)	Regional (6 neighbors)	N/A	N/A	N/A	+0.58	N/A	-1.44	N/A	N/A	N/A	+108	(47)

Nomenclature: See separate page