

DEHAVZ, Tajikistan

WMO: 387340

Lat: 39.450N

Lon: 70.200E

Elev: 8402

StdP: 10.75

Time Zone: 5.00 (E05)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	0.2	3.6	-11.3	4.1	1.4	-7.4	5.1	5.2	23.0	22.7	19.0	21.2	5.7	90	0.662

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	22.5	76.7	59.8	74.1	58.5	71.4	56.6	61.0	75.4	59.0	72.8	57.2	70.5	7.8	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
54.7	87.5	73.1	52.8	81.5	70.3	51.0	76.2	67.3	31.7	75.6	30.1	73.0	28.6	70.5	68.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.5	18.4	17.3	DB	-3.9	81.7	2.9	2.3	-6.0	83.4	-7.7	84.7	-9.3	86.1	-11.5	87.8
			WB	-5.1	64.5	2.8	1.7	-7.2	65.7	-8.8	66.7	-10.4	67.6	-12.5	68.9

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	40.5	19.1	21.1	31.4	41.9	49.0	54.2	59.1	58.1	53.0	43.0	32.2	22.8		
	DBStd	15.24	6.56	6.91	6.87	6.48	4.71	4.36	4.53	4.48	4.71	6.47	6.58	7.08		
	HDD50	4315	957	809	577	250	76	11	2	3	26	229	533	842		
	HDD65	8946	1422	1229	1042	694	497	323	188	218	361	682	983	1307		
	CDD50	851	0	0	0	6	44	138	283	253	115	12	0	0		
	CDD65	8	0	0	0	0	0	5	3	0	0	0	0	0		
	CDH74	253	0	0	0	0	0	14	141	93	5	0	0	0		
	CDH80	20	0	0	0	0	0	0	12	8	0	0	0	0		
	WSAvg	7.4	8.0	8.5	8.3	7.9	7.1	6.8	6.5	5.9	6.6	6.9	7.7	8.9		
	PrecAvg	20.7	2.0	2.5	3.0	2.7	2.3	1.3	1.1	0.6	0.4	1.2	1.7	2.0		
(15) Precipitation	PrecMax	25.9	4.1	4.3	4.7	4.3	4.7	2.4	2.8	1.1	0.7	3.1	4.4	3.8		
	PrecMin	15.3	0.9	1.0	1.1	1.1	1.2	0.6	0.4	0.3	0.0	0.4	0.6	0.7		
	PrecStd	2.9	0.8	0.7	0.9	0.8	0.9	0.5	0.5	0.2	0.2	0.6	0.9	0.8		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	36.2	42.4	51.6	65.9	70.4	75.9	81.3	80.5	74.6	66.3	53.9	42.9		
		MCWB	29.0	33.1	40.1	47.1	52.8	60.1	62.0	61.2	58.1	50.3	41.7	32.2		
	2%	DB	32.2	36.3	47.4	60.9	66.4	71.9	77.7	76.3	71.0	61.5	49.1	37.8		
		MCWB	26.7	30.6	37.3	46.2	51.2	56.9	60.3	59.5	55.1	47.1	38.4	30.2		
	5%	DB	29.9	33.6	44.3	57.1	63.5	68.9	74.7	73.6	68.0	57.9	45.5	34.9		
		MCWB	25.8	28.6	35.6	44.4	49.4	54.9	58.9	58.2	53.5	45.3	35.9	29.0		
	10%	DB	27.8	30.9	41.2	53.8	60.3	66.1	71.9	70.8	65.0	54.3	41.8	32.1		
		MCWB	24.0	26.7	33.6	42.6	47.8	52.8	57.3	56.6	51.3	43.2	33.7	27.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	30.0	35.3	40.7	49.7	54.7	61.3	63.8	62.9	59.0	50.9	42.6	33.8		
		MCDB	33.0	39.7	50.0	62.7	67.9	74.9	79.2	78.4	73.0	65.2	52.9	40.0		
	2%	WB	27.9	32.0	38.3	46.8	51.9	57.8	61.6	60.5	56.2	47.8	39.1	31.5		
		MCDB	31.3	35.8	45.6	58.4	64.9	70.8	76.4	74.9	69.9	60.1	47.7	35.9		
	5%	WB	26.0	29.3	36.4	45.0	50.0	55.7	59.4	58.5	54.0	45.7	36.6	29.8		
		MCDB	29.2	32.8	42.6	55.8	62.4	68.1	73.3	72.4	66.6	56.6	43.9	34.0		
	10%	WB	24.4	27.0	34.5	43.1	48.1	53.4	57.5	56.8	51.9	43.7	34.5	27.9		
		MCDB	27.5	30.6	40.0	52.6	59.3	64.9	70.7	70.0	64.1	53.1	40.8	32.0		
(35) Mean Daily Temperature Range	5% DB	MDBR	13.7	14.5	14.7	17.4	18.7	21.0	22.5	22.7	21.1	17.4	14.2	13.4		
		MCDBR	13.9	16.1	18.3	22.0	24.0	26.0	28.0	27.8	26.4	23.7	19.9	16.4		
		MCWBR	10.7	12.1	12.3	12.6	13.9	15.3	16.1	16.3	16.2	14.4	13.3	12.0		
		MCDBR	11.5	14.2	16.3	19.8	22.6	25.0	27.0	26.2	25.2	21.6	17.8	13.7		
	5% WB	MCWBR	9.1	10.8	11.4	12.0	13.4	15.1	16.2	15.8	16.0	13.3	12.0	10.4		
(40) Clear-Sky Solar Irradiance	taub		0.266	0.301	0.365	0.395	0.410	0.421	0.419	0.383	0.353	0.363	0.315	0.262		
	taud		2.253	2.144	2.041	2.046	2.069	2.057	2.079	2.204	2.248	2.119	2.201	2.303		
	Ebn at Noon		287	289	279	279	276	272	271	279	281	261	262	280		
	Edh at Noon		30	39	49	52	52	53	51	44	39	40	32	27		
(44) All-Sky Solar Radiation	RadAvg		722	980	1298	1571	1831	2154	2246	2155	1781	1138	711	600		
	RadStd		52	105	132	218	156	140	108	135	94	148	111	76		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (11 neighbors)	+0.68	N/A	N/A	+0.86	N/A	N/A	N/A	N/A	+205	+149

Nomenclature: See separate page