

KAZANARYK, Turkmenistan

WMO: 388060

Lat: 38.467N

Lon: 64.367E

Elev: 696

StdP: 14.33

Time Zone: 5.00 (E05)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	17.8	22.4	10.2	9.5	26.6	14.8	11.9	31.5	18.1	56.8	14.9	53.4	3.4	0	0.448

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	27.4	104.8	70.3	102.4	69.2	100.2	68.4	74.1	98.0	72.0	96.2	70.3	94.5	9.1	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.0	98.5	87.2	63.7	90.7	83.7	61.7	84.4	81.4	38.2	98.1	36.2	96.2	34.7	94.7	90.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.5	14.1	13.0	10.8	110.0	7.7	2.5	5.2	111.8	0.7	113.3	-3.6	114.7	-9.2	116.5
			10.1	79.3	7.9	3.7	4.4	82.0	-0.2	84.1	-4.6	86.2	-10.3	88.9
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	62.7	40.6	43.4	53.8	64.8	75.2	82.7	85.5	81.9	72.1	61.0	49.1	41.0	(6)
		DBStd	17.87	8.33	9.75	9.01	8.65	6.00	4.82	4.67	5.26	6.12	8.12	9.43	8.70	(7)
		HDD50	1041	309	221	65	5	0	0	0	0	13	126	302		(8)
		HDD65	3252	758	606	360	109	6	0	0	12	173	483	745		(9)
		CDD50	5670	16	35	183	450	781	981	1099	988	662	354	99	22	(10)
		CDD65	2406	0	0	13	104	321	531	634	523	225	49	6	0	(11)
		CDH74	35036	0	4	143	1176	4170	8044	9995	7645	3039	753	66	1	(12)
		CDH80	20575	0	0	26	431	2105	4998	6496	4775	1505	228	11	0	(13)
(14)	Wind	WSAvg	5.2	4.8	5.4	5.3	5.1	5.3	6.0	6.6	5.8	4.4	4.2	4.3	4.5	(14)
(15)	Precipitation	PrecAvg	6.7	1.0	1.3	1.3	0.9	0.4	0.0	0.0	0.0	0.0	0.2	0.7	0.9	(15)
(16)		PrecMax	11.7	2.8	3.8	3.0	4.3	1.9	0.3	0.4	0.2	0.2	1.1	1.9	3.0	(16)
(17)		PrecMin	3.9	0.2	0.1	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)
(18)		PrecStd	2.2	0.6	1.0	0.6	0.9	0.4	0.1	0.1	0.0	0.2	0.5	0.7		(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	DB	67.1	71.7	84.1	94.9	100.7	106.0	109.3	106.6	99.8	91.1	81.5	68.9		(19)
(20)		MCWB	50.2	52.6	59.8	65.5	67.6	71.2	73.6	70.1	67.5	63.1	58.5	50.8		(20)
(21)		DB	61.6	66.6	78.1	89.3	97.3	103.0	106.0	103.3	96.0	85.7	74.5	63.4		(21)
(22)		MCWB	48.1	51.3	57.6	63.4	66.4	69.8	70.7	69.3	67.0	61.2	56.2	48.6		(22)
(23)		DB	57.7	62.2	73.5	85.1	94.2	100.7	103.1	100.7	92.6	81.8	69.1	59.0		(23)
(24)		MCWB	46.6	49.5	56.0	61.8	65.5	68.7	69.5	68.6	65.5	59.6	54.1	47.2		(24)
(25)		DB	53.3	58.1	69.0	81.1	90.9	98.3	100.6	98.1	88.7	77.9	64.7	54.5		(25)
(26)		MCWB	44.7	47.8	54.0	60.5	64.6	67.6	68.7	68.0	64.0	58.5	51.8	45.4		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	WB	52.1	55.7	62.0	69.5	71.2	78.0	78.5	76.5	70.9	65.6	60.4	53.0		(27)
(28)		MCDB	62.4	67.0	78.2	87.3	92.3	99.9	102.6	99.6	94.4	85.4	75.6	63.0		(28)
(29)		WB	49.5	53.0	59.4	66.2	69.1	73.5	74.1	72.9	68.6	62.9	57.6	50.2		(29)
(30)		MCDB	59.1	62.7	73.6	82.6	90.7	96.9	98.7	96.7	91.8	81.4	71.1	60.8		(30)
(31)		WB	47.5	50.7	57.2	63.9	67.4	71.0	72.1	70.9	66.6	61.0	55.1	48.0		(31)
(32)		MCDB	56.1	60.1	70.2	79.4	88.7	95.5	96.9	94.8	89.4	79.0	66.8	57.5		(32)
(33)		WB	45.3	48.5	55.2	62.0	66.0	69.2	70.2	69.1	64.7	59.1	52.9	45.8		(33)
(34)		MCDB	52.7	57.5	67.2	77.7	86.6	93.3	95.3	93.4	86.3	75.9	63.1	53.8		(34)
(35)	Mean Daily Temperature Range	MDBR	16.3	18.6	20.3	23.1	26.4	28.1	27.4	29.7	31.4	28.4	21.5	17.0		(35)
(36)		5% DB	22.1	24.1	26.4	29.2	31.1	31.6	30.7	32.3	35.1	32.3	27.0	22.9		(36)
(37)		MCWBR	11.8	12.3	11.0	11.0	10.9	11.0	10.1	11.0	13.7	13.9	12.8	12.3		(37)
(38)		5% WB	19.8	20.5	22.8	24.9	27.1	29.3	28.8	31.7	33.6	30.0	24.3	20.6		(38)
(39)		MCWBR	11.5	11.2	10.6	10.5	10.6	12.3	11.9	12.6	14.2	14.4	12.3	12.1		(39)
(40)	Clear-Sky Solar Irradiance	taub	0.390	0.432	0.501	0.525	0.523	0.525	0.499	0.461	0.440	0.477	0.446	0.393		(40)
(41)		taud	2.092	1.988	1.851	1.830	1.859	1.848	1.909	1.994	2.011	1.894	1.962	2.069		(41)
(42)		Ebn at Noon	237	243	238	242	246	245	250	257	253	223	212	224		(42)
(43)		Edh at Noon	37	47	60	65	64	65	61	54	50	51	42	36		(43)
(44)	All-Sky Solar Radiation	RadAvg	677	970	1335	1782	2215	2513	2464	2264	1871	1302	833	612		(44)
(45)		RadStd	66	98	97	141	94	67	43	48	47	77	77	67		(45)

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		N/A	N/A	N/A	+0.70	N/A	N/A	N/A	N/A	N/A	N/A
	Regional (7 neighbors)	N/A	N/A	N/A	N/A	-1.04	-1.44	N/A	N/A	N/A	+94

Nomenclature: See separate page