

QARSHI, Uzbekistan

WMO: 388120

Lat: 38.750N

Lon: 65.717E

Elev: 375

StdP: 96.90

Time Zone: 5.00 (E05)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-9.3	-5.8	-11.5	1.5	-7.0	-8.5	1.9	-1.6	8.9	12.9	7.5	10.5	2.2	70	0.468

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.7	40.3	21.4	39.0	20.9	37.6	20.6	24.7	36.0	23.3	35.1	22.2	34.3	5.5	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
21.0	16.4	32.6	19.1	14.6	31.3	17.7	13.3	29.8	77.2	36.0	71.5	35.3	67.0	34.6	34.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8.7	7.4	6.4	-10.8	43.1	4.7	1.4	-14.1	44.1	-16.8	45.0	-19.5	45.8	-22.8	46.8
			-11.1	25.5	4.6	2.7	-14.4	27.5	-17.1	29.1	-19.7	30.6	-23.0	32.6
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	17.0	3.9	5.9	11.5	17.5	23.7	28.4	30.2	28.2	22.7	16.4	9.8	4.9
	DBStd	10.18	5.27	5.52	4.93	4.64	3.48	2.67	2.50	2.86	3.29	4.25	5.00	4.68
	HDD10.0	608	196	132	41	4	0	0	0	0	0	6	62	167
	HDD18.3	1851	448	349	216	69	4	0	0	0	5	86	258	415
	CDD10.0	3161	7	17	88	228	426	552	625	565	382	204	57	10
	CDD18.3	1363	0	0	5	44	172	302	367	307	137	26	3	0
	CDH23.3	18716	1	2	71	506	2092	4323	5467	4190	1652	371	41	1
	CDH26.7	10789	0	0	14	177	1037	2630	3484	2542	786	108	11	0
Wind	WSAvg	2.9	2.6	2.8	2.9	2.8	3.0	3.3	3.8	3.2	2.6	2.4	2.3	2.4
Precipitation	PrecAvg	259	38	43	53	37	18	2	1	0	1	5	27	34
	PrecMax	384	61	135	93	106	83	19	12	3	7	33	64	92
	PrecMin	150	14	13	21	1	0	0	0	0	0	3	2	
	PrecStd	70	14	25	20	24	20	4	2	1	2	7	18	23
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	20.1	22.4	28.9	34.1	37.9	41.2	42.8	41.4	37.1	32.6	28.1	21.0
		MCWB	11.4	12.4	15.5	18.8	20.1	21.3	21.6	22.5	20.0	16.7	16.0	11.1
	2%	DB	16.3	19.0	25.4	31.0	35.6	39.4	40.8	39.5	35.0	29.5	23.4	17.3
		MCWB	9.5	11.2	14.7	19.0	19.6	20.8	21.8	21.1	19.3	16.2	14.1	10.0
	5%	DB	13.7	16.5	22.7	28.5	34.1	37.9	39.3	37.9	33.2	27.4	20.5	14.6
		MCWB	8.4	10.4	13.6	17.7	19.2	20.7	21.1	20.6	18.6	15.5	12.7	9.2
	10%	DB	11.1	14.2	20.1	26.3	32.3	36.5	37.9	36.4	31.3	25.2	18.0	12.1
		MCWB	7.2	9.2	12.8	16.8	18.9	20.0	20.8	20.4	17.9	14.6	11.4	7.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.1	13.7	17.4	21.8	24.8	26.2	26.6	26.1	22.7	19.2	16.7	12.9
		MCDB	18.7	18.9	25.4	29.7	30.7	35.9	37.3	37.9	34.1	28.3	25.0	18.4
	2%	WB	10.2	12.1	15.7	20.1	22.1	23.6	24.6	24.1	20.9	17.7	15.1	10.7
		MCDB	15.0	17.8	22.9	28.0	32.2	35.6	36.5	35.7	32.3	27.0	22.0	15.6
	5%	WB	8.8	10.8	14.4	18.6	20.8	22.2	23.3	22.6	19.7	16.3	13.6	9.4
		MCDB	12.9	15.6	21.1	26.2	31.2	34.7	35.7	34.5	30.9	25.3	19.4	14.0
	10%	WB	7.4	9.5	13.2	17.4	19.6	21.2	22.1	21.4	18.5	15.1	12.0	8.1
		MCDB	10.9	13.8	19.1	24.8	29.7	34.1	35.0	33.8	29.6	23.8	17.1	11.9
Mean Daily Temperature Range	5% DB	MDBR	8.9	10.2	11.1	12.2	13.9	14.9	14.7	15.4	15.8	14.5	11.6	9.3
		MCDBR	13.3	14.2	15.3	15.7	16.5	16.7	16.1	16.5	17.2	17.0	15.4	13.7
		MCWBR	7.9	8.1	7.4	6.9	6.2	6.4	6.1	6.4	7.1	7.8	8.2	8.3
	5% WB	MCDBR	12.0	12.8	13.5	13.9	15.4	15.8	15.3	15.8	16.9	15.9	13.9	12.3
		MCWBR	7.8	8.0	7.5	7.3	7.6	7.4	7.5	7.7	8.4	8.6	8.2	8.0
Clear-Sky Solar Irradiance	taub	0.378	0.420	0.485	0.505	0.499	0.496	0.473	0.447	0.430	0.468	0.437	0.384	
	taud	2.131	2.027	1.887	1.876	1.914	1.914	1.966	2.022	2.027	1.899	1.979	2.100	
	Ebn at Noon	760	778	764	780	793	795	810	820	807	711	676	716	
	Edh at Noon	112	143	182	195	191	191	180	166	155	160	130	108	
All-Sky Solar Radiation	RadAvg	2.00	2.82	4.02	5.47	6.88	7.85	7.70	7.02	5.73	3.97	2.48	1.81	
	RadStd	0.21	0.29	0.33	0.50	0.31	0.19	0.14	0.14	0.15	0.21	0.24	0.20	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (8 neighbors)	N/A	N/A	N/A	+0.32	-0.38	-0.52	N/A	N/A	N/A	+61

Nomenclature: See separate page