

DANGHARA, Tajikistan

WMO: 388470

Lat: 38.067N

Lon: 69.283E

Elev: 669

StdP: 93.54

Time Zone: 5.00 (E05)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-10.3	-6.1	-12.8	1.3	-3.9	-10.2	1.7	1.1	7.7	8.6	6.3	7.2	2.5	270	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.0	40.1	19.9	38.8	19.2	37.6	18.7	21.0	36.8	20.3	35.3	19.7	34.0	1.9	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.6	12.9	23.7	15.7	12.1	24.1	14.9	11.5	24.0	64.1	37.0	61.5	35.1	59.2	34.1	23.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
(4) 6.3	6.0	4.9	DB	-12.0	42.3	5.6	1.1	-16.0	43.1	-19.3	43.7	-22.5	44.4	-26.6	45.2	
(5)			WB	-11.8	22.5	5.2	0.8	-15.5	23.0	-18.6	23.5	-21.5	23.9	-25.3	24.5	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	17.4	4.6	5.6	12.9	17.5	22.6	27.7	30.5	28.6	24.3	17.7	10.1	5.8
	DBStd	9.87	4.26	6.12	4.46	3.85	2.92	2.80	1.96	2.33	2.53	4.04	4.59	4.75
	HDD10.0	526	169	139	23	3	0	0	0	0	0	2	48	143
	HDD18.3	1719	424	358	175	58	3	0	0	0	1	62	249	389
	CDD10.0	3223	3	14	112	228	391	529	636	578	430	239	52	12
	CDD18.3	1374	0	0	6	33	135	279	378	319	181	41	3	0
	CDH23.3	18464	0	3	36	322	1382	3728	5752	4581	2187	455	19	0
	CDH26.7	10604	0	0	6	82	582	2145	3684	2833	1123	148	2	0
(14) Wind	WSAvg	2.0	2.0	2.2	2.2	1.9	2.0	1.8	1.9	2.1	2.2	2.1	1.9	1.8
(15) Precipitation	PrecAvg	519	54	71	84	80	60	25	14	7	7	23	42	52
	PrecMax	736	97	121	135	187	120	54	37	21	19	50	112	100
	PrecMin	326	22	23	24	26	11	9	5	3	1	4	12	7
	PrecStd	101	21	23	27	31	29	11	7	4	4	11	25	25
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	16.2	23.0	26.7	31.6	35.3	40.0	42.3	41.3	36.7	33.2	25.9	18.9
		MCWB	7.7	11.8	14.0	16.9	18.7	19.9	21.3	19.6	17.9	15.8	13.4	9.4
	2%	DB	14.0	17.7	23.8	28.9	33.5	38.3	40.8	39.3	35.5	30.2	21.7	16.5
		MCWB	7.3	9.9	13.3	16.3	18.5	19.0	20.3	19.2	17.2	15.3	11.9	8.2
	5%	DB	12.3	14.8	21.9	26.8	31.8	36.9	39.5	38.1	34.3	28.0	19.1	14.4
		MCWB	6.6	8.4	12.6	15.7	18.2	18.8	19.8	18.7	16.8	14.3	10.8	7.4
	10%	DB	10.8	13.1	19.8	24.8	30.0	35.5	38.2	36.8	32.7	25.7	16.8	12.7
		MCWB	5.8	7.6	11.9	15.3	18.0	18.4	19.1	18.2	16.4	13.7	10.1	6.8
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.7	12.4	15.8	18.9	20.8	21.2	22.2	20.7	18.7	17.0	14.3	10.7
		MCDB	13.3	20.0	23.4	26.7	31.2	35.6	38.4	37.8	34.6	29.6	23.2	16.7
	2%	WB	8.4	10.6	14.6	17.9	20.0	20.4	21.4	19.8	17.9	15.9	13.0	9.5
		MCDB	12.3	16.4	21.7	25.7	29.6	34.3	38.0	37.1	33.9	27.6	20.1	14.5
	5%	WB	7.4	9.3	13.6	17.1	19.3	19.7	20.8	19.2	17.2	15.0	11.8	8.4
		MCDB	10.9	14.1	19.6	24.5	28.6	33.2	37.5	36.6	33.0	25.8	17.5	12.5
	10%	WB	6.6	8.2	12.6	16.1	18.5	19.2	20.1	18.6	16.5	14.1	10.8	7.5
		MCDB	9.8	12.3	18.1	22.9	27.6	32.6	36.1	35.6	31.8	24.5	15.3	11.3
(35) Mean Daily Temperature Range	5% DB	MDBR	7.9	8.5	9.4	10.7	12.4	13.8	15.0	15.5	15.6	13.5	9.7	8.8
		MCDBR	10.8	10.9	11.9	14.5	15.2	15.6	16.5	16.5	17.4	16.7	13.7	11.5
		MCWBR	6.2	5.7	5.7	6.0	5.7	5.0	6.1	6.3	7.6	7.5	6.9	6.0
	5% WB	MCDBR	9.0	9.9	10.8	12.5	13.3	14.4	15.2	15.7	16.7	14.5	11.3	10.1
		MCWBR	5.6	5.6	6.0	5.9	5.8	5.0	5.9	6.3	7.5	6.7	6.1	6.0
(40) Clear-Sky Solar Irradiance	taub		0.383	0.438	0.498	0.505	0.517	0.549	0.541	0.504	0.464	0.491	0.449	0.394
	taud		2.093	1.964	1.854	1.878	1.882	1.802	1.809	1.887	1.942	1.845	1.927	2.045
	Ebn at Noon		758	761	755	781	781	753	755	773	777	693	667	706
	Edh at Noon		118	153	189	195	198	215	211	191	170	170	139	116
(44) All-Sky Solar Radiation	RadAvg		2.12	2.77	4.00	5.33	6.61	7.72	7.79	7.17	5.98	4.11	2.50	1.90
	RadStd		0.24	0.41	0.35	0.55	0.48	0.33	0.24	0.22	0.18	0.35	0.32	0.24

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (11 neighbors)	N/A	N/A	N/A	N/A	-0.36	-0.68	N/A	N/A	N/A	N/A

Nomenclature: See separate page