

TEJEN, Turkmenistan

WMO: 388860

Lat: 37.383N

Lon: 60.517E

Elev: 610

StdP: 14.37

Time Zone: 5.00 (E05)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	16.9	23.3	8.5	8.7	23.2	15.6	12.4	33.2	18.6	46.1	16.1	43.7	4.5	90	0.426

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	26.8	105.3	70.9	102.9	70.5	100.6	70.0	80.2	95.3	76.1	94.3	73.2	93.6	5.6	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
75.8	137.9	92.2	70.1	113.4	89.0	66.2	98.6	86.4	44.4	95.4	40.0	94.6	37.3	93.1	97.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
17.7	14.4	12.1	DB	12.9	109.7	9.0	2.6	6.4	111.6	1.1	113.1	-3.9	114.5	-10.4	116.4	
			WB	13.0	79.7	8.6	5.9	6.8	84.0	1.8	87.4	-3.0	90.8	-9.2	95.1	

Monthly Climatic Design Conditions

		Annual														
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	64.2	40.5	44.4	55.3	65.5	77.0	84.4	87.4	84.1	74.8	63.3	50.8	41.8	(6)
(7)		DBStd	18.18	9.00	9.41	8.79	8.37	5.84	4.58	4.10	4.53	5.78	7.64	8.57	7.48	(7)
(8)		HDD50	916	310	194	45	4	0	0	0	0	0	5	89	269	(8)
(9)		HDD65	3030	760	576	319	92	4	0	0	0	4	124	432	719	(9)
(10)		CDD50	6108	15	39	211	470	837	1031	1161	1056	745	416	112	15	(10)
(11)		CDD65	2746	0	1	19	109	375	581	696	591	299	70	5	0	(11)
(12)		CDH74	36725	4	17	271	1143	4327	8218	10379	8035	3415	843	73	0	(12)
(13)		CDH80	21446	0	3	90	459	2195	5012	6710	4989	1687	281	20	0	(13)
(14)	Wind	WSAvg	4.8	4.4	5.3	5.4	5.7	5.3	5.3	4.7	4.5	4.1	4.3	4.2	4.6	(14)
(15)	Precipitation	PrecAvg	6.3	0.8	0.7	1.2	0.8	0.5	0.0	0.0	0.0	0.5	0.6	0.6	0.6	(15)
(16)		PrecMax	11.3	2.4	2.4	4.9	3.1	2.0	0.3	0.1	0.2	0.4	4.0	1.9	1.4	(16)
(17)		PrecMin	2.1	0.0	0.1	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)
(18)		PrecStd	2.2	0.5	0.6	1.0	0.8	0.5	0.1	0.0	0.1	0.8	0.4	0.4	0.5	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	71.4	76.2	89.2	96.1	101.6	106.8	109.5	107.1	100.6	92.5	82.6	70.4	(19)
MCWB			52.9	55.6	60.6	65.7	67.0	70.1	72.5	71.8	67.8	64.3	60.9	53.5	(20)	
2%		DB	63.8	69.1	81.0	89.7	97.3	103.6	106.1	103.5	96.2	86.8	74.0	63.9	(21)	
		MCWB	49.9	53.3	58.2	64.7	68.0	69.6	71.5	70.5	66.9	63.4	57.4	51.0	(22)	
5%		DB	57.7	63.5	75.5	85.6	94.1	101.0	103.5	101.1	92.9	82.6	69.3	58.4	(23)	
		MCWB	47.1	50.9	56.9	63.6	66.9	69.7	71.6	70.0	66.0	61.5	55.0	49.0	(24)	
10%		DB	52.9	58.4	70.3	80.8	91.0	98.4	101.1	98.4	89.4	78.5	64.8	53.6	(25)	
		MCWB	45.0	48.6	55.3	61.2	66.1	69.1	70.8	68.8	64.7	59.5	53.1	46.4	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	53.8	57.8	62.6	74.4	79.8	86.1	84.6	85.6	74.5	68.6	62.5	55.3	(27)
MCD B			68.0	70.6	83.1	83.9	88.8	94.8	100.3	96.8	93.4	85.9	78.5	67.0	(28)	
2%		WB	50.8	54.5	59.8	67.4	70.9	76.3	79.7	78.6	70.5	64.9	59.0	52.1	(29)	
		MCD B	61.7	67.1	76.8	84.2	89.3	93.0	98.4	94.0	89.1	83.4	71.2	62.0	(30)	
5%		WB	48.2	51.6	57.9	64.5	68.5	72.9	76.1	74.3	68.0	62.8	56.4	49.3	(31)	
		MCD B	56.6	61.3	72.9	81.4	89.0	94.6	95.9	93.3	87.9	79.4	66.6	57.6	(32)	
10%		WB	45.5	49.2	56.0	62.3	67.0	70.7	73.5	71.3	65.9	60.8	53.8	46.7	(33)	
		MCD B	52.2	57.7	69.1	77.5	87.2	93.7	94.6	93.1	85.9	75.7	63.5	53.1	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	17.6	18.7	20.2	21.0	23.9	25.8	26.8	28.1	27.4	24.9	20.7	17.6	(35)
MCDBR			27.1	28.5	30.6	29.1	28.8	30.3	29.7	31.2	30.6	30.8	28.9	26.8	(36)	
MCWBR			15.2	15.3	12.5	11.1	10.1	11.2	10.6	11.9	11.9	14.3	14.8	16.5	(37)	
5% WB		MCDBR	24.7	25.7	26.8	26.0	26.2	27.4	27.3	28.2	27.3	27.7	25.2	24.5	(38)	
		MCWBR	14.6	14.8	11.8	11.6	10.6	13.3	13.7	14.4	12.7	14.1	13.9	15.5	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.395	0.442	0.514	0.555	0.558	0.560	0.551	0.504	0.474	0.498	0.455	0.404	(40)	
(41)		taud	2.090	1.966	1.821	1.777	1.794	1.782	1.809	1.894	1.936	1.865	1.948	2.056	(41)	
(42)		Ebn at Noon	239	242	236	235	238	237	238	246	245	220	213	224	(42)	
(43)		Edh at Noon	38	49	62	69	69	69	67	60	55	54	44	37	(43)	
(44)	All-Sky Solar Radiation	RadAvg	716	1003	1352	1791	2212	2526	2495	2313	1896	1331	873	656	(44)	
(45)		RadStd	62	104	105	164	85	78	52	64	48	77	74	74	(45)	

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65		
(46)	Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) -2.63	(j) N/A	(k) N/A	(l) N/A	(46)	
(47)	Regional (6 neighbors)	N/A	N/A	N/A	+0.74	-0.99	N/A	N/A	N/A	N/A	+158	(47)

Nomenclature: See separate page