

KERKI, Turkmenistan

WMO: 389110

Lat: 37.833N

Lon: 65.200E

Elev: 240

StdP: 98.47

Time Zone: 5.00 (E05)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-8.2	-4.5	-12.0	1.4	-1.6	-9.3	1.7	2.8	12.3	15.0	10.6	13.5	2.5	300	0.472

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.7	40.8	22.2	39.5	21.6	38.2	21.1	24.7	37.9	23.7	36.6	22.7	35.4	4.2	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
20.3	15.4	33.9	19.1	14.3	32.7	17.9	13.3	30.9	76.5	38.1	72.3	36.8	68.2	35.4	31.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.7	8.4	7.3	-10.1	43.5	5.0	1.0	-13.7	44.2	-16.6	44.8	-19.4	45.3	-23.1	46.0		
(5)			-10.6	26.3	4.9	2.5	-14.1	28.1	-16.9	29.6	-19.7	31.0	-23.2	32.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	18.1	5.1	7.1	13.2	19.3	25.3	29.4	30.9	29.1	23.7	17.3	10.6	5.9	(6)
(7)		DBStd	10.11	5.26	5.63	5.04	4.77	3.39	2.53	2.19	2.65	3.21	4.30	5.07	4.72	(7)
(8)		HDD10.0	496	163	108	27	2	0	0	0	0	0	3	51	141	(8)
(9)		HDD18.3	1638	410	314	173	46	2	0	0	0	2	71	236	384	(9)
(10)		CDD10.0	3463	11	28	124	281	473	582	649	591	411	229	70	15	(10)
(11)		CDD18.3	1564	0	0	12	75	217	332	391	333	163	38	5	0	(11)
(12)		CDH23.3	21118	0	2	118	771	2641	4831	5832	4549	1876	447	50	1	(12)
(13)		CDH26.7	12286	0	0	26	292	1372	2989	3743	2796	919	137	12	0	(13)
(14)	Wind	WSAvg	3.2	3.4	3.8	3.8	3.4	3.2	3.3	3.4	3.1	2.5	2.6	2.8	3.0	(14)
(15)	Precipitation	PrecAvg	181	30	25	49	28	12	1	0	0	3	12	25	(15)	
(16)		PrecMax	333	96	66	113	82	39	14	1	0	5	26	68	61	(16)
(17)		PrecMin	96	1	4	5	0	0	0	0	0	0	0	0	1	(17)
(18)		PrecStd	55	21	15	26	21	11	3	0	0	1	6	17	16	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	20.1	22.9	29.9	35.1	38.8	41.7	43.0	41.7	37.7	32.3	28.4	21.0	(19)
(20)			MCWB	9.6	11.0	16.6	19.8	20.5	21.9	24.0	23.0	20.0	17.8	15.8	10.1	(20)
(21)		2%	DB	17.0	20.0	26.7	32.2	36.7	40.0	41.3	40.0	35.5	30.0	24.2	18.2	(21)
(22)			MCWB	8.9	10.8	14.7	18.4	20.4	21.3	23.0	21.5	19.3	16.5	13.5	9.5	(22)
(23)		5%	DB	14.7	17.6	24.1	30.0	35.0	38.6	39.8	38.5	33.7	28.0	21.4	15.8	(23)
(24)			MCWB	8.2	10.1	13.8	17.7	20.0	21.2	22.2	21.0	18.8	15.7	12.3	8.8	(24)
(25)		10%	DB	12.6	15.5	21.7	27.9	33.4	37.2	38.5	37.0	31.9	25.8	19.1	13.3	(25)
(26)			MCWB	7.4	9.3	12.9	16.9	19.1	20.7	21.5	20.3	17.7	14.7	11.4	7.8	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.8	13.6	18.6	22.2	24.3	25.6	26.4	25.0	22.0	18.9	16.4	12.6	(27)
(28)			MCD B	16.7	18.5	27.8	33.1	35.6	38.0	39.6	38.5	34.2	30.5	27.2	17.2	(28)
(29)		2%	WB	10.2	12.2	16.3	20.3	22.8	24.4	25.0	23.6	20.7	17.3	14.5	10.6	(29)
(30)			MCD B	15.0	17.4	23.4	29.5	33.5	36.8	39.0	36.8	33.2	28.1	22.3	16.2	(30)
(31)		5%	WB	8.9	11.1	14.9	19.0	21.5	23.4	23.8	22.3	19.5	16.2	13.1	9.4	(31)
(32)			MCD B	13.6	16.3	21.7	27.4	32.0	35.8	37.6	35.4	32.0	26.7	19.8	14.7	(32)
(33)		10%	WB	7.7	9.9	13.6	17.9	20.3	22.3	22.6	21.2	18.4	15.2	11.9	8.2	(33)
(34)			MCD B	12.0	14.8	20.0	25.6	30.4	34.6	36.1	34.6	30.3	24.8	18.1	12.9	(34)
(35)	Mean Daily Temperature Range	MDBR	8.7	9.7	10.7	11.8	13.3	14.5	14.7	15.5	15.5	13.9	11.2	9.1	(35)	
(36)		5% DB	MCD BR	12.1	12.9	14.0	14.7	15.7	16.4	16.2	16.7	17.1	16.2	14.6	12.7	(36)
(37)			MCWBR	6.2	6.3	5.6	5.5	5.6	5.7	6.0	6.2	6.7	6.9	6.7	6.5	(37)
(38)			5% WB	MCD BR	10.7	11.4	12.5	13.5	14.1	14.7	15.5	15.9	16.0	14.9	13.0	11.3
(39)		MCWBR		6.3	6.5	6.3	6.1	6.4	6.7	7.0	7.0	7.2	7.0	6.8	6.6	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.394	0.437	0.499	0.517	0.513	0.512	0.491	0.460	0.439	0.476	0.450	0.399	(40)	
(41)		taud	2.085	1.983	1.860	1.857	1.886	1.877	1.923	1.994	2.012	1.897	1.951	2.059	(41)	
(42)		Ebn at Noon	748	764	756	772	784	783	796	812	802	710	671	706	(42)	
(43)		Edh at Noon	120	151	188	200	197	199	189	172	159	162	136	115	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.16	3.02	4.24	5.69	7.14	8.11	7.92	7.25	6.01	4.24	2.68	2.00	(44)	
(45)		RadStd	0.24	0.32	0.35	0.50	0.27	0.16	0.13	0.13	0.13	0.24	0.25	0.23	(45)	

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46) Station Only	DBAvg	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(47) Regional (5 neighbors)		N/A	N/A	N/A	+0.25	+1.33	+1.64	N/A	N/A	N/A
		N/A	N/A	N/A	+0.32	-0.36	-0.50	N/A	N/A	N/A

Nomenclature: See separate page