

QURGONTEPPA, Tajikistan

WMO: 389330

Lat: 37.817N

Lon: 68.783E

Elev: 1407

StdP: 13.96

Time Zone: 5.00 (E05)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	18.0	24.9	12.7	11.0	22.5	18.4	14.6	29.8	14.0	41.5	9.9	43.6	2.0	50	0.380

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	27.8	102.0	76.7	100.2	75.6	98.2	74.6	78.1	98.8	76.8	97.6	75.5	95.9	3.2	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
71.5	122.5	93.7	70.0	116.2	92.7	68.5	110.1	91.2	42.8	99.3	41.5	97.6	40.2	96.0	83.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
10.0	9.2	7.8	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
			16.2	105.4	8.7	1.4	9.9	106.5	4.8	107.3	-0.1	108.1	-6.5	109.1
			15.6	81.2	8.6	1.6	9.4	82.4	4.3	83.3	-0.5	84.2	-6.7	85.3
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	63.9	41.8	44.0	57.3	65.9	75.4	82.6	85.0	81.4	74.6	63.8	50.7	42.5	(6)
		DBStd	16.78	6.94	10.14	7.77	6.63	4.99	3.75	2.72	3.51	3.83	6.39	7.45	7.24	(7)
		HDD50	815	264	204	27	2	0	0	0	0	1	71	246		(8)
		HDD65	2862	721	588	254	66	2	0	0	1	99	432	699		(9)
		CDD50	5871	8	36	255	479	786	978	1084	974	737	429	93	12	(10)
		CDD65	2441	0	0	17	93	323	528	619	509	287	62	3	0	(11)
		CDH74	30848	0	10	203	935	3541	7135	8694	6417	3182	704	27	0	(12)
		CDH80	17114	0	2	43	304	1691	4207	5360	3756	1550	197	4	0	(13)
(14)	Wind	WSAvg	3.1	3.1	3.6	3.5	3.3	3.5	3.3	3.2	2.9	2.8	2.8	2.7	2.7	(14)
(15)	Precipitation	PrecAvg	10.7	1.4	1.6	2.6	1.7	1.0	0.1	0.0	0.0	0.0	0.3	0.8	1.2	(15)
(16)		PrecMax	16.8	4.3	3.3	4.6	4.0	2.8	0.4	0.2	0.0	0.1	1.4	2.6	3.2	(16)
(17)		PrecMin	6.3	0.2	0.3	1.2	0.4	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.2	(17)
(18)		PrecStd	2.6	0.8	0.8	1.0	0.9	0.7	0.1	0.0	0.0	0.0	0.4	0.7	0.8	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	DB	63.2	73.9	84.8	92.4	98.2	104.1	104.7	102.3	96.6	90.6	78.7	66.5		(19)
(20)		MCWB	49.0	55.0	61.1	66.9	71.6	76.8	78.5	76.8	71.8	67.4	59.4	51.3		(20)
(21)		DB	58.9	65.8	79.4	87.1	95.3	101.5	102.4	100.1	94.2	84.8	70.9	61.7		(21)
(22)		MCWB	47.1	51.6	58.9	64.6	70.1	75.6	77.4	75.4	70.5	65.1	55.3	48.8		(22)
(23)		DB	55.7	61.0	74.9	83.3	92.6	99.4	100.7	97.9	91.9	81.5	66.9	57.8		(23)
(24)		MCWB	45.8	48.8	57.2	63.2	68.8	74.5	76.4	74.5	69.8	62.5	52.8	47.1		(24)
(25)		DB	52.5	57.3	70.3	79.3	89.3	96.7	98.8	95.5	88.7	77.8	62.8	53.7		(25)
(26)		MCWB	44.5	47.6	55.6	61.6	67.6	73.4	75.5	73.0	67.7	60.3	51.0	45.5		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	WB	51.0	56.8	62.5	68.9	72.9	78.9	80.4	78.2	73.6	68.3	59.8	52.2		(27)
(28)		MCDB	59.8	72.8	82.6	87.0	94.1	100.3	101.0	98.9	93.7	87.3	75.7	63.3		(28)
(29)		WB	48.7	52.6	60.1	66.3	71.4	77.1	78.7	76.7	71.7	66.1	56.5	49.8		(29)
(30)		MCDB	56.1	63.0	75.8	81.4	92.9	98.6	99.2	97.7	92.3	83.7	67.4	59.1		(30)
(31)		WB	47.0	50.5	58.2	64.6	69.8	75.4	77.5	75.4	70.0	63.5	54.0	47.9		(31)
(32)		MCDB	53.8	58.5	71.9	79.4	89.5	96.5	98.1	95.6	90.1	79.5	64.1	54.9		(32)
(33)		WB	45.2	48.7	56.6	63.2	68.4	74.1	76.3	74.0	68.3	61.2	52.0	46.4		(33)
(34)		MCDB	51.2	55.9	68.6	76.2	86.9	94.6	96.7	93.7	87.3	75.5	60.8	53.2		(34)
(35)	Mean Daily Temperature Range	MDBR	15.5	16.5	19.7	21.3	24.1	27.1	27.8	28.2	29.0	24.9	18.5	16.3		(35)
(36)		5% DB	21.6	23.2	26.9	28.5	29.4	30.9	30.3	30.6	31.9	30.0	25.9	24.6		(36)
(37)		MCWBR	11.9	11.5	11.2	10.9	11.6	13.6	13.7	13.6	14.3	13.8	12.1	13.3		(37)
(38)		5% WB	17.8	19.3	23.2	24.3	26.5	28.8	29.2	29.7	31.0	27.8	22.7	20.5		(38)
(39)		MCWBR	10.3	10.3	10.4	10.0	11.3	13.7	13.8	14.0	14.4	13.3	10.9	11.5		(39)
(40)	Clear-Sky Solar Irradiance	taub	0.388	0.440	0.495	0.500	0.510	0.542	0.532	0.500	0.465	0.492	0.454	0.403		(40)
(41)		taud	2.111	1.985	1.879	1.906	1.911	1.829	1.842	1.910	1.954	1.858	1.938	2.047		(41)
(42)		Ebn at Noon	240	242	241	250	250	241	242	246	247	220	212	222		(42)
(43)		Edh at Noon	37	48	59	60	61	66	65	59	54	54	44	37		(43)
(44)	All-Sky Solar Radiation	RadAvg	666	889	1304	1741	2154	2486	2488	2284	1908	1331	817	603		(44)
(45)		RadStd	75	120	113	164	138	95	69	66	50	105	94	81		(45)

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	Regional (10 neighbors)	N/A	N/A	N/A	N/A	-0.65	-1.22	N/A	N/A	N/A	N/A

Nomenclature: See separate page