

PARKHAR, Tajikistan

WMO: 389440

Lat: 37.483N

Lon: 69.383E

Elev: 1467

StdP: 13.93

Time Zone: 5.00 (E05)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	17.2	23.6	14.9	12.4	19.4	20.7	16.3	27.4	21.7	40.7	18.3	41.2	3.2	0	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	25.4	102.5	69.7	100.6	68.4	98.7	67.5	71.9	96.3	70.2	95.2	68.9	93.9	5.5	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.1	94.7	81.6	62.2	88.3	79.4	60.5	83.2	78.0	36.9	96.8	35.2	95.1	34.1	94.3	79.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.0	14.4	12.1	13.5	106.0	10.2	0.9	6.1	106.6	0.1	107.2	-5.6	107.7	-13.0	108.4
			13.1	74.1	10.0	2.1	5.9	75.7	0.1	76.9	-5.6	78.1	-12.8	79.7

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	64.0	40.7	42.7	55.8	65.0	75.1	83.9	87.3	83.5	75.6	64.1	50.6	41.9	(6)
(7)		DBStd	17.77	6.86	9.91	7.54	6.93	5.61	4.14	3.05	3.66	4.24	6.51	7.95	7.07	(7)
(8)		HDD50	893	290	229	34	3	0	0	0	0	0	1	78	258	(8)
(9)		HDD65	3005	752	623	295	81	3	0	0	0	1	96	439	715	(9)
(10)		CDD50	5994	3	25	213	453	778	1017	1156	1039	768	439	95	8	(10)
(11)		CDD65	2631	0	0	9	81	315	567	691	574	319	69	6	0	(11)
(12)		CDH74	32417	0	2	83	619	3162	7366	9835	7309	3336	657	48	0	(12)
(13)		CDH80	17896	0	0	16	162	1425	4273	6060	4204	1585	164	7	0	(13)
(14)	Wind	WSAvg	4.6	4.4	4.8	5.3	4.7	5.7	5.4	5.3	4.8	4.2	3.7	3.2	3.1	(14)
(15)	Precipitation	PrecAvg	19.0	2.2	3.3	3.3	2.7	1.8	0.6	0.6	0.5	0.3	0.6	1.4	1.6	(15)
(16)		PrecMax	25.0	5.6	6.7	5.8	4.1	5.1	1.9	1.7	1.0	1.2	1.7	4.2	3.4	(16)
(17)		PrecMin	10.6	0.8	1.3	0.6	0.9	0.2	0.1	0.1	0.1	0.1	0.0	0.3	0.3	(17)
(18)		PrecStd	3.5	1.1	1.3	1.3	0.9	1.0	0.4	0.4	0.2	0.3	0.5	0.9	0.8	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	60.5	70.5	81.2	90.5	98.8	103.9	105.7	102.6	95.4	88.7	80.5	62.5	(19)
MCWB			49.0	54.0	59.9	65.5	67.7	69.0	71.0	70.7	65.8	62.2	59.9	49.9	(20)	
2%		DB	56.7	62.9	75.5	84.5	94.4	101.5	103.4	100.1	93.6	84.1	71.6	58.6	(21)	
		MCWB	47.7	52.6	58.2	63.5	66.0	68.2	70.7	68.6	65.0	60.0	55.4	48.5	(22)	
5%		DB	53.4	58.6	71.3	80.8	91.4	99.3	101.5	98.3	91.6	81.3	66.4	55.3	(23)	
		MCWB	46.3	50.2	56.6	62.7	65.5	67.3	69.2	67.3	64.0	59.2	53.7	47.2	(24)	
10%		DB	50.4	55.4	67.2	77.2	88.3	96.7	99.7	96.0	88.8	77.6	62.2	52.0	(25)	
		MCWB	44.9	48.3	55.2	61.9	64.9	66.6	68.0	66.5	62.9	57.7	51.6	45.7	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	50.9	55.7	62.0	70.1	70.9	73.1	76.3	73.4	67.3	62.7	60.2	52.9	(27)
MCD B			58.6	66.4	75.2	82.8	88.9	94.6	102.2	99.6	93.0	86.0	77.7	59.9	(28)	
2%		WB	49.0	53.0	59.6	67.1	68.8	70.1	72.9	70.2	65.8	61.0	57.1	49.5	(29)	
		MCD B	54.9	61.3	72.2	79.3	86.5	94.8	98.4	96.4	90.8	81.6	70.2	56.1	(30)	
5%		WB	47.0	51.0	57.6	65.0	67.5	68.9	70.9	68.9	64.7	59.6	54.3	48.0	(31)	
		MCD B	52.2	57.4	68.3	76.7	84.8	94.3	97.7	95.3	89.6	78.5	64.1	53.6	(32)	
10%		WB	45.2	49.2	56.0	63.2	66.4	67.8	69.1	67.5	63.4	58.2	52.4	46.2	(33)	
		MCD B	49.9	54.2	65.4	74.0	82.8	93.5	96.7	93.4	87.4	75.8	61.0	51.3	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	13.9	14.7	17.1	18.9	22.5	25.0	25.4	25.3	26.0	22.3	16.9	14.5	(35)
MCD BR			18.8	19.4	22.7	24.5	26.6	27.8	26.9	26.7	28.2	26.2	23.7	20.4	(36)	
MCWBR			12.0	11.4	10.3	10.2	8.5	9.1	10.1	9.8	11.5	11.3	12.8	12.8	(37)	
5% WB		MCD BR	16.5	17.6	19.2	20.7	22.6	25.8	25.0	24.7	26.9	24.1	20.7	17.0	(38)	
		MCWBR	11.0	10.9	9.9	10.5	9.4	9.4	10.9	9.7	11.5	10.8	11.7	11.6	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.393	0.449	0.504	0.514	0.528	0.561	0.547	0.511	0.472	0.500	0.462	0.407	(40)	
taud		2.088	1.956	1.856	1.871	1.865	1.782	1.804	1.879	1.932	1.838	1.916	2.038	(41)		
Ebn at Noon		239	239	239	246	245	236	238	244	245	219	210	222	(42)		
Edh at Noon		38	49	60	62	64	69	68	61	55	55	45	38	(43)		
(44)	All-Sky Solar Radiation	RadAvg	677	900	1334	1757	2189	2515	2512	2305	1930	1362	834	615	(44)	
(45)		RadStd	75	125	112	162	138	96	77	59	46	99	93	84	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (10 neighbors)	N/A	N/A	N/A	N/A	-0.65	-1.22	N/A	N/A	N/A	N/A

Nomenclature: See separate page