

KHOROG, TajikistanWMO: **389540**Lat: **37.501N**Lon: **71.515E**Elev: **2077**StdP: **78.74**Time Zone: **5.00 (E05)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-17.2	-14.5	-20.8	0.8	-12.9	-18.8	0.9	-10.6	3.0	-3.1	2.2	-2.0	0.0	N/A	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.9	32.2	18.7	30.9	17.7	29.5	16.9	19.8	30.7	18.6	29.6	17.5	28.4	1.0	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
15.9	14.6	27.5	14.4	13.3	26.9	13.1	12.2	25.3	67.3	30.8	62.6	29.7	58.5	28.6	25.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.3	4.7	3.5	-19.3	34.3	2.9	0.9	-21.4	34.9	-23.1	35.4	-24.7	35.9	-26.8	36.6		
(5)			-20.1	21.8	3.4	1.5	-22.6	22.8	-24.5	23.7	-26.4	24.6	-28.8	25.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	9.7	-6.7	-3.7	3.7	10.8	15.2	19.2	22.5	22.4	17.8	11.2	4.8	-1.7
	DBStd	10.30	4.14	3.99	4.08	3.31	2.36	2.53	2.58	2.33	2.65	3.06	2.77	3.29
	HDD10.0	1672	517	384	198	29	1	0	0	0	0	23	157	362
	HDD18.3	3486	775	618	455	227	100	19	2	1	41	221	407	621
	CDD10.0	1562	0	0	2	52	162	277	389	384	234	61	1	0
	CDD18.3	333	0	0	0	0	3	46	133	127	25	0	0	0
	CDH23.3	3707	0	0	0	5	59	504	1431	1378	325	4	0	0
	CDH26.7	1216	0	0	0	0	4	127	546	487	52	0	0	0
Wind	WSAvg	0.6	0.1	0.3	0.5	1.0	1.1	0.9	0.8	0.8	0.8	0.5	0.4	0.3
Precipitation	PrecAvg	239	27	36	51	41	32	8	3	0	1	15	18	32
	PrecMax	452	121	90	134	115	92	34	17	4	10	125	75	182
	PrecMin	70	1	4	4	0	2	0	0	0	0	0	0	0
	PrecStd	77	24	21	30	27	23	8	5	1	2	27	20	37
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	3.1	6.4	16.1	23.2	27.2	31.8	34.3	33.6	29.6	23.7	15.7	8.2
		MCWB	-0.6	1.2	6.6	10.9	13.8	17.4	20.1	20.1	17.6	12.4	7.2	2.6
	2%	DB	1.5	4.3	13.6	20.5	25.0	29.6	32.7	32.0	28.1	21.5	13.5	6.1
		MCWB	-1.3	0.1	5.6	9.9	12.2	16.1	19.1	18.5	16.3	11.3	6.0	1.5
	5%	DB	0.3	2.8	11.6	18.8	23.3	28.1	31.3	30.8	26.8	19.9	11.6	4.7
		MCWB	-2.3	-0.4	4.5	9.1	11.6	15.3	18.0	17.7	15.3	10.4	4.9	0.4
	10%	DB	-0.9	1.5	9.7	16.9	21.6	26.3	29.8	29.5	25.3	17.9	9.9	3.3
		MCWB	-2.9	-1.0	3.7	8.0	10.8	14.4	17.2	17.0	14.4	9.3	3.8	-0.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	0.6	2.6	7.6	12.2	14.8	18.5	21.0	21.9	19.0	13.1	7.6	3.8
		MCDB	1.7	4.4	12.6	22.0	24.7	29.8	33.0	31.3	28.2	21.9	14.1	6.4
	2%	WB	-0.7	1.3	6.5	10.6	13.1	16.8	19.8	20.2	17.2	11.9	6.7	2.5
		MCDB	0.7	2.8	11.3	18.1	22.8	28.1	31.4	30.5	26.4	20.4	11.8	5.0
	5%	WB	-1.7	0.5	5.5	9.7	12.3	15.9	18.7	18.7	15.9	10.8	5.7	1.1
		MCDB	-0.3	1.9	10.1	16.3	21.1	26.7	30.2	29.5	25.4	18.8	10.3	3.9
	10%	WB	-2.7	-0.5	4.5	8.9	11.5	14.9	17.7	17.6	14.8	9.7	4.6	-0.1
		MCDB	-1.2	1.2	8.9	15.2	19.5	25.3	28.9	28.5	24.4	16.9	8.8	2.7
Mean Daily Temperature Range		MDBR	8.6	8.2	8.2	9.6	11.8	13.3	13.9	14.3	14.3	12.5	9.9	8.1
	5% DB	MCDBR	8.1	7.7	10.4	12.3	14.8	15.6	15.6	15.3	15.9	15.2	12.4	9.0
		MCWBR	5.5	4.9	4.9	5.6	5.9	6.6	7.2	7.7	8.2	7.4	6.4	5.5
	5% WB	MCDBR	6.7	6.5	9.1	10.7	12.6	14.5	14.7	14.3	15.1	14.3	11.1	8.2
		MCWBR	4.9	4.4	4.9	5.4	5.8	6.8	7.3	8.3	8.2	7.6	6.0	5.4
Clear-Sky Solar Irradiance	taub	0.325	0.377	0.448	0.478	0.481	0.482	0.470	0.429	0.369	0.387	0.364	0.317	
	taud	2.002	1.864	1.758	1.789	1.838	1.859	1.911	2.043	2.188	2.038	2.025	2.095	
	Ebn at Noon	826	823	800	805	811	808	813	840	876	808	772	810	
	Edh at Noon	128	169	208	214	207	203	191	164	133	140	125	109	
All-Sky Solar Radiation	RadAvg	2.69	3.48	5.03	6.11	6.45	7.03	7.45	7.37	6.24	4.07	2.65	2.33	
	RadStd	0.17	0.31	0.31	0.46	0.46	0.55	0.48	0.36	0.25	0.44	0.30	0.15	