

ALEPPO INTL, Syrian Arab Republic

WMO: 400070

Lat: 36.181N

Lon: 37.224E

Elev: 389

StdP: 96.74

Time Zone: 2.00 (SYR)

Period: 94-12

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-2.0	-0.5	-9.3	1.8	4.2	-7.1	2.2	5.9	10.2	9.0	8.8	8.9	1.1	280	0.491

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.8	39.8	19.9	38.1	19.8	36.7	19.7	23.1	32.8	22.3	32.0	21.7	31.3	4.8	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.1	15.5	27.6	19.2	14.7	27.0	18.8	14.3	26.8	70.8	33.0	68.0	31.8	65.7	31.3	26.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
10.6	9.6	8.6	-4.4	42.7	1.5	2.2	-5.4	44.3	-6.3	45.6	-7.2	46.8	-8.3	48.4	
			DB												
			WB	-5.4	24.3	1.5	0.8	-6.4	24.9	-7.3	25.4	-8.2	25.9	-9.3	26.5

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	18.2	6.5	7.9	11.5	16.1	21.9	27.0	29.8	29.5	25.9	20.6	12.8	7.8
	DBStd	8.87	2.47	2.87	3.09	3.51	3.24	2.48	1.96	1.95	2.45	3.25	3.50	2.88
	HDD10.0	293	111	67	19	2	0	0	0	0	0	15	78	
	HDD18.3	1471	367	292	212	84	7	0	0	0	17	166	326	
	CDD10.0	3278	2	9	66	186	371	510	613	606	477	327	101	11
	CDD18.3	1414	0	0	1	18	119	260	355	348	227	86	1	0
	CDH23.3	17497	0	0	11	228	1441	3223	4756	4546	2479	796	18	0
	CDH26.7	9444	0	0	1	63	631	1782	2816	2658	1239	255	0	0
Wind	WSAvg	3.6	2.5	2.8	3.1	3.5	4.0	5.2	5.8	5.2	3.9	2.5	1.9	2.1
Precipitation	PrecAvg	323	59	51	42	33	16	2	0	0	3	23	36	55
	PrecMax	500	136	125	154	96	83	20	1	2	37	84	76	163
	PrecMin	143	4	4	2	0	0	0	0	0	0	0	0	0
	PrecStd	87	31	28	29	24	20	4	0	7	23	20	30	30
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	15.8	18.0	24.8	31.8	36.6	40.1	42.8	41.9	37.9	33.5	25.2	18.8
		MCWB	10.9	11.4	13.8	16.8	18.0	18.7	19.9	20.1	19.3	17.0	13.7	11.5
	2%	DB	13.5	16.2	22.0	28.2	34.3	38.0	40.0	39.3	35.8	31.1	23.2	16.0
		MCWB	9.2	10.3	12.7	15.3	17.3	18.4	20.1	20.4	18.8	16.7	13.1	10.8
	5%	DB	12.1	15.0	19.9	25.9	32.2	36.2	38.1	37.9	34.2	29.5	21.6	14.1
		MCWB	8.6	10.0	12.1	14.8	16.7	18.2	20.1	20.2	18.8	16.3	13.0	9.8
	10%	DB	10.9	13.3	18.0	23.8	30.3	34.7	36.6	36.2	32.9	27.9	19.5	12.7
		MCWB	7.8	9.3	11.3	14.1	16.4	18.1	20.1	20.4	18.5	16.1	12.5	9.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.8	12.6	15.7	18.1	19.7	21.6	24.1	24.1	22.2	20.0	16.2	13.2
		MCDB	14.5	16.3	21.5	26.2	30.1	32.0	34.7	33.9	30.9	27.0	20.7	15.5
	2%	WB	10.4	11.4	14.0	16.6	18.7	20.8	23.1	23.2	21.4	18.8	15.2	11.9
		MCDB	12.4	14.9	19.4	24.9	29.6	31.1	33.5	32.6	30.1	26.1	20.1	14.4
	5%	WB	9.5	10.5	12.8	15.6	17.9	20.1	22.3	22.6	20.9	18.1	14.3	11.1
		MCDB	11.2	13.9	18.1	23.7	28.6	30.9	32.3	32.0	29.5	25.7	18.8	13.1
	10%	WB	8.6	9.7	11.9	14.7	17.2	19.5	21.7	22.0	20.2	17.3	13.5	10.2
		MCDB	10.1	12.7	17.1	22.2	27.9	30.3	31.6	31.4	28.7	24.7	17.5	12.1
Mean Daily Temperature Range	5% DB	MDBR	8.1	9.4	11.1	12.4	14.3	14.2	13.8	13.7	13.6	12.8	11.3	8.6
		MCDBR	10.3	11.7	14.3	15.5	17.0	16.2	16.0	15.6	15.1	15.2	14.4	11.4
		MCWBR	6.7	7.1	7.1	6.2	5.6	4.8	4.5	4.3	4.8	6.0	6.9	7.1
	5% WB	MCDBR	8.2	10.3	12.3	13.9	14.7	14.0	13.8	13.7	13.3	12.6	10.9	8.8
		MCWBR	6.0	6.7	6.6	6.2	5.2	4.5	4.3	4.2	4.3	5.3	6.0	6.0
Clear-Sky Solar Irradiance	taub	0.369	0.394	0.421	0.478	0.460	0.411	0.411	0.425	0.398	0.424	0.381	0.367	
	taud	2.243	2.162	2.097	1.959	2.053	2.216	2.233	2.186	2.258	2.144	2.234	2.252	
	Ebn at Noon	802	827	840	811	831	871	868	849	853	783	781	776	
	Edh at Noon	106	129	150	181	168	142	139	143	126	129	106	99	
All-Sky Solar Radiation	RadAvg	2.27	3.14	4.58	5.77	6.99	8.06	7.93	7.05	5.79	4.13	2.94	2.13	
	RadStd	0.25	0.42	0.29	0.38	0.34	0.20	0.14	0.18	0.19	0.22	0.26	0.31	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (12 neighbors)	N/A	N/A	-1.92	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page