

LATAKIA, Syrian Arab Republic

WMO: 400220

Lat: 35.533N

Lon: 35.767E

Elev: 7

StdP: 101.24

Time Zone: 2.00 (SYR)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	4.3	5.9	-6.2	2.2	8.8	-3.9	2.7	9.9	15.0	13.9	12.5	14.8	2.3	60	0.360

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.0	32.6	23.6	31.6	24.5	30.9	24.6	26.7	30.6	26.2	30.1	25.8	29.6	3.0	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
25.6	20.8	29.9	25.0	20.1	29.5	24.5	19.5	29.1	84.2	30.8	81.7	30.2	79.8	29.8	30.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
10.3	8.5	7.1	1.1	36.6	2.1	2.3	-0.4	38.3	-1.6	39.6	-2.8	40.9	-4.3	42.5		
			-0.9	28.4	1.7	1.0	-2.2	29.2	-3.2	29.8	-4.1	30.4	-5.4	31.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	20.1	12.2	13.2	15.3	17.9	21.4	24.5	26.9	27.9	26.1	23.0	18.2	13.9
	DBStd	5.91	2.60	2.67	2.89	2.85	2.39	1.66	1.18	1.16	1.56	2.50	3.04	2.62
	HDD10.0	22	11	6	2	0	0	0	0	0	0	0	0	4
	HDD18.3	657	189	145	103	41	2	0	0	0	2	38	137	
	CDD10.0	3697	79	94	164	236	353	436	525	554	482	402	245	126
	CDD18.3	1292	0	1	8	27	97	186	267	296	232	146	33	1
	CDH23.3	12157	0	2	47	174	524	1449	2959	3558	2281	1003	156	3
CDH26.7	3640	0	0	9	54	144	278	896	1321	678	237	22	0	
Wind	WSAvg	2.9	3.1	3.5	3.2	3.0	2.9	2.8	3.1	2.9	2.6	2.4	2.5	2.8
Precipitation	PrecAvg	760	166	113	95	49	23	5	1	2	15	77	88	160
	PrecMax	1100	595	350	373	184	114	20	20	29	85	360	313	460
	PrecMin	434	31	12	12	1	0	0	0	0	0	0	0	7
	PrecStd	200	126	69	70	43	23	6	4	5	22	66	65	105
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	20.5	23.1	27.5	32.0	33.8	33.7	33.0	33.2	33.6	34.1	29.4	22.8
		MCWB	14.0	15.0	15.6	18.6	20.0	21.2	24.6	26.7	23.1	18.9	17.8	14.4
	2%	DB	18.9	20.8	24.0	27.8	30.3	30.2	31.4	32.1	31.3	30.7	26.9	20.8
		MCWB	13.8	14.0	15.2	17.4	19.6	23.4	25.3	26.1	24.5	20.7	17.1	14.7
	5%	DB	17.8	19.0	21.8	24.9	27.8	29.1	30.6	31.4	30.5	29.0	25.0	19.5
		MCWB	13.1	13.6	14.8	16.8	20.2	23.5	25.2	25.7	24.2	21.3	17.1	14.3
	10%	DB	16.7	17.7	19.9	22.9	25.9	28.1	30.0	30.9	29.8	27.8	23.6	18.4
		MCWB	12.4	13.1	14.6	16.8	20.2	23.1	25.0	25.5	23.9	21.1	16.8	13.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	16.3	16.8	18.2	20.4	23.2	26.0	27.4	27.8	26.8	24.6	20.8	17.1
		MCDB	18.9	20.2	23.2	26.2	27.8	29.8	31.0	31.7	30.9	29.0	24.8	20.4
	2%	WB	14.7	15.5	16.9	19.2	22.2	25.0	26.5	27.0	25.8	23.4	19.5	16.1
		MCDB	17.8	18.9	20.9	24.1	26.3	28.6	30.1	31.0	29.9	27.9	24.2	19.3
	5%	WB	13.8	14.5	16.0	18.4	21.4	24.3	25.9	26.5	25.1	22.7	18.4	15.2
		MCDB	17.0	18.0	19.8	22.8	25.5	27.9	29.6	30.4	29.3	27.2	23.4	18.6
	10%	WB	12.8	13.6	15.2	17.5	20.8	23.7	25.5	26.0	24.6	21.9	17.5	14.2
		MCDB	16.0	17.2	19.0	21.6	24.8	27.3	29.1	30.0	28.9	26.5	22.4	17.6
Mean Daily Temperature Range	5% DB	MDBR	7.7	7.9	8.2	8.3	8.0	7.0	6.2	6.0	7.6	9.1	9.5	8.3
		MCDBR	9.0	10.1	11.8	12.7	12.4	9.1	7.6	6.9	8.8	10.8	11.5	9.8
		MCWBR	5.6	6.4	7.0	7.0	7.0	6.0	5.4	4.5	5.7	6.5	6.7	6.0
	5% WB	MCDBR	7.5	8.4	9.4	10.3	9.2	7.8	6.8	6.6	7.8	9.1	9.9	8.0
		MCWBR	5.3	5.9	6.3	6.8	6.0	5.6	5.2	4.6	5.5	6.2	6.7	5.5
Clear-Sky Solar Irradiance	taub	0.381	0.406	0.441	0.493	0.483	0.444	0.466	0.475	0.437	0.439	0.396	0.380	
	taud	2.305	2.226	2.130	2.009	2.095	2.257	2.209	2.171	2.280	2.224	2.297	2.313	
	Ebn at Noon	799	822	824	799	813	843	821	806	820	776	774	772	
	Edh at Noon	101	122	146	173	161	137	143	146	124	121	101	95	
All-Sky Solar Radiation	RadAvg	2.35	3.29	4.74	5.91	7.17	7.95	7.74	6.92	5.78	4.20	2.98	2.18	
	RadStd	0.22	0.37	0.23	0.41	0.34	0.16	0.14	0.16	0.18	0.24	0.21	0.28	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (17 neighbors)	+0.28	N/A	-1.59	N/A	N/A	N/A	N/A	N/A	+141	N/A

Nomenclature: See separate page