

BASSEL AL ASSAD INTL, Syrian Arab Republic

WMO: 400250

Lat: 35.401N

Lon: 35.949E

Elev: 157

StdP: 14.61

Time Zone: 2.00 (SYR)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	37.4	40.7	19.9	15.0	49.5	24.8	18.9	49.7	30.8	58.4	23.0	57.5	4.6	60	0.363

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	15.0	91.7	72.2	89.5	74.9	88.0	75.4	79.2	87.6	78.2	86.7	77.3	85.8	7.6	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
76.6	139.5	86.1	75.4	134.0	85.0	74.5	129.8	84.3	42.9	87.6	41.9	86.8	40.9	86.0	86.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
19.6	16.5	13.9	DB	32.5	99.2	4.2	4.0	29.5	102.0	27.0	104.4	24.6	106.6	21.6	109.6
			WB	29.2	82.2	4.3	2.1	26.2	83.7	23.7	84.9	21.2	86.1	18.1	87.6

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	67.1	53.5	55.1	58.5	63.2	69.2	74.7	79.1	80.8	77.8	72.4	64.0	56.2	(6)
	DBStd	10.42	4.78	4.97	5.09	5.07	4.59	3.02	2.11	1.85	2.62	4.84	5.38	4.91	(7)
	HDD50	51	23	13	3	1	0	0	0	0	0	0	0	11	(8)
	HDD65	1309	358	278	212	91	10	0	0	0	0	5	82	273	(9)
	CDD50	6296	131	156	268	397	595	740	902	956	833	695	419	204	(10)
	CDD65	2078	0	1	11	38	140	290	437	491	383	236	50	1	(11)
	CDH74	20112	1	9	95	341	1050	2482	4712	5585	3662	1838	328	9	(12)
	CDH80	6859	0	0	16	88	320	615	1705	2269	1271	521	54	0	(13)
(14) Wind	WSAvg	6.5	6.7	7.1	7.1	6.8	6.6	6.7	6.8	6.5	6.1	5.6	5.8	6.3	(14)
(15) Precipitation	PrecAvg	33.7	6.4	5.3	3.0	2.2	0.9	0.3	0.0	0.1	0.8	2.9	4.1	7.6	(15)
	PrecMax	61.9	19.0	12.4	7.9	6.1	2.9	1.5	0.3	0.6	3.2	9.6	9.5	20.2	(16)
	PrecMin	14.2	1.2	0.9	0.6	0.2	0.1	0.0	0.0	0.0	0.3	0.0	0.0	0.7	(17)
	PrecStd	10.1	3.7	2.7	1.8	1.5	0.7	0.4	0.1	0.2	0.9	2.3	2.4	4.6	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	70.0	75.2	82.0	88.9	94.0	94.2	93.0	94.1	93.0	94.5	85.4	74.3	(19)
		MCWB	56.0	58.2	61.0	65.3	67.2	70.8	75.3	78.0	69.9	66.8	62.1	57.8	(20)
	2%	DB	66.4	70.1	76.5	82.3	88.0	87.8	89.5	90.0	89.2	88.2	80.7	70.1	(21)
		MCWB	55.4	56.4	59.3	63.5	66.7	73.1	76.6	77.8	74.7	67.0	61.5	57.3	(22)
	5%	DB	64.4	66.6	72.0	77.7	82.7	85.1	87.8	89.0	87.4	84.6	77.4	67.8	(23)
		MCWB	55.0	55.6	57.7	61.6	67.4	73.0	76.5	77.5	74.9	68.6	61.7	56.5	(24)
	10%	DB	62.4	64.4	68.2	73.8	79.1	83.2	86.3	87.9	86.0	82.4	74.8	65.3	(25)
		MCWB	53.9	54.6	58.1	61.8	67.5	72.7	76.0	77.0	74.1	69.2	61.3	55.6	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	60.3	61.4	64.4	68.9	72.9	77.6	80.2	81.3	79.4	75.9	68.5	62.1	(27)
		MCDB	65.7	69.1	75.4	83.3	82.4	85.4	88.4	90.0	87.7	84.0	75.7	69.2	(28)
	2%	WB	58.0	59.1	61.9	66.3	71.0	75.7	78.7	79.6	77.3	73.4	66.2	60.0	(29)
		MCDB	64.1	66.1	71.1	76.3	80.3	83.8	86.8	88.2	86.3	82.2	75.2	66.5	(30)
	5%	WB	56.1	57.3	60.2	64.5	69.6	74.7	77.7	78.7	76.1	71.8	64.4	58.6	(31)
		MCDB	62.5	64.8	68.4	73.5	79.0	82.8	85.8	87.2	85.3	80.8	73.9	64.9	(32)
	10%	WB	54.5	55.6	58.8	63.0	68.2	73.6	76.9	77.8	75.0	70.2	62.6	56.9	(33)
		MCDB	60.8	63.0	66.6	71.2	77.1	81.6	85.0	86.5	84.3	79.5	72.0	63.7	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	16.0	16.2	16.9	17.4	17.8	16.3	15.4	15.0	16.6	18.9	19.2	17.0	(35)
		MCDBR	18.8	20.5	23.5	24.5	24.6	20.6	17.6	16.7	18.6	22.3	22.9	20.4	(36)
	5% WB	MCWBR	11.5	12.5	13.7	13.5	13.4	13.7	11.6	10.9	12.5	13.5	12.7	12.4	(37)
		MCWBR	15.8	18.0	19.1	20.8	20.0	17.2	15.9	16.0	16.7	18.6	19.5	17.6	(38)
(40) Clear-Sky Solar Irradiance	taub		0.398	0.428	0.468	0.526	0.513	0.462	0.482	0.493	0.457	0.465	0.414	0.398	(40)
		taud	2.213	2.120	2.019	1.897	1.978	2.160	2.121	2.079	2.174	2.109	2.201	2.218	(41)
	Ebn at Noon		246	252	253	245	250	262	256	251	254	237	238	237	(42)
		Edh at Noon	35	43	52	62	57	48	49	51	44	43	36	33	(43)
(44) All-Sky Solar Radiation	RadAvg		742	1035	1492	1868	2265	2521	2459	2202	1840	1337	949	690	(44)
	RadStd		72	119	78	128	109	50	45	48	57	74	70	87	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (15 neighbors)	+0.50	N/A	-2.86	N/A	N/A	N/A	N/A	N/A	+254	N/A	N/A

Nomenclature: See separate page