

BASSEL AL ASSAD INTL, Syrian Arab Republic

WMO: 400250

Lat: 35.401N

Lon: 35.949E

Elev: 48

StdP: 100.75

Time Zone: 2.00 (SYR)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	3.0	4.9	-6.7	2.1	9.7	-4.0	2.7	9.9	13.8	14.7	10.3	14.2	2.1	60	0.363

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	8.4	33.2	22.3	31.9	23.8	31.1	24.1	26.2	30.9	25.7	30.4	25.2	29.9	3.4	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.8	19.9	30.1	24.1	19.1	29.5	23.6	18.5	29.1	81.9	30.9	79.6	30.5	77.3	30.0	30.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
8.8	7.4	6.2	DB	0.3	37.3	2.3	2.2	-1.4	38.9	-2.8	40.2	-4.1	41.5	-5.8	43.1	
			WB	-1.5	27.9	2.4	1.1	-3.2	28.7	-4.6	29.4	-6.0	30.0	-7.7	30.9	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	19.5	11.9	12.8	14.7	17.3	20.7	23.7	26.2	27.1	25.4	22.5	17.8	13.5
	DBStd	5.79	2.66	2.76	2.83	2.82	2.55	1.68	1.17	1.03	1.46	2.69	2.99	2.73
	HDD10.0	28	13	7	2	1	0	0	0	0	0	0	0	6
	HDD18.3	727	199	154	118	51	6	0	0	0	0	3	46	152
	CDD10.0	3498	73	87	149	221	331	411	501	531	463	386	233	113
	CDD18.3	1154	0	1	6	21	78	161	243	273	213	131	28	1
	CDH23.3	11173	1	5	53	189	583	1379	2618	3103	2034	1021	182	5
	CDH26.7	3811	0	0	9	49	178	342	947	1261	706	289	30	0
Wind	WSAvg	2.9	3.0	3.2	3.2	3.0	2.9	3.0	3.0	2.9	2.7	2.5	2.6	2.8
Precipitation	PrecAvg	857	163	134	77	56	22	7	1	3	21	74	104	193
	PrecMax	1573	482	316	200	154	73	39	8	16	82	244	242	513
	PrecMin	361	30	24	16	4	2	0	0	0	0	7	0	19
	PrecStd	256	94	69	45	38	19	11	2	4	22	59	61	116
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	21.1	24.0	27.8	31.6	34.4	34.6	33.9	34.5	33.9	34.7	29.6	23.5
		MCWB	13.3	14.6	16.1	18.5	19.6	21.6	24.0	25.6	21.1	19.3	16.7	14.3
	2%	DB	19.1	21.2	24.7	28.0	31.1	31.0	31.9	32.2	31.8	31.2	27.1	21.2
		MCWB	13.0	13.6	15.2	17.5	19.3	22.8	24.8	25.4	23.7	19.4	16.4	14.0
	5%	DB	18.0	19.2	22.2	25.4	28.2	29.5	31.0	31.7	30.8	29.2	25.2	19.9
		MCWB	12.8	13.1	14.3	16.4	19.7	22.8	24.7	25.3	23.8	20.3	16.5	13.6
	10%	DB	16.9	18.0	20.1	23.2	26.2	28.4	30.2	31.1	30.0	28.0	23.8	18.5
		MCWB	12.1	12.6	14.5	16.6	19.7	22.6	24.5	25.0	23.4	20.7	16.3	13.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.7	16.3	18.0	20.5	22.7	25.4	26.8	27.4	26.3	24.4	20.3	16.7
		MCDB	18.7	20.6	24.1	28.5	28.0	29.7	31.4	32.2	31.0	28.9	24.3	20.6
	2%	WB	14.4	15.0	16.6	19.0	21.6	24.3	26.0	26.5	25.2	23.0	19.0	15.6
		MCDB	17.8	18.9	21.7	24.6	26.8	28.8	30.5	31.2	30.2	27.9	24.0	19.2
	5%	WB	13.4	14.1	15.7	18.1	20.9	23.7	25.4	26.0	24.5	22.1	18.0	14.8
		MCDB	16.9	18.2	20.2	23.1	26.1	28.2	29.9	30.7	29.6	27.1	23.3	18.3
	10%	WB	12.5	13.1	14.9	17.2	20.1	23.1	25.0	25.5	23.9	21.2	17.0	13.8
		MCDB	16.0	17.2	19.2	21.8	25.1	27.6	29.5	30.3	29.1	26.4	22.2	17.6
Mean Daily Temperature Range	5% DB	MDBR	8.9	9.0	9.4	9.7	9.9	9.1	8.5	8.4	9.2	10.5	10.6	9.5
		MCDBR	10.4	11.4	13.0	13.6	13.7	11.4	9.8	9.3	10.4	12.4	12.7	11.3
		MCWBR	6.4	6.9	7.6	7.5	7.5	7.6	6.5	6.0	6.9	7.5	7.1	6.9
	5% WB	MCDBR	8.8	10.0	10.6	11.6	11.1	9.5	8.8	8.9	9.3	10.3	10.8	9.8
		MCWBR	6.1	6.7	7.1	7.6	7.3	7.0	6.2	6.1	6.7	7.2	6.9	6.7
Clear-Sky Solar Irradiance	taub	0.398	0.428	0.468	0.526	0.513	0.462	0.482	0.493	0.457	0.465	0.414	0.398	
	taud	2.213	2.120	2.019	1.897	1.978	2.160	2.121	2.079	2.174	2.109	2.201	2.218	
	Ebn at Noon	776	795	797	771	788	827	807	790	800	748	750	746	
	Edh at Noon	111	136	163	194	181	151	156	160	138	136	112	105	
All-Sky Solar Radiation	RadAvg	2.34	3.26	4.71	5.89	7.14	7.95	7.75	6.94	5.80	4.21	2.99	2.18	
	RadStd	0.23	0.38	0.24	0.40	0.34	0.16	0.14	0.15	0.18	0.23	0.22	0.28	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (15 neighbors)	+0.28	N/A	-1.59	N/A	N/A	N/A	N/A	N/A	+141	N/A

Nomenclature: See separate page