

DEIR EZ-ZUR, Syrian Arab Republic

WMO: 400450

Lat: 35.285N

Lon: 40.176E

Elev: 700

StdP: 14.33

Time Zone: 2.00 (SYR)

Period: 94-12

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	29.0	32.0	14.1	11.5	40.1	17.8	13.9	44.5	26.6	46.8	22.8	47.8	3.9	290	0.452

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	24.2	108.6	70.3	106.3	69.7	104.1	69.1	74.8	100.8	73.3	98.7	71.9	97.4	8.9	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.9	98.1	91.2	64.1	91.9	88.9	62.4	86.6	87.5	38.8	101.4	37.4	99.1	36.1	97.5	81.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.4	22.0	18.7	24.8	112.9	4.5	2.2	21.6	114.5	19.0	115.8	16.5	117.1	13.3	118.7
			23.0	77.2	4.2	1.9	20.0	78.6	17.6	79.7	15.2	80.7	12.2	82.1
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	69.3	45.4	49.8	57.7	66.9	78.1	87.4	92.7	91.4	83.2	72.7	56.9	48.4
	DBStd	17.45	4.78	5.48	5.72	6.29	5.84	4.40	3.54	3.44	4.46	5.78	6.41	5.27
	HDD50	336	153	64	7	1	0	0	0	0	0	0	18	93
	HDD65	2090	607	425	236	48	1	0	0	0	0	10	248	515
	CDD50	7392	11	59	247	507	871	1123	1324	1283	996	703	225	43
	CDD65	3670	0	0	10	104	407	673	859	818	546	248	5	0
	CDH74	52485	0	0	143	1128	4955	9974	14006	12886	6922	2411	58	2
	CDH80	32372	0	0	30	390	2581	6272	9626	8595	3897	978	3	0
Wind	WSAvg	6.6	4.3	5.5	6.6	7.1	7.8	10.1	10.5	8.1	6.7	4.3	3.8	3.9
Precipitation	PrecAvg	6.1	1.1	0.9	1.0	0.7	0.3	0.0	0.0	0.0	0.0	0.3	0.6	0.8
	PrecMax	11.8	3.6	3.2	5.2	3.8	2.3	0.3	1.1	0.0	0.6	1.3	2.6	2.8
	PrecMin	1.9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	2.3	0.8	0.8	1.2	0.9	0.5	0.0	0.2	0.0	0.1	0.4	0.7	0.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	62.6	69.6	84.2	95.4	102.9	109.0	112.3	110.6	104.1	95.6	79.1	68.1
		MCWB	52.8	53.2	59.4	64.1	68.7	68.0	71.9	71.4	68.6	66.3	57.4	54.8
	2%	DB	59.4	66.2	77.4	89.3	98.6	105.5	109.5	107.9	100.6	91.9	75.2	63.4
		MCWB	50.8	52.3	56.3	62.2	65.6	67.4	70.7	71.3	68.4	65.5	57.4	53.0
	5%	DB	57.0	63.4	73.5	84.8	95.4	102.9	107.1	105.5	98.2	88.7	72.4	60.5
		MCWB	49.8	51.5	55.6	60.5	64.7	66.8	69.8	70.3	68.0	64.2	56.7	51.7
	10%	DB	54.6	60.5	70.0	80.9	92.4	100.5	104.8	103.1	95.6	85.5	69.4	57.7
		MCWB	48.4	50.3	54.1	59.3	63.8	66.3	69.3	70.0	67.6	63.7	55.9	50.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	55.2	56.6	62.5	66.6	71.3	72.1	76.7	77.6	73.7	69.5	62.9	56.5
		MCDB	59.8	63.9	74.8	88.2	97.2	100.1	104.5	102.4	95.8	89.4	72.0	62.9
	2%	WB	52.7	54.1	59.4	63.8	68.5	70.3	74.8	75.3	71.8	67.6	61.0	54.7
		MCDB	57.3	62.3	71.2	82.6	91.5	98.0	102.4	100.4	94.7	86.6	69.5	60.5
	5%	WB	51.0	52.6	57.5	62.0	66.6	69.0	73.2	73.7	70.4	66.0	59.2	53.2
		MCDB	55.2	60.9	69.3	80.3	89.9	96.6	99.8	98.6	93.2	84.6	67.8	58.7
	10%	WB	49.3	51.2	55.6	60.5	65.1	67.8	71.6	72.4	69.0	64.6	57.1	51.7
		MCDB	53.2	59.1	67.6	77.7	88.2	95.3	98.7	97.2	91.5	81.9	66.3	56.6
Mean Daily Temperature Range	5% DB	MDBR	17.2	19.0	21.6	23.2	24.5	24.3	24.2	24.6	25.0	24.2	22.6	18.5
		MCDBR	20.4	22.8	26.6	28.5	28.4	26.5	25.9	26.7	27.6	28.3	26.3	21.5
		MCWBR	12.9	12.0	12.7	11.2	10.6	9.4	9.6	10.6	12.4	13.0	13.9	13.1
	5% WB	MCDBR	16.8	19.4	22.6	24.8	25.7	24.8	24.6	24.8	25.1	24.4	21.3	17.9
		MCWBR	11.6	11.3	11.5	10.8	10.5	9.5	9.7	10.9	12.2	12.1	12.0	11.6
Clear-Sky Solar Irradiance	taub	0.387	0.417	0.450	0.529	0.530	0.480	0.478	0.471	0.445	0.483	0.408	0.392	
	taud	2.087	2.008	1.933	1.765	1.785	1.911	1.930	1.950	2.002	1.898	2.054	2.072	
	Ebn at Noon	247	254	258	244	246	258	257	256	256	229	237	235	
	Edh at Noon	40	48	56	70	70	62	60	57	52	53	41	38	
All-Sky Solar Radiation	RadAvg	867	1151	1576	1917	2261	2550	2441	2187	1839	1361	1011	784	
	RadStd	55	95	76	98	113	84	60	74	77	79	75	70	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page