

DARAA, Syrian Arab Republic

WMO: 400950

Lat: 32.600N

Lon: 36.100E

Elev: 543

StdP: 94.97

Time Zone: 2.00 (SYR)

Period: 94-11

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	1.1	2.6	-9.8	1.7	10.1	-7.0	2.2	12.6	11.1	13.0	9.2	10.5	0.6	150	0.365

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.7	36.5	19.3	35.0	19.4	33.6	19.6	22.9	31.3	22.2	30.0	21.6	28.9	3.8	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.7	16.4	25.2	20.1	15.8	24.9	19.4	15.1	24.5	70.9	30.6	68.0	30.1	65.6	28.9	30.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
9.1	7.8	6.7	-1.5	40.1	1.9	2.3	-2.9	41.8	-3.9	43.2	-5.0	44.5	-6.4	46.2		
			DB	WB	DB	WB	DB	WB	DB	WB	DB	WB	DB	WB		
			-2.9	24.7	2.0	2.2	-4.4	26.3	-5.5	27.6	-6.7	28.9	-8.2	30.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	18.3	9.1	10.2	13.1	16.7	21.1	24.4	26.4	26.6	24.5	21.1	15.2	10.7
	DBStd	6.87	2.55	2.68	3.51	3.79	3.28	2.14	1.63	1.70	1.90	3.12	3.34	2.67
	HDD10.0	107	46	26	8	1	0	0	0	0	0	0	3	24
	HDD18.3	1117	285	229	168	74	11	0	0	0	0	10	102	238
	CDD10.0	3142	19	31	104	203	344	432	508	516	435	345	161	44
	CDD18.3	1109	0	0	6	27	96	182	250	257	185	97	9	1
	CDH23.3	11565	0	4	89	401	1189	1966	2586	2593	1710	919	107	1
	CDH26.7	5267	0	0	22	137	516	936	1274	1275	731	358	19	0
Wind	WSAvg	2.0	2.0	2.0	2.2	2.2	2.3	2.5	2.8	2.4	1.7	1.3	1.3	1.5
Precipitation	PrecAvg	264	61	58	33	15	4	1	0	0	1	10	27	53
	PrecMax	467	167	168	86	136	28	17	4	0	5	32	133	143
	PrecMin	113	1	9	0	0	0	0	0	0	0	0	0	8
	PrecStd	109	41	42	25	29	6	4	1	0	1	10	32	42
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	19.8	23.1	29.2	33.5	37.3	37.7	38.3	38.4	36.7	35.5	28.9	21.9
		MCWB	10.7	12.4	14.7	16.5	17.8	18.6	21.2	20.6	18.4	17.4	14.5	11.0
	2%	DB	17.4	19.3	25.9	30.2	34.1	35.7	35.6	35.3	34.2	32.5	26.2	19.0
		MCWB	10.1	10.6	13.5	15.3	17.1	18.4	20.7	21.1	18.6	16.5	13.7	10.4
	5%	DB	15.7	17.5	23.0	28.1	31.9	33.7	34.0	33.7	32.4	30.3	24.0	17.2
		MCWB	9.7	10.0	12.2	14.6	16.6	18.6	20.6	21.2	19.1	16.2	13.4	10.2
	10%	DB	14.2	15.6	20.5	25.5	29.7	31.7	32.7	32.5	30.7	28.3	22.2	15.7
		MCWB	8.9	9.6	11.8	14.0	16.1	18.6	20.3	20.8	18.9	16.5	12.8	9.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.1	13.8	16.6	18.2	20.5	21.7	24.0	24.2	23.0	19.7	16.7	13.4
		MCDB	16.9	20.6	24.9	28.1	31.9	31.0	33.2	33.7	31.5	27.0	23.1	17.8
	2%	WB	11.3	11.8	14.6	16.7	18.7	20.7	22.7	23.1	21.6	18.8	15.6	12.4
		MCDB	14.9	17.2	22.3	26.6	30.1	30.1	31.7	31.1	28.4	26.3	22.1	16.2
	5%	WB	10.5	10.9	13.5	15.6	17.6	20.0	21.9	22.4	20.8	18.2	14.8	11.5
		MCDB	14.1	15.4	21.1	25.5	28.6	29.1	30.4	29.9	27.2	25.3	21.2	15.1
	10%	WB	9.7	10.2	12.4	14.6	16.8	19.4	21.3	21.8	20.2	17.6	14.0	10.8
		MCDB	13.2	14.0	18.8	24.2	27.3	28.4	29.1	28.8	26.5	24.7	20.3	14.1
Mean Daily Temperature Range	5% DB	MDBR	8.9	8.9	10.8	12.8	14.1	13.8	12.7	12.5	12.7	12.9	12.1	9.7
		MCDBR	11.8	13.0	15.8	17.2	18.0	17.4	14.7	14.2	15.7	16.6	15.2	12.4
		MCWBR	6.6	6.5	7.0	7.1	6.6	6.0	5.0	4.3	5.2	6.7	7.1	6.7
	5% WB	MCDBR	9.4	10.4	13.6	14.8	15.5	14.2	13.0	12.6	12.2	13.3	12.5	9.4
		MCWBR	6.0	5.9	6.8	7.1	6.3	5.2	4.5	3.9	4.4	6.0	6.5	5.8
Clear-Sky Solar Irradiance	taub	0.348	0.377	0.418	0.461	0.461	0.392	0.400	0.405	0.396	0.416	0.369	0.351	
	taud	2.319	2.220	2.085	1.973	2.005	2.238	2.225	2.210	2.239	2.167	2.285	2.320	
	Ebn at Noon	858	867	856	833	835	891	882	873	867	813	825	831	
	Edh at Noon	103	126	155	182	177	140	141	141	131	131	106	98	
All-Sky Solar Radiation	RadAvg	2.91	3.69	5.14	6.30	7.44	8.29	8.04	7.35	6.25	4.69	3.47	2.73	
	RadStd	0.20	0.34	0.32	0.36	0.34	0.12	0.09	0.11	0.16	0.20	0.20	0.18	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (21 neighbors)	+0.44	N/A	-1.73	N/A	N/A	N/A	N/A	-64	+158	+103

Nomenclature: See separate page