

TEL AVIV SDE DOV, Israel

WMO: 401762

Lat: 32.114N

Lon: 34.782E

Elev: 13

StdP: 101.17

Time Zone: 2.00 (ISR)

Period: 94-07

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 8.5	(c) 9.5	(d) -1.5	(e) 3.3	(f) 17.6	(g) 0.9	(h) 4.0	(i) 16.1	(j) 14.6	(k) 14.8	(l) 13.5	(m) 14.8	(n) 2.9	(o) 100	(p) N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 5.1	(c) 31.2	(d) 24.4	(e) 30.5	(f) 24.5	(g) 30.0	(h) 24.4	(i) 26.8	(j) 29.6	(k) 26.2	(l) 29.2	(m) 25.6	(n) 28.9	(o) 4.9	(p) 300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) 26.1	(b) 21.5	(c) 29.1	(d) 25.2	(e) 20.3	(f) 28.7	(g) 24.6	(h) 19.6	(i) 28.4	(j) 84.7	(k) 29.6	(l) 81.6	(m) 29.3	(n) 79.1	(o) 29.0	(p) 31.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 11.3	(b) 9.4	(c) 8.0	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		
(a) 11.3	(b) 9.4	(c) 8.0	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	20.9	14.1	14.3	15.9	18.7	21.7	24.7	26.9	27.6	26.5	23.9	19.9	15.7		
	DBStd	5.22	1.87	1.82	2.44	2.91	2.03	1.34	0.89	0.87	1.20	2.18	2.11	2.01		
	HDD10.0	1	1	1	0	0	0	0	0	0	0	0	0	0		
	HDD18.3	449	131	114	86	24	1	0	0	0	0	1	8	85		
	CDD10.0	3963	129	121	182	261	362	441	524	546	496	430	296	176		
	CDD18.3	1368	1	1	9	35	104	191	266	288	246	172	54	3		
	CDH23.3	12038	4	7	60	211	334	1326	2845	3327	2567	1167	186	5		
	CDH26.7	2959	1	1	18	92	61	161	717	1060	653	173	22	0		
(14) Wind	WSAvg	3.8	3.9	4.4	4.2	4.1	3.8	3.8	3.7	3.6	3.7	3.7	3.7	3.6		
(15) Precipitation	PrecAvg	549	152	96	53	17	4	0	0	0	1	23	76	127		
	PrecMax	1029	379	287	154	100	32	4	0	1	9	124	364	398		
	PrecMin	264	12	3	0	0	0	0	0	0	0	0	9	13		
	PrecStd	190	75	62	48	22	6	1	0	0	2	32	81	88		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	22.3	23.8	30.1	35.1	32.3	30.2	31.3	31.6	31.8	32.2	29.6	24.0		
		MCWB	14.1	13.4	16.0	18.1	20.0	23.1	26.0	25.8	25.2	20.6	16.4	15.7		
	2%	DB	20.2	20.3	25.0	28.8	28.0	29.0	30.3	30.9	30.6	29.8	26.9	22.0		
		MCWB	13.9	14.4	14.9	17.2	19.5	23.5	25.5	25.7	24.3	22.4	17.4	15.4		
	5%	DB	19.0	18.8	21.4	24.9	26.1	28.1	29.9	30.4	30.0	28.3	25.4	20.7		
		MCWB	14.4	14.1	15.5	17.0	20.3	23.4	25.2	25.2	24.0	22.5	18.5	15.3		
	10%	DB	18.0	17.7	19.5	22.5	25.0	27.5	29.2	30.0	29.3	27.4	24.2	19.7		
		MCWB	14.0	13.7	15.6	17.5	20.3	23.1	24.7	25.0	23.7	22.3	18.1	15.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	17.6	17.1	18.7	20.0	23.1	25.7	27.9	28.1	26.6	25.6	22.5	18.2		
		MCDB	19.7	20.6	21.1	23.6	25.8	28.6	29.9	30.5	29.7	27.7	25.7	21.5		
	2%	WB	16.1	15.8	18.0	19.2	22.1	24.9	26.8	27.1	25.9	24.9	21.3	17.1		
		MCDB	18.5	18.5	21.0	23.4	25.2	27.6	29.4	29.7	29.2	27.5	24.7	20.2		
	5%	WB	15.1	15.1	17.0	18.5	21.5	24.2	26.1	26.3	25.2	24.1	20.2	16.2		
		MCDB	18.0	17.7	19.7	23.0	24.6	27.2	29.0	29.4	28.9	27.1	23.7	19.5		
	10%	WB	14.2	14.3	16.2	17.9	20.9	23.7	25.5	25.7	24.6	23.1	19.2	15.5		
		MCDB	17.2	17.1	19.1	22.2	24.0	26.8	28.6	29.2	28.5	26.7	23.0	18.9		
(35) Mean Daily Temperature Range	5% DB	MDBR	6.4	6.4	6.2	6.5	5.9	5.2	4.9	5.1	5.7	6.2	7.3	6.6		
		MCDBR	8.2	8.6	10.1	12.3	8.5	6.1	5.4	5.4	6.4	7.3	9.3	8.4		
		MCWBR	5.7	5.9	5.5	5.2	4.9	3.8	3.2	3.2	4.1	4.6	5.9	5.6		
	5% WB	MCDBR	6.9	7.2	6.9	8.3	6.6	5.6	4.8	5.0	6.2	6.1	7.2	6.7		
		MCWBR	5.8	5.8	4.8	5.0	4.5	3.9	3.5	3.8	5.1	4.8	6.4	5.4		
(40) Clear-Sky Solar Irradiance	taub	0.388	0.421	0.463	0.496	0.491	0.425	0.439	0.446	0.435	0.447	0.400	0.383			
	taud	2.265	2.154	2.033	1.965	2.014	2.252	2.222	2.206	2.237	2.182	2.286	2.306			
	Ebn at Noon	815	822	815	805	810	862	848	838	832	786	795	798			
	Edh at Noon	111	136	165	183	176	138	142	142	133	130	108	101			
(44) All-Sky Solar Radiation	RadAvg	2.95	3.80	5.22	6.39	7.40	8.09	7.86	7.17	6.12	4.63	3.44	2.74			
	RadStd	0.18	0.28	0.29	0.28	0.29	0.12	0.09	0.11	0.15	0.20	0.17	0.17			

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (15 neighbors)		+0.46	N/A	-2.47	N/A	N/A	N/A	N/A	-77	+152	+103

Nomenclature: See separate page