

TEL AVIV BEN GURION, Israel

WMO: 401800

Lat: 32.011N

Lon: 34.887E

Elev: 135

StdP: 14.62

Time Zone: 2.00 (ISR)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	43.2	45.8	24.4	18.6	66.3	29.3	23.4	67.1	27.8	57.5	24.3	57.9	4.4	120	0.394

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	14.4	95.4	68.8	92.4	71.4	90.0	73.1	78.7	87.8	77.4	86.8	76.4	85.9	11.6	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
75.6	134.7	84.7	74.7	130.7	84.0	73.4	124.8	83.4	42.3	87.4	41.0	86.8	40.0	86.1	88.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
21.3	18.9	16.7	DB	38.8	104.8	2.9	3.6	36.7	107.4	35.1	109.5	33.5	111.5	31.4	114.1
			WB	36.0	80.1	3.2	2.8	33.7	82.1	31.9	83.7	30.1	85.2	27.8	87.3

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	70.1	56.4	57.8	61.7	67.2	73.1	77.9	81.6	82.5	80.2	75.2	67.4	59.8	(6)
	DBStd	10.13	4.01	4.57	5.78	6.25	5.09	3.10	2.07	1.90	2.38	4.16	5.03	4.31	(7)
	HDD50	7	4	2	0	0	0	0	0	0	0	0	0	1	(8)
	HDD65	854	269	209	139	36	1	0	0	0	0	1	29	170	(9)
	CDD50	7351	202	219	363	517	716	836	979	1008	905	781	521	304	(10)
	CDD65	2723	2	7	36	103	252	386	514	543	455	317	100	8	(11)
	CDH74	27298	17	77	387	1048	2128	3618	5790	6392	4638	2480	654	69	(12)
	CDH80	10350	2	18	143	451	827	1294	2359	2676	1683	737	152	8	(13)
(14) Wind	WSAvg	7.3	7.3	7.5	7.5	7.6	7.5	7.6	7.9	7.4	7.1	6.6	6.6	7.0	(14)
(15) Precipitation	PrecAvg	21.3	5.7	3.9	2.4	0.7	0.1	0.0	0.0	0.0	0.0	0.9	2.8	5.8	(15)
	PrecMax	47.2	20.7	13.6	6.8	6.1	1.7	0.2	0.0	0.1	0.3	4.5	13.4	18.3	(16)
	PrecMin	7.6	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.4	(17)
	PrecStd	7.8	3.3	2.6	1.7	1.1	0.3	0.0	0.0	0.0	0.0	1.1	2.9	4.1	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	75.6	82.6	91.8	98.7	101.4	98.7	95.4	95.0	96.8	96.6	89.0	80.6	(19)
		MCWB	57.3	59.1	61.9	65.1	66.7	68.0	73.7	77.3	71.8	67.1	63.5	57.9	(20)
	2%	DB	71.3	75.2	83.8	91.1	93.5	91.5	91.8	91.7	91.2	90.0	84.2	75.2	(21)
		MCWB	56.0	57.1	60.5	63.7	65.7	70.0	74.4	76.3	73.7	68.3	62.8	58.1	(22)
	5%	DB	68.0	70.4	77.3	84.5	87.9	88.2	90.0	90.0	88.3	86.2	80.7	71.5	(23)
		MCWB	55.3	56.1	59.2	61.9	65.4	71.2	74.6	75.9	74.0	69.3	62.2	57.2	(24)
	10%	DB	64.8	66.8	72.0	79.2	83.9	86.3	88.6	89.3	87.2	83.9	77.3	68.4	(25)
		MCWB	54.8	55.6	58.4	61.2	65.9	71.3	74.4	75.6	73.4	69.1	62.0	57.0	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	61.8	62.5	66.2	69.6	72.5	76.5	80.0	80.9	79.2	76.5	69.9	64.6	(27)
		MCDB	68.0	71.9	81.3	87.4	85.2	86.9	89.0	90.0	88.2	84.2	79.2	72.4	(28)
	2%	WB	59.1	60.1	63.2	66.4	70.5	75.0	78.0	79.2	77.1	74.2	67.8	61.8	(29)
		MCDB	66.5	69.6	74.4	81.0	82.2	85.3	87.3	88.2	86.7	82.6	76.9	69.8	(30)
	5%	WB	57.5	58.4	61.4	64.7	69.3	73.9	76.7	78.0	75.8	72.5	66.2	59.9	(31)
		MCDB	64.9	67.0	71.7	77.2	80.7	83.9	86.3	87.2	85.4	81.5	75.6	67.8	(32)
	10%	WB	56.1	57.0	59.9	63.2	67.9	72.7	75.7	76.9	74.6	71.0	64.5	58.4	(33)
		MCDB	63.2	65.0	69.7	74.9	78.8	82.5	85.4	86.3	84.3	80.6	73.6	65.9	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	16.0	17.2	18.1	19.7	19.1	16.6	15.1	14.4	15.1	16.8	18.2	16.7	(35)
		MCDBR	21.8	24.4	27.1	29.9	28.0	20.6	17.2	15.4	16.8	21.2	22.8	22.1	(36)
		MCWBR	11.9	12.3	11.8	11.9	11.5	9.2	8.2	7.0	8.0	10.6	11.0	11.6	(37)
	5% WB	MCDBR	17.6	19.9	21.5	23.2	20.9	17.1	15.4	14.9	15.4	16.9	18.5	17.6	(38)
		MCWBR	11.1	11.9	11.2	11.3	10.4	8.3	7.5	7.3	8.2	9.4	11.0	11.0	(39)
(40) Clear-Sky Solar Irradiance	taub		0.390	0.424	0.469	0.504	0.500	0.431	0.444	0.451	0.441	0.454	0.404	0.386	(40)
	taud		2.238	2.125	1.999	1.925	1.970	2.210	2.184	2.168	2.194	2.138	2.250	2.274	(41)
	Ebn at Noon		258	260	257	253	255	272	268	265	262	247	251	252	(42)
	Edh at Noon		36	44	54	61	58	46	47	47	44	43	36	33	(43)
(44) All-Sky Solar Radiation	RadAvg		945	1210	1658	2028	2350	2575	2502	2288	1951	1477	1100	879	(44)
(45)	RadStd		59	89	95	89	93	39	27	35	48	62	56	54	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (15 neighbors)	+0.81	N/A	-3.60	N/A	N/A	N/A	N/A	-108	+256	+189
		+0.83	N/A	-4.45	N/A	N/A	N/A	N/A	-139	+274	+185

Nomenclature: See separate page