

BEER SHEVA TEYMAN, Israel

WMO: 401910

Lat: 31.287N

Lon: 34.723E

Elev: 656

StdP: 14.35

Time Zone: 2.00 (ISR)

Period: 94-05

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 42.5	(c) 44.2	(d) 23.2	(e) 17.9	(f) 69.3	(g) 27.9	(h) 22.4	(i) 68.6	(j) 27.0	(k) 52.2	(l) 24.8	(m) 56.2	(n) 9.2	(o) 120	(p) 0.395

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.1	96.4	67.2	93.4	68.0	91.0	69.2	76.2	84.8	75.2	83.8	74.3	82.6	12.1	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
74.3	131.2	78.2	73.1	126.1	77.8	72.0	121.1	77.7	40.1	85.0	39.2	83.5	38.4	82.9	82.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 21.5	(b) 18.7	(c) 16.7	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		
(a) 21.5	(b) 18.7	(c) 16.7	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	68.1	54.2	54.8	58.7	66.0	72.2	76.5	80.4	80.2	77.7	72.9	65.7	57.0
	DBStd	10.63	4.19	4.54	6.21	7.29	5.36	3.50	2.27	2.29	3.29	4.97	5.27	4.58
	HDD50	20	9	7	1	0	0	0	0	0	0	0	0	3
	HDD65	1221	336	288	219	66	4	0	0	0	0	4	51	253
	CDD50	6626	139	143	270	481	688	794	944	937	830	711	470	219
	CDD65	2352	1	3	24	97	226	344	479	472	380	250	72	4
	CDH74	20817	8	38	242	1111	2136	2988	4679	4395	3186	1633	373	28
CDH80	8494	0	8	83	497	892	1212	2167	1870	1203	487	71	4	
Wind	WSAvg	7.8	8.6	8.7	8.1	8.4	7.7	7.4	7.3	6.8	6.9	7.0	8.2	8.4
Precipitation	PrecAvg	13.0	3.5	2.5	1.5	0.3	0.1	0.0	0.0	0.0	0.0	0.6	1.5	3.0
	PrecMax	25.5	6.8	6.4	5.4	1.8	0.6	0.2	0.0	0.0	0.3	2.7	7.5	8.1
	PrecMin	5.7	0.1	0.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.2	0.2
	PrecStd	4.8	1.7	1.5	1.3	0.5	0.1	0.0	0.0	0.0	0.1	0.7	1.7	2.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	73.8	79.7	90.0	100.2	100.2	99.7	97.9	95.6	98.9	93.7	86.0	77.5
		MCWB	54.7	56.5	60.4	62.9	65.3	66.6	70.1	72.3	67.8	65.7	63.3	56.8
	2%	DB	68.4	71.1	79.9	92.0	93.8	92.2	94.4	92.7	92.6	88.8	81.4	72.4
		MCWB	54.5	54.4	57.6	60.9	63.3	67.3	69.5	72.1	69.7	67.4	60.7	55.1
	5%	DB	64.7	66.6	74.8	86.1	88.4	89.3	91.9	90.5	88.6	84.9	78.0	68.3
		MCWB	53.7	53.3	57.4	59.9	64.0	67.8	70.3	72.5	70.5	68.0	60.0	54.8
	10%	DB	62.0	63.6	69.1	80.4	84.6	86.3	89.8	88.5	86.0	81.7	74.8	65.3
		MCWB	53.2	52.9	56.3	59.1	63.9	68.1	70.4	72.4	70.4	67.7	59.6	54.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	60.0	59.4	64.8	66.4	69.8	74.1	76.9	78.0	76.4	75.4	68.7	60.7
		MCDB	64.5	70.1	76.5	86.1	84.9	85.1	87.0	86.0	85.8	83.7	75.6	67.5
	2%	WB	57.3	57.2	61.6	63.8	68.1	72.4	75.5	76.6	74.7	73.3	66.0	58.9
		MCDB	62.4	65.7	73.1	79.7	80.2	81.6	84.6	84.7	82.6	79.8	72.8	66.0
	5%	WB	55.7	55.7	59.5	62.3	66.9	71.1	74.6	75.7	73.6	72.0	64.4	57.3
		MCDB	62.0	62.8	69.1	77.3	78.7	79.7	83.3	84.0	81.4	78.2	72.5	64.5
	10%	WB	54.3	54.0	57.7	60.9	65.7	70.1	73.6	74.7	72.5	70.4	62.9	55.9
		MCDB	60.6	60.7	66.3	75.5	77.3	79.2	82.0	83.0	80.9	77.3	70.8	62.8
Mean Daily Temperature Range	5% DB	MDBR	14.8	16.2	17.7	21.5	22.5	20.5	20.1	19.0	19.1	17.9	17.2	15.5
		MCDBR	19.6	22.1	25.5	29.8	29.3	25.0	23.2	20.7	22.6	21.3	21.0	19.9
		MCWBR	10.1	11.0	10.5	10.2	9.0	7.5	6.9	6.1	7.5	8.4	9.1	9.5
	5% WB	MCDBR	16.0	19.4	21.4	24.6	23.8	20.1	19.5	18.8	19.5	18.4	17.1	16.7
		MCWBR	10.1	11.0	10.1	10.2	8.6	6.8	6.5	6.2	8.3	7.8	8.7	10.0
Clear-Sky Solar Irradiance	taub		0.365	0.398	0.441	0.478	0.476	0.409	0.416	0.422	0.421	0.432	0.380	0.363
	taud		2.241	2.128	2.003	1.915	1.952	2.182	2.177	2.165	2.169	2.121	2.245	2.266
	Ebn at Noon		268	269	266	260	261	278	276	273	269	254	260	262
	Edh at Noon		36	44	54	61	60	47	47	47	45	44	36	34
All-Sky Solar Radiation	RadAvg		1001	1270	1699	2064	2359	2579	2502	2300	1964	1508	1140	935
	RadStd		54	76	90	71	90	33	32	31	48	55	54	46

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (20 neighbors)	+0.81	N/A	-3.82	N/A	N/A	N/A	N/A	N/A	-108	+272	+193

Nomenclature: See separate page