

BEER SHEVA TEYMAN, Israel

WMO: 401910

Lat: 31.287N

Lon: 34.723E

Elev: 200

StdP: 98.95

Time Zone: 2.00 (ISR)

Period: 94-05

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 5.8	(c) 6.8	(d) -4.9	(e) 2.6	(f) 20.7	(g) -2.3	(h) 3.2	(i) 20.3	(j) 12.1	(k) 11.2	(l) 11.1	(m) 13.4	(n) 4.1	(o) 120	(p) 0.395

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.1	35.8	19.5	34.1	20.0	32.8	20.7	24.6	29.3	24.0	28.8	23.5	28.1	5.4	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.5	18.7	25.7	22.8	18.0	25.5	22.2	17.3	25.4	75.5	29.5	73.4	28.6	71.3	28.3	27.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 9.6	(b) 8.4	(c) 7.4	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		
(a) 9.6	(b) 8.4	(c) 7.4	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	20.1	12.3	12.7	14.8	18.9	22.3	24.7	26.9	26.8	25.4	22.7	18.7	13.9
	DBStd	5.90	2.33	2.52	3.45	4.05	2.98	1.94	1.26	1.27	1.83	2.76	2.93	2.54
	HDD10.0	11	5	4	1	0	0	0	0	0	0	0	0	2
	HDD18.3	678	187	160	122	37	2	0	0	0	0	2	28	141
	CDD10.0	3681	77	79	150	267	382	441	524	521	461	395	261	122
	CDD18.3	1307	1	2	13	54	126	191	266	262	211	139	40	2
	CDH23.3	11565	4	21	134	617	1187	1660	2599	2442	1770	907	207	16
	CDH26.7	4719	0	4	46	276	496	673	1204	1039	668	271	39	2
Wind	WSAvg	3.5	3.8	3.9	3.6	3.7	3.5	3.3	3.3	3.1	3.1	3.1	3.6	3.8
Precipitation	PrecAvg	331	89	63	38	8	2	0	0	0	1	14	38	77
	PrecMax	648	172	162	136	46	14	4	0	0	8	69	190	207
	PrecMin	144	2	15	0	0	0	0	0	0	0	0	6	4
	PrecStd	122	44	39	33	13	3	1	0	0	2	17	44	58
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	23.2	26.5	32.2	37.9	37.9	37.6	36.6	35.3	37.2	34.3	30.0	25.3
		MCWB	12.6	13.6	15.8	17.2	18.5	19.2	21.2	22.4	19.9	18.7	17.4	13.8
	2%	DB	20.2	21.7	26.6	33.3	34.3	33.4	34.7	33.7	33.6	31.6	27.5	22.4
		MCWB	12.5	12.4	14.2	16.0	17.4	19.6	20.9	22.3	20.9	19.7	15.9	12.9
	5%	DB	18.2	19.2	23.8	30.0	31.4	31.8	33.3	32.5	31.5	29.4	25.6	20.2
		MCWB	12.1	11.8	14.1	15.5	17.8	19.9	21.3	22.5	21.4	20.0	15.5	12.7
	10%	DB	16.7	17.6	20.6	26.9	29.2	30.2	32.1	31.4	30.0	27.6	23.8	18.5
		MCWB	11.8	11.6	13.5	15.0	17.7	20.0	21.3	22.5	21.3	19.8	15.3	12.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.5	15.2	18.2	19.1	21.0	23.4	24.9	25.6	24.6	24.1	20.4	15.9
		MCDB	18.1	21.2	24.7	30.1	29.4	29.5	30.6	30.0	29.9	28.7	24.2	19.7
	2%	WB	14.1	14.0	16.4	17.7	20.1	22.4	24.1	24.8	23.7	23.0	18.9	14.9
		MCDB	16.9	18.7	22.9	26.5	26.8	27.6	29.2	29.3	28.1	26.5	22.7	18.9
	5%	WB	13.2	13.2	15.3	16.8	19.4	21.7	23.6	24.3	23.1	22.2	18.0	14.1
		MCDB	16.7	17.1	20.6	25.1	25.9	26.5	28.5	28.9	27.4	25.7	22.5	18.1
	10%	WB	12.4	12.2	14.3	16.0	18.7	21.2	23.1	23.7	22.5	21.3	17.2	13.3
		MCDB	15.9	16.0	19.0	24.2	25.2	26.2	27.8	28.3	27.2	25.2	21.6	17.1
Mean Daily Temperature Range	5% DB	MDBR	8.2	9.0	9.8	12.0	12.5	11.4	11.1	10.5	10.6	10.0	9.6	8.6
		MCDBR	10.9	12.3	14.2	16.6	16.3	13.9	12.9	11.5	12.5	11.8	11.7	11.1
		MCWBR	5.6	6.1	5.8	5.7	5.0	4.2	3.8	3.4	4.2	4.7	5.0	5.3
	5% WB	MCDBR	8.9	10.8	11.9	13.7	13.2	11.2	10.8	10.4	10.9	10.2	9.5	9.3
		MCWBR	5.6	6.1	5.6	5.7	4.8	3.8	3.6	3.5	4.6	4.3	4.8	5.6
Clear-Sky Solar Irradiance	taub	0.365	0.398	0.441	0.478	0.476	0.409	0.416	0.422	0.421	0.432	0.380	0.363	
	taud	2.241	2.128	2.003	1.915	1.952	2.182	2.177	2.165	2.169	2.121	2.245	2.266	
	Ebn at Noon	844	848	838	821	823	877	869	861	847	802	820	825	
	Edh at Noon	114	140	170	193	188	149	149	148	142	139	112	106	
All-Sky Solar Radiation	RadAvg	3.16	4.00	5.36	6.51	7.44	8.13	7.89	7.25	6.19	4.75	3.59	2.95	
	RadStd	0.17	0.24	0.28	0.22	0.28	0.10	0.10	0.10	0.15	0.17	0.17	0.14	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (20 neighbors)		+0.45	N/A	-2.12	N/A	N/A	N/A	N/A	-60	+151	+107

Nomenclature: See separate page